

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Jun 21, 2024	Inspection Result:	PASSED
Permit Number: Property Address:	PRCTI20240063 3500 S MERIDIAN, Unit: 530, PUYALLUP, WA 98373;		
Contractor:	MARCO CONTRACTORS INC 100 COMMONWEALTH DR		
To construct:	WARRENDALE, PA 15095 retail tenant improvement project, designated as Group M (Mercantile).		
	Work to include but not limited to:Demolition of existing non-structural		
	tenant improvements and storefront; New interior partition walls,		
	ceilings, finishes; New storefront, new illuminated channel; New electrical		
	distribution and lighting; Existing HVAC unit with new distribution as		
	required; (1) one new restroom location using existing plumbing fixtures;		
	(1) one new sink in Staff	Room JD SPORTS UN	IT #530 * REV (1) -
	5/17/2024 - FLOOR PLA	N CHANGES, EXITS, EGR	ESS PATHWAYS, WALLS
	AND MULTIPLE OTHER	CHANGES FROM ORIGIN	IAL PLANS

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. complete all framing,nailplates,and electrical cover approval as discussed with contractor. not ready
- 2 1; complete all framing as per city approved plans.
 - 2 ; provide special inspection approval report for welding and anchor bolts as discussed with contractor.
- 3 INSPECTION DATE 5/31/2024
 1.managers office approved for cover
 2.fur out wall at demising wall sales side approved
 3.provide special inspection reports on site for front area on site at time of next inspection



City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

4.complete framing at front area per city approved plans

Sincerely,

King

Shannon King Building Inspector 2 ShannonK@PuyallupWA.gov (253) 840-6684