



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 24, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: B-20-0180

Property Address: 3601 9TH ST SW, PUYALLUP, WA 98373;

Contractor: THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND
58104 Roger Olson 4520 36th ave s fargo, ND 58104 (701) 850-9953

To construct: HOMEWOOD SUITES SOUTH HILL MALL MOTEL *FEE DEFERRAL-SWR*
REVISION (1) 6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD
PERIMETER DRAINTILE

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 2 date of inspection 6/24/2024
 1. gas pipe risers from 1st floor to roof approved at 10 psi as noted on page P-310 of city approved plans
 2. roof drains approved as marked up on page 309 of city approved plans
- FLOOR 5
 1. DWV and supply test (supply at 90 psi) approved at rooms 529,527,525,523,524,526,528,530 as marked up on city approved plans page P-21013
- FLOOR 4
 1. DWV and supply test (supply at 90 psi) approved at rooms 429,427,425,423,424,426,428,430 as marked up on city approved plans page P-208B

Sincerely,

Kevin Spruell
Building Inspector I



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

KSpruell@PuyallupWA.gov

(253) 841-5590