



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 27, 2024

Inspection Result: PARTIAL PASS

Permit Number: B-20-0180

Property Address: 3601 9TH ST SW, PUYALLUP, WA 98373;

Contractor: THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND 58104 Roger Olson 4520 36th ave s fargo, ND 58104 (701) 850-9953

To construct: HOMEWOOD SUITES SOUTH HILL MALL MOTEL *FEE DEFERRAL-SWR*
REVISION (1) 6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD PERIMETER DRAINTILE

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 inspection date 6/11/2024
 1. remove drywall in areas where covered with out energy/vapor barrier inspections
 2. complete fasteners per listing
 3. complete framing at shafts
 4. not a complete list / not ready
 - 2 date of inspection 6/13/2024
 1. complete items 1 and 2 of previous list
 2. provide clarification on off sets
 3. complete log cabin at drywall corners
 4. not a complete list/not ready
- LEVEL ONE
1. areas in corridor where moisture was to high approved for cover
- 4 date of inspection 6/25/2024
 1. drywall first layer in shafts at stacks 218,219,221,224,226,225,229,228, approved as marked up on the city approved on page A-101
 2. insulation and vapor barrier at exterior wall of south mech shaft approved as marked up on city approved plans page A-101



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590