

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Jun 27, 2024	Inspection Result:	NOT READY
Permit Number: Property Address:		UP, WA 98371;	
Contractor:	FORTRESS BUILDERS, IN 897-7374NEELEY CONS ⁻ PUYALLUP, WA 98372-4	TRUCTION COMPANY 1	OKANE, WA 99223 (509) 11 23RD ST SE
To construct:	Small Tenant Improvements at PHS, BLDG -01. At existing third floor existing chemistry classroom 3 new student lab stations will be added, along with a relocated fume hood and refrigerator from building-02. Existing third floor storage room near chemistry classroom will be converted to Science Prep room which includes relocated a fume hood, small refrigerator, hazardous materials storage cabinets, science utility sink, emergency eyewash, fire blanket, fire extinguisher, spill kits, neutralized chemical barrel, and installing a new emergency shower. No exterior work is building done except roof penetrations for fume hood exhaust. The existing building is currently in use, connected to public water and sewer. Work planned to take place over winter break, after contractor has been selected REV (1) - 5.31.2024 - ADDED SCOPE FOR HEALTH DEPT REQUIRED SCIENCE CLASSROOM 325 PURGE FAN, MOTORIZED DAMPER, AND EMERGENCY 100% VENTILATION BUTTON		

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. this was partial inspection for room 325
 - 2. ok to occupy pending electrical final approval
- 2 1.complete items from department of health inspection



City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

2.provide department of health approval at time of next inspection3.provide fire final approval at time of next inspection4.not ready

Sincerely,

Kevin Spruell Building Inspector I KSpruell@PuyallupWA.gov (253) 841-5590