

# Hydraulic Calculations for

**Project:** Homewood Suites  
3500 South Meridian  
Puyallup, WA. 98373

**Drawing no.:** FS-10  
**Date:** 5/6/2024

## Design

**Remote area number:** Area 10  
**Remote area location:** Attic  
**Occupancy classification:** Light Hazard  
**Density:** 0.10 gpm./ft.2  
**Area of application:** Entire Area  
**Coverage per sprinkler:** 100 sq.ft. maximum  
**Type of sprinklers calculated:** Upright  
**No. of sprinklers calculated:** 12  
**In rack demand:** 0 gpm.  
**Hose streams:** 100 gpm. outside + 0 gpm. inside  
**Total water required (including hose streams):** 308.13 gpm at -5.86 psi [ 57.67 psi safety margin ]  
**Type of system:** dry pipe  
**Volume of dry or preaction system:**

## Water Supply Information

**Date:** 01-26-2024  
**Location:** 3601 9th Street Southwest  
**Source:** Fruitland Mutual Water Company


**Contractor:** Discount Fire Protection, LLC.  
4 Red Bluff Court  
Mansfield, TX. 76063

**Name of designer:** Timothy McBride  
**Authority having jurisdiction:**

## Notes

Pdev at node BOR to SOP - 3" AMEs 3000SS Backflow Preventer

### Hydraulic Demand Graph



Water Source:  
A) 52 psi Static  
B) 400 gpm at 51.69 psi

Demand at Source:  
C) 308.1 gpm at -5.86 psi

## Supply Analysis

Node at	Static Pressure [psi]	Residual Pressure [psi]	Flow [gpm]	Available Pressure [psi]	Total Demand [gpm]	Required Pressure [psi]
CTY	52.0	51.0	754.0	51.81	308.13	-5.86

## Node Analysis

Node Tag	Elev [ft]	Type	Pressure [psi]	Discharge [gpm]
CTY	1.000	source	-5.861	-308.127
M01	-4.000	ref	-4.134	100.000
JP4	54.500	ref	35.138	0.000
J11	59.250	ref	16.447	0.000
J12	59.250	ref	12.949	0.000
J13	59.250	ref	11.133	0.000
J14	59.250	ref	9.978	0.000
J15	59.250	ref	9.724	0.000
J16	59.250	ref	9.726	0.000
J17	59.250	ref	10.028	0.000
J18	59.250	ref	11.621	0.000
J19	59.250	ref	14.346	0.000
JP8	59.250	ref	17.469	0.000
J20	59.250	ref	8.107	0.000
J21	59.250	ref	9.214	0.000
J22	59.250	ref	13.459	0.000
JP5	54.500	ref	36.838	0.000
JP6	54.500	ref	39.384	0.000
JP7	13.667	ref	64.381	0.000
TR3	5.000	ref	83.177	0.000
BR3	2.000	ref	88.341	0.000
BR2	2.000	ref	88.773	0.000
BR1	2.000	ref	88.813	0.000
SOP	2.000	ref	-9.431	0.000
BOR	2.000	ref	-6.778	0.000
911	60.250	K=5.60	15.088	21.752
912	60.250	K=5.60	11.779	19.220
913	63.750	K=5.60	8.316	16.149
914	63.750	K=5.60	7.263	15.092
915	63.750	K=5.60	7.032	14.850
916	63.750	K=5.60	7.034	14.852
917	60.250	K=5.60	9.019	16.818
918	60.250	K=5.60	10.524	18.167
919	60.250	K=5.60	13.101	20.269
920	60.250	K=5.60	7.430	15.265
921	60.250	K=5.60	8.251	16.086
922	60.250	K=5.60	12.261	19.609

## Pipe Information

negative pipe flow (Q) indicates flow is from node 2 towards node 1

Node 1	Elev [ft]	K-factor	Discharge & Flow [gpm]	Nom i.d. [in]	Fittings num & length [ft]	L [ft] F [ft] T [ft]	C factor psi/ft	total (Pt) elev (Pe) frict (Pf)	Notes
JP4	54.500		q= 0.000 Q= 86.143	1.25 1.452	1T=5.486	24.333 5.486	C=100	Pt= 35.138 Pe= 2.057	Mat="1-ALXL"
J11	59.250					29.819	0.558	Pf= 16.634	
J11	59.250		q= 0.000 Q= 64.391	1.25 1.452	1E=2.743	8.000 2.743	C=100	Pt= 16.447 Pe= 0.000	Mat="1-ALXL"
J12	59.250					10.743	0.326	Pf= 3.498	
J12	59.250		q= 0.000 Q= 45.171	1.25 1.452	1E=2.743	8.000 2.743	C=100	Pt= 12.949 Pe= 0.000	Mat="1-ALXL"
J13	59.250					10.743	0.169	Pf= 1.815	
J13	59.250		q= 0.000 Q= 29.022	1.25 1.452	1E=2.743	12.750 2.743	C=100	Pt= 11.133 Pe= 0.000	Mat="1-ALXL"
J14	59.250					15.493	0.075	Pf= 1.155	
J14	59.250		q= 0.000 Q= 13.930	1.25 1.452		13.250 0.000	C=100	Pt= 9.978 Pe= 0.000	Mat="1-ALXL"
J15	59.250					13.250	0.019	Pf= 0.254	
J15	59.250		q= 0.000 Q= -0.920	1.25 1.452	1E=2.743	12.750 2.743	C=100	Pt= 9.724 Pe= 0.000	Mat="1-ALXL"
J16	59.250					15.493	0.000	Pf= -0.002	
J16	59.250		q= 0.000 Q= -15.772	1.25 1.452	1E=2.743	9.750 2.743	C=100	Pt= 9.726 Pe= 0.000	Mat="1-ALXL"
J17	59.250					12.493	0.024	Pf= -0.301	
J17	59.250		q= 0.000 Q= -32.590	1.25 1.452	1E=2.743	14.500 2.743	C=100	Pt= 10.028 Pe= 0.000	Mat="1-ALXL"
J18	59.250					17.243	0.092	Pf= -1.593	
J18	59.250		q= 0.000 Q= -50.757	1.25 1.452		13.000 0.000	C=100	Pt= 11.621 Pe= 0.000	Mat="1-ALXL"
J19	59.250					13.000	0.21	Pf= -2.726	
J19	59.250		q= 0.000 Q= -71.026	1.25 1.452		8.000 0.000	C=100	Pt= 14.346 Pe= 0.000	Mat="1-ALXL"
JP8	59.250					8.000	0.39	Pf= -3.123	
JP8	59.250		q= 0.000 Q= -121.985	1.25 1.452	2T=10.971	5.333 10.971	C=100	Pt= 17.469 Pe= -2.057	Mat="1-ALXL"
JP5	54.500					16.305	1.062	Pf= -17.312	
911	60.250	5.6	q= 21.752 Q= -21.752	1 1.104	1T=4.577	1.000 4.577	C=100	Pt= 15.088 Pe= -0.433	Mat="1-ALXL"
J11	59.250					5.577	0.166	Pf= -0.926	
912	60.250	5.6	q= 19.220 Q= -19.220	1 1.104	1T=4.577	1.000 4.577	C=100	Pt= 11.779 Pe= -0.433	Mat="1-ALXL"
J12	59.250					5.577	0.132	Pf= -0.737	
913	63.750	5.6	q= 16.149 Q= -16.149	1 1.104	1T=4.577	4.500 4.577	C=100	Pt= 8.316 Pe= -1.948	Mat="1-ALXL"
J13	59.250					9.077	0.096	Pf= -0.869	
914	63.750	5.6	q= 15.092 Q= -15.092	1 1.104	1T=4.577	4.500 4.577	C=100	Pt= 7.263 Pe= -1.948	Mat="1-ALXL"
J14	59.250					9.077	0.084	Pf= -0.767	

Pipe Information, cont.

Node 1	Elev	K-factor	Discharge & Flow	Nom i.d.	Fittings num & length	L [ft]	C factor	total (Pt)	Notes
Node 2	[ft]		[gpm]	[in]	[ft]	F [ft] T [ft]	psi/ft	elev (Pe) frict (Pf)	
915	63.750	5.6	q= 14.850 Q= -14.850	1 1.104	1T=4.577	4.500 4.577		Pt= 7.032 Pe= -1.948	Mat="1-ALXL"
J15	59.250					9.077	0.082	Pf= -0.744	
916	63.750	5.6	q= 14.852 Q= -14.852	1 1.104	1T=4.577	4.500 4.577		Pt= 7.034 Pe= -1.948	Mat="1-ALXL"
J16	59.250					9.077	0.082	Pf= -0.744	
917	60.250	5.6	q= 16.818 Q= -16.818	1 1.104	1T=4.577	1.000 4.577		Pt= 9.019 Pe= -0.433	Mat="1-ALXL"
J17	59.250					5.577	0.103	Pf= -0.575	
918	60.250	5.6	q= 18.167 Q= -18.167	1 1.104	1T=4.577	1.000 4.577		Pt= 10.524 Pe= -0.433	Mat="1-ALXL"
J18	59.250					5.577	0.119	Pf= -0.664	
919	60.250	5.6	q= 20.269 Q= -20.269	1 1.104	1T=4.577	1.000 4.577		Pt= 13.101 Pe= -0.433	Mat="1-ALXL"
J19	59.250					5.577	0.146	Pf= -0.813	
920	60.250	5.6	q= 15.265 Q= -15.265	1 1.104	1E=1.831	1.000 1.831		Pt= 7.430 Pe= -0.433	Mat="1-ALXL"
J20	59.250					2.831	0.086	Pf= -0.244	
J20	59.250		q= 0.000 Q= -15.265	1 1.104	1E=1.831	11.000 1.831		Pt= 8.107 Pe= 0.000	Mat="1-ALXL"
J21	59.250					12.831	0.086	Pf= -1.106	
J21	59.250		q= 0.000 Q= -31.350	1 1.104		13.000 0.000		Pt= 9.214 Pe= 0.000	Mat="1-ALXL"
J22	59.250					13.000	0.327	Pf= -4.245	
J22	59.250		q= 0.000 Q= -50.959	1 1.104		5.000 0.000		Pt= 13.459 Pe= 0.000	Mat="1-ALXL"
JP8	59.250					5.000	0.802	Pf= -4.011	
921	60.250	5.6	q= 16.086 Q= -16.086	1 1.104	1T=4.577	1.000 4.577		Pt= 8.251 Pe= -0.433	Mat="1-ALXL"
J21	59.250					5.577	0.095	Pf= -0.530	
922	60.250	5.6	q= 19.609 Q= -19.609	1 1.104	1T=4.577	1.000 4.577		Pt= 12.261 Pe= -0.433	Mat="1-ALXL"
J22	59.250					5.577	0.137	Pf= -0.764	
JP4	54.500		q= 0.000 Q= -86.143	2.5 2.635		55.500 0.000		Pt= 35.138 Pe= 0.000	Mat="1-AL10"
JP5	54.500					55.500	0.031	Pf= -1.700	
JP5	54.500		q= 0.000 Q=-208.127	2.5 2.635	2E=11.758	4.500 11.758		Pt= 36.838 Pe= 0.000	Mat="1-AL10"
JP6	54.500					16.258	0.157	Pf= -2.546	
JP6	54.500		q= 0.000 Q=-208.127	2.5 2.635	1E=5.879	40.833 5.879		Pt= 39.384 Pe=-17.681	Mat="1-AL10"
JP7	13.667					46.712	0.157	Pf= -7.316	
JP7	13.667		q= 0.000 Q=-208.127	2.5 2.635	3E=17.636	78.417 17.636		Pt= 64.381 Pe= -3.753	Mat="1-AL10"
TR3	5.000					96.053	0.157	Pf=-15.044	

### Pipe Information, cont.

Node 1	Elev	Discharge & Flow	Nom i.d.	Fittings num & length	L [ft]	C factor	total (Pt) elev (Pe)	Notes
Node 2	[ft]	[gpm]	[in]	[ft]	F [ft] T [ft]	psi/ft	frict (Pf)	
TR3	5.000	q= 0.000 Q=-208.127	2.5 2.635	1T=16.474 1D=5.491	3.000 31.576		Pt= 83.177 Pe= -1.299	Mat="1-WL10"
BR3	2.000			1B=9.610	34.576	0.112	Pf= -3.865	
BR3	2.000	q= 0.000 Q=-208.127	3 3.26	1E=9.408	1.500 9.408		Pt= 88.341 Pe= 0.000	Mat="1-WL10"
BR2	2.000				10.908	0.04	Pf= -0.432	
BR2	2.000	q= 0.000 Q=-208.127	3 3.26		1.000 0.000		Pt= 88.773 Pe= 0.000	Mat="1-WL10"
BR1	2.000				1.000	0.04	Pf= -0.040	
BR1	2.000	q= 0.000 Q=-208.127	3 3.26	2G=2.688 1C=21.503	6.500 33.599		Pt= 88.813 Pe= 0.000	Mat="1-WL10"
SOP	2.000			1E=9.408	40.099	0.04	Pf= -1.590	Pdev=99.83 psi
SOP	2.000	q= 0.000 Q=-208.127	3 3.26	1E=9.408	5.000 9.408		Pt= -9.431 Pe= 0.000	Mat="1-WL10"
BOR	2.000				14.408	0.04	Pf= -0.571	Pdev=-2.08 psi
BOR	2.000	q= 0.000 Q=-208.127	6 6.065	1E=14.000	10.000 14.000		Pt= -6.778 Pe= -2.598	Mat="S40"
M01	-4.000				24.000	0.002	Pf= -0.046	
M01	-4.000	q= 100.000 Q=-308.127	6 6.08	1G=4.588 1E=21.411	96.000 71.880		Pt= -4.134 Pe= 2.165	Mat="1-PVC"
CTY	1.000			1T=45.881	167.880	0.003	Pf= -0.437	

### Material Codes

- |   |   |
|---|---|
| <p><b><u>Pipe Material</u></b></p> <ul style="list-style-type: none"> <li>S40 - Schedule 40 Steel</li> <li>1-PVC - PVC C900 Underround Pipe</li> <li>1-AL10 - Allied Tube schedule 10</li> <li>1-ALXL - Allied Tube XL</li> <li>1-WL10 - Wheatland's schedule 10</li> </ul> | <p><b><u>Fittings</u></b></p> <ul style="list-style-type: none"> <li>B - Butterfly Valve</li> <li>C - Check Valve</li> <li>D - Dry Valve</li> <li>E - Standard 90 degree elbow</li> <li>G - Gate Valve</li> <li>T - Tee - Flow turn 90 degrees</li> </ul> |
|---|---|