



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 28, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: PRCTI20221714

Property Address: 111 W MAIN, PUYALLUP, WA 98371;

Contractor: ALDRICH & ASSOCIATES INC. 810 240TH ST SE BOTHELL, WA 98021
Randy Carlson 6218 Rocky Mountain Drive Southwest Olympia, WA 98512

To construct: Remodel office space on the ground floor of an existing parking structure - COMMUNITY HEALTHCARE * REV (1) - 11/20/2023 - REVISE SIDE SEWER CONNECTION LOCATION * REV (2) - 2.22.2024 - IDENTIFY REVISION TO APPLICABLE BUILDING CODE COMPLIANCE TO 2018 INTERNATIONAL EXISTING BUILDING CODE, WITH RESPECTIVE CODE REFERENCES.

On this day we have inspected your construction for **Mechanical Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1.MECH approved at hard lids room 107 pharmacy waiting
- 2 date of inspection 6/25/2024
 1. complete positive attachment of diffuser's as discussed with contractor
- 3 date of inspection 6/28/2024
 1. R/I mech in corridors and rooms to the north approved

Sincerely,

Kevin Spruell
Building Inspector I



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

KSpruell@PuyallupWA.gov

(253) 841-5590