



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 01, 2024

Inspection Result: NOT READY

Permit Number: PRCTI20240063

Property Address: 3500 S MERIDIAN, Unit: 530, PUYALLUP, WA 98373;

Contractor: MARCO CONTRACTORS INC 100 COMMONWEALTH DR
WARRENDALE, PA 15095

To construct: retail tenant improvement project, designated as Group M (Mercantile).
Work to include but not limited to: Demolition of existing non-structural tenant improvements and storefront; New interior partition walls, ceilings, finishes; New storefront, new illuminated channel; New electrical distribution and lighting; Existing HVAC unit with new distribution as required; (1) one new restroom location using existing plumbing fixtures; (1) one new sink in Staff Room. - JD SPORTS UNIT #530 * REV (1) - 5/17/2024 - FLOOR PLAN CHANGES, EXITS, EGRESS PATHWAYS, WALLS AND MULTIPLE OTHER CHANGES FROM ORIGINAL PLANS

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684