



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 25, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: B-20-0078

Property Address: 1515 S MERIDIAN, PUYALLUP, WA 98371;

Contractor: BALDWIN GENERAL CONTRACTING PO BOX 686, 0876 ALBANY, OR 93721

To construct: HAMPTON INN ADDITION & PARKING BELOW * REV (1) - 10/26/2023 - LOCATION CHANGE FOR OIL/WATER SEPARATOR IN PARKING LOT * REV (2) - 12/27/2023 - UPDATES TO WALL TYPE, PLANS, SECTIONS, ELEVATIONS & SHEAR WALL DETAILS * REV (3) - 3/25/2024 - UPDATES TO CHASE AND SHAFT WALLS

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 date of inspection 6/15/2024
LEVEL 4
1.corridor ceiling 2nd layer approved
2.bathroom ceiling and walls first layer approved
LEVEL 3
1. corridor ceiling 2nd layer approved
2.bathroom ceiling and walls first layer approved except room 361,and 362
LEVEL 2
corridor ceiling 1st layer approved
- 2 L4: Ceiling of CHASE First Layer
L3: Ceiling of Chase First Layer
L2: Ceiling of Chase First Layer
complete all areas as discussed with contractor . (failed)



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Sincerely,

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive style with a large, stylized "S" and "K".

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684