



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 02, 2024

Inspection Result: NOT READY

Permit Number: B-20-0078

Property Address: 1515 S MERIDIAN, PUYALLUP, WA 98371;

Contractor: BALDWIN GENERAL CONTRACTING PO BOX 686, 0876 ALBANY, OR 93721

To construct: HAMPTON INN ADDITION & PARKING BELOW * REV (1) - 10/26/2023 - LOCATION CHANGE FOR OIL/WATER SEPARATOR IN PARKING LOT * REV (2) - 12/27/2023 - UPDATES TO WALL TYPE, PLANS, SECTIONS, ELEVATIONS & SHEAR WALL DETAILS * REV (3) - 3/25/2024 - UPDATES TO CHASE AND SHAFT WALLS

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide as built plumbing plan approval from mechanical engineer for changes to below slab plumbing.
2 ; test failed on below slab plumbing. (no 10' head test at time of inspection)
- 2 1 ; provide as built plumbing plan approval from mechanical engineer for changes to below slab plumbing prior to below slab plumbing approval . (inspection of below slab plumbing only)
- 3 1 ; complete rough-in of water supply as discussed with contractor.
2 ; approved test on d.w.v.
- 4 date of inspection 7/2/2024
1.cancelled on site by contractor

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590