



CITY OF PUYALLUP
Development & Permitting Services
 333 S. Meridian, Puyallup, WA 98371
 (253) 864-4165
www.cityofpuyallup.org

Permit No:
 PRCTI20240784

COMMERCIAL - TENANT IMPROVEMENT/REMODEL

Puyallup, WA

| | | |
|----------------------------|--|--------------------------------|
| Job Address | Address: 1023 39TH AVE SE, PUYALLUP, WA 98374 Parcel # 0419034037 | ISSUED July 03, 2024 |
| Owner | BCC PUYALLUP LLC 9675 SE 36TH ST STE 115 MERCER ISLAND, WA 98188 | |
| Applicant | Leonard Ruff 6210 36th Ave. NE Seattle, WA 98115 (206) 294-1288 leonard.ruff@cascademissioncritical.com | |
| Contractor | HOWARD S WRIGHT 415 1ST AVE N SEATTLE, WA 98109 WA L&I #: | |
| Description of Work | Interior tenant improvement to construct UPS & Battery Rooms totaling 1,753 sf - CENTERIS SCALE MATRIX UPS & BATTERY ROOM TENANT IMPROVEMENT | |
| Permit Types | Commercial - Tenant Improvement/Remodel | |
| Expiration Date: | December 30, 2024 | |
| Total ESU's | | |

Building Components:

| Quantity | Units | Description |
|----------|-----------|------------------------------------|
| 1753 | SQ FT | Business |
| 8 | DIFFUSERS | Mechanical Ducts |
| | | Total Value of Work: \$0.00 |

Standard Conditions:

1. * Final approval by the Building Official is required prior to use or occupancy.* Work shall not proceed until the inspector has approved the stages of construction.* Surface storm water shall be diverted from the building site and shall not drain onto adjacent properties.* I hereby acknowledge that I have read this Permit/Application, that the information given is correct; that I am the owner or the duly authorized agent of the owner; that plans submitted herewith are in compliance with all applicable city, county and state laws and that all construction will proceed in accordance with said laws. This permit shall expire if work is not commenced with 180 days or if the work is suspended for a period of 180 days. Permits expire two years from issuance. * By leaving the contractor information section blank, I hereby certify further that contractors (general or subcontractors) will not be hired to perform any work in association with this permit. I also certify that if I do choose to hire a contractor (general or subcontractor) I will only hire those contractors that are licensed by the State of Washington. If you are a property owner, contractor or permittee and you are paying for someone to perform the work, they must have a valid contractor registration and the person(s) installing plumbing inside a structure must meet the plumbing certification requirements. If you have any questions regarding these regulations, you may contact the Washington State Department of Labor and Industries or you can find more

information on-line at: <http://www.lni.wa.gov/TradesLicensing/Contractors/HireCon/default.asp>

2. • Comply with 2021 IFC and 2021 IBC
 - Total coverage required in the city of puyallup
 - L&I Final required prior to Fire Final
 - Exit lighting test required, contractor to provide light meter
 - Separate permits required for Fire Alarm and Fire Sprinkler
 - RTU'S will be required to be tested for shut down with Fire Alarm
 - Smoke and Fire dampeners will be tested with Fire Alarm. Access doors are required for maintenance and visual inspection.
 - Fire extinguishers required per code to be installed at time of Fire Final
 - In existing buildings all required service and maintenance to be completed prior to inspection for the Fire Alarm, and Fire Sprinkler Systems.
 - All above items to be completed prior to fire final. Fire final required before building final

Schedule your inspection online through the city of puyallup online permit system. This is a request for inspection only. A date and time will be selected by Inspector depending on availability. Email morning of inspection between 7am – 8am for scheduled date and time. Fire Inspections are Monday – Thursday there will be no inspections on Fridays. David Drake ddrake@puyallupwa.gov

3. The subject property has been classified as a contaminated site by the Tacoma Pierce County Health Department (TPCHD) and must be remediated per Washington Administrative Code Title 173. It is the applicant's responsibility to coordinate cleanup with TPCHD. Visit <https://www.tpchd.org/healthy-places/contaminated-property-cleanup> for more information. The applicant shall request a remediation status report from TPCHD by emailing UST@tpchd.org. Provide a copy of the status report to the City.

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
Leonard Ruff