City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Permit Number: B-20-0078

Property Address: 1515 S MERIDIAN, PUYALLUP, WA 98371;

Contractor: BALDWIN GENERAL CONTRACTING PO BOX 686, 0876 ALBANY, OR

93721

To construct: HAMPTON INN ADDITION & PARKING BELOW * REV (1) - 10/26/2023 -

LOCATION CHANGE FOR OIL/WATER SEPARATOR IN PARKING LOT * REV (2) - 12/27/2023 - UPDATES TO WALL TYPE, PLANS, SECTIONS, ELEVATIONS & SHEAR WALL DETAILS * REV (3) - 3/25/2024 - UPDATES

TO CHASE AND SHAFT WALLS

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1; drywall nailing complete at 2nd layer of stairwell walls, ceiling. 2; 1st layer complete at stair stringers, and landings.

Corrections:

- 1 1; drywall nailing of 1st layer at 2nd floor complete except 253, shower wall at valve and chase,260 shower wall at valve and chase,261 shower wall at valve and chase,262 shower wall at valve and chase,360 except shower, 361 & 362 1st layer except bathroom shower wall.
 - 2; drywall nailing of 2nd layer at rooms 358, except furred wall and chase, 357 except furred wall and chase, 355 except furred wall and chase, 354 except furred wall and chase, 353 except furred wall and chase.
 - 3; drywall nailing of 2nd layer at 4th floor complete except 460 shower valve wall and chase,461 shower valve wall and chase,

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684