



# Columbia Fire

SPRINKLER SYSTEM SERVICE & REPAIR

Project Name: Central Pierce  
Project Address: 1019 39<sup>th</sup> Ave SE  
Puyallup, WA 98374

Columbia fire scope of work is to add and relocate existing heads for the new walls and ceiling to comply with NFPA #13- 2016, and the city of Puyallup standards.

The modification of the fire sprinkler system for Central Pierce will not affect the original hydraulic design of the building and does not require hydraulic calculations.

111 South Findlay Street Seattle, WA 98108		<b>071105</b>	
TEL	206.232.8569	FAX	206.340.6100
<a href="http://www.ColumbiaFire.net">www.ColumbiaFire.net</a>			
COLUMFL795NJ LOCAL 699 Contractor			



(Signature)

**Najeeb Habib**

(Print Name)

**Designer**

(Title)

