



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 26, 2024

Inspection Result: NOT READY

Permit Number: PRCTI20240250

Property Address: 1019 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: SMAJIC CONSTRUCTION LLC 7405 118TH AVE SE NEWCASTLE, WA 98056 (425) 378-2593

To construct: Interior renovation of approximately 9,193 SF space for receiving and storage of fire department personnel equipment/ clothing. - CENTRAL PIERCE FIRE & RESCUE WAREHOUSE

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide detail from architect for top and bottom track attachment.
 - 2 ; provide detail on min. gap at deflection track.
 - 3 provide energy code path for heated space in storage rooms as discussed with contractor.
 - 4 ; complete all framing as per city approved plans
- not ready

Sincerely,

Shannon King



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684