



City of Puyallup  
**Engineering Division**  
333 S. Meridian, Puyallup, WA 98371  
(253) 864-4165  
www.cityofpuyallup.org

July 11, 2024

Contour Engineering LLC  
PO Box 949  
GIG HARBOR, WA 98335  
patrick.hopper@contourengineeringllc.com

**RE: Alternative Methods /Materials Request (AMR) for Permit PRAMR20240897  
Bradbury Place Townhomes**

Dear Contour Engineering LLC,

The City reviewed the Alternative Methods/Materials Request described by the permit applicant as, "The request proposes to exceed the max burial height/depth of 20 feet for a sanitary sewer manhole. As part of the sanitary sewer main extension, SS manholes are being installed/replaced south of the project site, within the 27th Ave SE ROW. two (2) manholes #110 & 120 need to be 25 feet deep, so the correct pipe slope is achieved for sewage flow." The request is **Approved** with the following conditions:

Conditions
1. Conditions of Approval: 1) Manholes shall be sized to allow for entry and repair; 2) Use ductile iron pipe or provide supporting calculations for pipe strength and deflection due to soil type at depth and imparted dead and live loads.

The signed AMR application is available to view and download in the CityView portal. If you have any questions regarding this decision, or would like to further discuss your request, please contact me directly.

Sincerely,

Mark Higginson  
Sr Civil Engineer  
253.841.5559  
MHigginson@PuyallupWA.gov