



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 11, 2024

Inspection Result: PARTIAL PASS

Permit Number: B-20-0180

Property Address: 3601 9TH ST SW, PUYALLUP, WA 98373;

Contractor: THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND
58104 Roger Olson 4520 36th ave s fargo, ND 58104 (701) 850-9953

To construct: HOMEWOOD SUITES SOUTH HILL MALL MOTEL *FEE DEFERRAL-SWR*
REVISION (1) 6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD
PERIMETER DRAINTILE

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 NORTH STAIRWELL
 1. level 4 southwall hotel side 2nd layer approved
 2. level 5 south and west wall provide min lap per UL listing hotel side at 2nd layer
 3. level 4 west wall hotel side provide min lap per UL listing 2nd layer
- SOUTH STAIRWELL
 1. level 5 east wall hotel side 2nd layer approved
- 2 date of inspection 6/17/2024
 1. discussed shaft designs
- 3
 1. this was mech R/I inspection
 2. 4th floor corridor mech partial approval as marked up on city approved plans pages M-204A and M-204B
 - 3.date of inspection 7/10/2024

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Kevin Spruell

Building Inspector I

KSpruell@PuyallupWA.gov

(253) 841-5590