

City of Puyallup **Engineering Division** 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Jul 12, 2024	Inspection Result:	FAILED	
Permit Number: Property Address:		PUYALLUP, WA 98374;		
Contractor:	LINCOLN CONSTRUCTION INC 11803 101st Ave Ct E, Suite 201 Puyallup, WA 98373 (253) 847-6414			
To construct:	5 1	PARKING LOT A; PARKING IMPROVEMENTS: ASPHALT		
	PAVING;CONCRETI	E PAVING & STORMWATER	~ PIERCE COLLEGE	
	PARKING EXPANSI	ON		

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: See first correction! Spalls, hog fuel, and track out on roadway that needs to be cleaned up! No one on site @ 2pm.

Corrections:


- 1 Clean construction debris off roadway!
 - Maintain dust control!
 - Finish silt fence where needed. If fill is going to be higher than surrounding areas, silt fence needs to be installed.
 - Finish tree protection where and if needed.

Sincerely,

City of Puyallup



Engineering Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org



Jason Little Development Engineering Inspector JLittle@PuyallupWA.gov (253) 435-3636