

Date: 7/18/2024

Permit Application #PRMH20241062

Project Number: Tractor Supply 1886 Puyallup WA
Type of Project (Description): Replacement of RTUs
Project Address: 621 RIVER ROAD, PUYALLUP, WA 9837
Engineer: Proscap Engineering & Energy Group

Review Status: PC1

RESPONSES:

PLAN CHECK NO. 1:

- The note in the Project Aerial View doesn't match the project scope of work. Three RTUs and one CU are to be replaced. See marked-up document(s) for review comment: [1062 PLANS, sheet T001]

Please see the revised plan.

- Please correct this note to the 2021 International Building Code. See marked-up document(s) for review comment:[1062 PLANS, sheet S1, Structural Design Criteria note A.]

Please see the revised plans and calculation report.

- The minimum design ground snow load within the City of Puyallup is 20psf. Please see the Puyallup Municipal Code 17.04.050, table R301.2(1). See marked-up document(s) for review comment: [1062 PLANS, Structural Design Criteria note C3] and [STRUCTURAL CALCS]

Please see the revised plans and calculation report.

- The engineer of record's signature must be placed directly over the seal. See the WAC 196-23-070, item 1D. See marked-up document(s) for review comment: [1062 PLANS, structural sheets] and [STRUCTURAL CALCS]

Please see the revised plans and calculation report.