



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jul 18, 2024

**Inspection Result:** PARTIAL PASS

**Permit Number:** B-20-0180

**Property Address:** 3601 9TH ST SW, PUYALLUP, WA 98373;

**Contractor:** THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND 58104 Roger Olson 4520 36th ave s fargo, ND 58104 (701) 850-9953

**To construct:** HOMEWOOD SUITES SOUTH HILL MALL MOTEL \*FEE DEFERRAL-SWR\*  
REVISION (1) 6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD PERIMETER DRAINTILE

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Mechanical duct seal complete at East West Corridor. Levels 1 - 5 as noted on sheet M-203A of City approved plans.

**Corrections:**

- 1 NORTH STAIRWELL
  1. level 4 southwall hotel side 2nd layer approved
  2. level 5 south and west wall provide min lap per UL listing hotel side at 2nd layer
  3. level 4 west wall hotel side provide min lap per UL listing 2nd layer
- SOUTH STAIRWELL
  1. level 5 east wall hotel side 2nd layer approved
- 2 date of inspection 6/17/2024
  1. discussed shaft designs
- 3
  1. this was mech R/I inspection
  2. 4th floor corridor mech partial approval as marked up on city approved plans pages M-204A and M-204B
  3. date of inspection 7/10/2024

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive style with a large initial "S" and "K".

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684