



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 18, 2024

Inspection Result: PARTIAL PASS

Permit Number: B-20-0180

Property Address: 3601 9TH ST SW, PUYALLUP, WA 98373;

Contractor: THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND 58104 Roger Olson 4520 36th ave s fargo, ND 58104 (701) 850-9953

To construct: HOMEWOOD SUITES SOUTH HILL MALL MOTEL *FEE DEFERRAL-SWR*
REVISION (1) 6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD PERIMETER DRAINTILE

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Corridor attachment of shaft liner for Mechanical ducting East West Corridor. Levels 1 - 5 as noted on sheet A101 of City approved plans

Corrections:

- 1 inspection date 6/11/2024
 1. remove drywall in areas where covered with out energy/vapor barrier inspections
 2. complete fasteners per listing
 3. complete framing at shafts
 4. not a complete list / not ready
- 2 date of inspection 6/13/2024
 1. complete items 1 and 2 of previous list
 2. provide clarification on off sets
 3. complete log cabin at drywall corners
 4. not a complete list/not ready

LEVEL ONE

 1. areas in corridor where moisture was to high approved for cover
- 3 date of inspection 6/25/2024
 1. drywall first layer in shafts at stacks 218,219,221,224,226,225,229,228, approved as marked up on the city approved on page A-101
 2. insulation and vapor barrier at exterior wall of south mech shaft approved as marked up on



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

city approved plans page A-101

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684