



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 23, 2024

Inspection Result: PARTIAL PASS

Permit Number: PRCNC20221036

Property Address: 1601 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: ABSHER CONSTRUCTION CO. PO BOX 280 PUYALLUP, WA 98371-0152

To construct: New ~54,000 SF building containing labs, classrooms, faculty and student spaces. REVISION (1) -003/21/2023 - ADDED DETAILS & DESIGN REFINEMENT FROM PERMIT SET TO IFC SET OF DOCUMENTS (NO CHANGE IN SQ FTG OR COST)

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: reinspect of ceilings in rooms - 232A,233A,233,232,231, complete.

Corrections:

- 1 1. this was a comment inspection
2. discussed ceiling requirements
- 2 inspection date 5/21/2024
1. cancelled on site by contractor
- 3 date of inspection 6/20/2024
level one ceilings with clouds and standard grid attached on 4 sides
1. provide tie wires all perimeter bars
2. provide positive attachment at all diffusers
3. complete all firestopping at rated walls
4. complete all wires at light fixtures
5. provide clarification on air returns in corridor
6. provide stenciling at rated walls
7. ok to cover in areas as discussed with contractor
- 4 1 ; approved cover in room 236 only.
2 ; provide positive attachment of diffusers to main and cross tee of ceiling.
3 ; complete sprinkler attachment to ceiling.
4 ; complete pipe insulation.



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

5 ; complete monokote fireproofing at areas discussed with Brandon.

2nd floor rooms not ready at time of inspection.

5 level 2 ceiling inspection non rated classrooms only -

208,207,206,205,204,203,202,201,236,235,234,232,231 - complete corrections as noted on sheets provided to Scott. (A121&A122)

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684