


FIRE PROTECTION DIVISION

7/18/24

Archer Construction, Inc.
7855 South 206th Street
Kent, Wa 98032




Attention: Puyallup Fire Prevention

Reference: Remembrance Gallery TI – 110 9th Ave SW

The above referenced fire sprinkler tenant improvement involves adding/relocating sprinklers for new ceilings and walls. Previously this space was used for vender sales (Merchantile / Ordinary Hazard Group 2). The new space is largely Gallery / Museum (Light Hazard), with one storage room and one audio/video closet. The new design criteria is less than or equal to that of the previous use. For these reasons the proposed sprinkler modifications will not affect the hydraulic calculations.

Sincerely,
Theodore Queen

	WASHINGTON STATE CERTIFICATE OF COMPETENCY FIRE SPRINKLER SYSTEMS
Theodore M. Queen 4930-0205-C Level 3 Archer Construction, Inc. ARCHEI*219DR	
	7.18.24
Signature	Date