

City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 25, 2024 Inspection Result: PARTIAL PASS

Permit Number: PRCTI20221788

Property Address: 401 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: HOWARD S WRIGHT 415 1ST AVE N SEATTLE, WA 98109

To construct: Conversion of existing OR#1 Suite and Auxiliary spaces into a Hybrid OR

Suite, reconfiguration of existing control room, storage, and sub-sterile room to accommodate new Hybrid OR Suite. REVISION (1) - 03/22/2024 REVISE STRUCTURAL DRAWINGS AND CALCS AND MINOR REVISIONS AT CONTROL ROOM 2D02, OR 2D03, ELECTRONICS ROOM 2D09A.

On this day we have inspected your construction for **Medical Gas Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1; the 24 hour test pressure is 160 psi on the 200 psi Gauge and 150psi on the 300 psi Gauges as marked on Gauges.

Corrections:

Sincerely,

Shannon King Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org