



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 30, 2024

Inspection Result: NOT READY

Permit Number: PRRRSF20231418

Property Address: 907 18TH ST NW, PUYALLUP, WA 98371;

Contractor: GDK SERVICES LLC 7911 BRIGHT COURT SW OLYMPIA, WA 98512

To construct: Remove roof trusses off entire garage. Remove walls and slab from back of original garage that was added but not built to code. Repour new engineered slab and built walls on new section. Add engineered storage trusses over entire garage. * REV (1) 7/30/2024 - FIREWALL DETAILS & ENGINEER FOOTING

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

Sincerely,

Kevin Spruell
Building Inspector
KSpruell@PuyallupWA.gov
(253) 841-5590