



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jul 31, 2024

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCCP20230970

**Property Address:**

**Contractor:** MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

**To construct:** Civil Construction Permit for the East Town Crossing project associated with Preliminary Site Plan/SEPA, P-21-0034.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Note: Storm test is preliminary only to keep the paving schedule. The city will not accept the storm until "ALL" heavy construction and digging has been completed.

McKee air tested storm @ 3.5 to 4 psi for 15min. each:

- CB27 to WQ5 12"CPEP (PASSED)
- CB27 to CB28 8"DI (PASSED)
- CB26 to WQ5 12"CPEP (PASSED)
- CB26 to CB18 24"CPEP (PASSED)
- WQ4 to CB18 12"CPEP (PASSED)
- WQ4 to CB19 12"CPEP (PASSED)
- CB20 to CB19 12"CPEP (PASSED)
- CB20 to CB21 8"DI (PASSED)

Another crew is bedding and backfilling r-tank 3.

**Corrections:**

Sincerely,



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by a series of vertical, wavy lines that resemble the letters 'LITTLE'. A horizontal line extends from the right side of the signature.

Jason Little

Development Engineering Inspector

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 435-3636