



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 01, 2024 **Inspection Result:** **PASSED**

Permit Number: PRCTI20231574

Property Address: 105 7TH ST SW, PUYALLUP, WA 98371;

Contractor: TBD <NO STREET ADDRESS> WA NEELEY CONSTRUCTION COMPANY
111 23RD ST SE PUYALLUP, WA 98372-4163

To construct: Small Tenant Improvements at PHS, BLDG -01. At existing third floor existing chemistry classroom 3 new student lab stations will be added, along with a relocated fume hood and refrigerator from building-02. Existing third floor storage room near chemistry classroom will be converted to Science Prep room which includes relocated a fume hood, small refrigerator, hazardous materials storage cabinets, science utility sink, emergency eyewash, fire blanket, fire extinguisher, spill kits, neutralized chemical barrel, and installing a new emergency shower. No exterior work is building done except roof penetrations for fume hood exhaust. The existing building is currently in use, connected to public water and sewer. Work planned to take place over winter break, after contractor has been selected. - REV (1) - 5.31.2024 - ADDED SCOPE FOR HEALTH DEPT REQUIRED SCIENCE CLASSROOM 325 PURGE FAN, MOTORIZED DAMPER, AND EMERGENCY 100% VENTILATION BUTTON

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. this was partial inspection for room 325
- 2 1 ; complete Department of Health requirements for changes to hood duct and final prior to mechanical final inspection.
not ready



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Sincerely,

A handwritten signature in black ink that reads "Monty Johnson". The signature is written in a cursive, flowing style.

Monty Johnson

Sr Building Inspector

Monty@PuyallupWA.gov

(253) 770-3326