



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Aug 01, 2024

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCCP20230970

**Property Address:**

**Contractor:** MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

**To construct:** Civil Construction Permit for the East Town Crossing project associated with Preliminary Site Plan/SEPA, P-21-0034.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** McKee TV'ed the sewer mains that were repaired for belly's. They cleaned (jetted and vaced) a few that were dirty as well.

This morning at 9am a water sample was taken from the pipe run crossing Shaw Rd. it was brought to Water Management Labs.

Pulled mandrel through 8"pvc sewer main:

- SSMH4 to SSMH6 (PASSED) - SSMH6 to SSMH9 (PASSED) - SSMH9 to SSMH8 (PASSED)
- SSMH2 to SSMH3 (PASSED) - SSMH3 to Existing SSMH14 (PASSED)
- SSMH3 to SSMH13 (PASSED)

Air tested sewer main w/ SS's: Mains 8"pvc & SS's 6"pvc

- SSMH6 to SSMH9 (PASSED) - SSMH6 to SSMH4 w/ 3 SS's (PASSED)
- SSMH 9 to SSMH2 w/ 1 SS (PASSED) - SSMH9 to SSMH8 (PASSED)

This afternoon at 2pm the second (24hr) water sample was taken from the onsite wet tap #1 and delivered to Water Management Labs.

**Corrections:**

Sincerely,



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Jason Little

Development Engineering Inspector

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 435-3636