



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 06, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCCP20231400

Property Address: 1601 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: LINCOLN CONSTRUCTION INC 11803 101st Ave Ct E, Suite 201
Puyallup, WA 98373 (253) 847-6414

To construct: PARKING LOT A; PARKING IMPROVEMENTS: ASPHALT
PAVING; CONCRETE PAVING & STORMWATER ~ PIERCE COLLEGE
PARKING EXPANSION

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Freeman Bell is hydro-testing the fire hydrant. 200psi for 2hrs. Hydrant (PASSED) Hydro-test.

They are importing fill for the parking lot.

Corrections:

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by a series of vertical, wavy lines that resemble the letters 'LITTLE'. A horizontal line extends from the right side of the signature.

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 435-3636