



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Aug 07, 2024

**Inspection Result:** NOT READY

**Permit Number:** PRCTI20240469

**Property Address:** 1601 INDUSTRIAL PARK WAY, PUYALLUP, WA 98371;

**Contractor:** CORTI CONSTRUCTION, INC. 4024 148TH AVE NE BOTHELL, WA 98052

**To construct:** NON-STRUCTURAL INTERIOR TENANT IMPROVEMENT: WORK  
INCLUDES ADDING ROOF INSULATION TO EXISTING ROOF  
THROUGHOUT THE SUITE. - PROLOGIS Project is a resubmittal review.

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 7/31/2024
  1. provide engineering for pods on site at time of next inspection (will submit from architect)
  2. complete pods in areas that exceed 1,000 sq ft (contractor will create soffit/separation at kitchenette)
  3. provide seismic separation joint in areas that exceed 2,500 sq ft (Completed)
  4. not a complete list

Sincerely,

Kevin Spruell  
Building Inspector  
[KSpruell@PuyallupWA.gov](mailto:KSpruell@PuyallupWA.gov)  
(253) 841-5590