



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Aug 07, 2024                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** PRCCP20231400

**Property Address:** 1601 39TH AVE SE, PUYALLUP, WA 98374;

**Contractor:** LINCOLN CONSTRUCTION INC 11803 101st Ave Ct E, Suite 201  
Puyallup, WA 98373 (253) 847-6414

**To construct:** PARKING LOT A; PARKING IMPROVEMENTS: ASPHALT  
PAVING; CONCRETE PAVING & STORMWATER ~ PIERCE COLLEGE  
PARKING EXPANSION

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Flushed new hydrant from both 2.5" ports for 15min.  
Bags captured existing rusty scales.  
Hydrant was turned towards the roadway and has a Stortz adaptor. (It is Live)  
Crew is importing fill for parking lot.

**Corrections:**

Sincerely,



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by a series of vertical, wavy lines that resemble the letters 'LITTLE'. A horizontal line extends to the right from the end of the signature.

Jason Little

Development Engineering Inspector

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 435-3636