



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 08, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCTI20240469

Property Address: 1601 INDUSTRIAL PARK WAY, PUYALLUP, WA 98371;

Contractor: CORTI CONSTRUCTION, INC. 4024 148TH AVE NE BOTHELL, WA 98052

To construct: NON-STRUCTURAL INTERIOR TENANT IMPROVEMENT: WORK
INCLUDES ADDING ROOF INSULATION TO EXISTING ROOF
THROUGHOUT THE SUITE. - PROLOGIS Project is a resubmittal review.

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 7/31/2024
 1. provide engineering for pods on site at time of next inspection (will submit from architect)
 2. complete pods in areas that exceed 1,000 sq ft (contractor will create soffit/separation at kitchenette)
 3. provide seismic separation joint in areas that exceed 2,500 sq ft (Completed)
 4. not a complete list
- 2 date of inspection 8/8/2024
 1. kitchen area approved for cover
 2. main area complete pods per city approved plans (fasteners and spacing as discussed with contractor)
 3. this is a complete list

Sincerely,

Kevin Spruell
Building Inspector



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

KSpruell@PuyallupWA.gov

(253) 841-5590