



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Aug 09, 2024                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** PRCTI20231772

**Property Address:** 401 15TH AVE SE, PUYALLUP, WA 98372;

**Contractor:** SELLEN 227 WESTLAKE AVE N SEATTLE, WA 98109 (206) 682-7770

**To construct:** Remodel of portion of emergency department to create spaces for treating lower acuity patients in open bays by removing some walls and installing wall mounted hand-wash sinks. Additionally will convert open room to become two separate rooms for holding patients requiring seclusion with enclosed workroom for staff to observe seclusion rooms. HVAC will be modified to serve the new spaces. Some electrical updates will also occur. - GOOD SAM HOSPITAL - ED

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 complete drywall at 1 hour wall from soffit to top of wall and storage room.
- 2 phase 2
  1. top out in area 180.7 rooms B and C approved
- 3 date of inspection 8/7/2024
  - 2nd phase
    1. rooms M180.7B and M180.7C framing and fire stopping above hard lids approved for cover walls in this area also approved for cover
- 4 date of inspection 8/8/2024
  - 1.drywall approved in rooms M180.7B and M180.7C and surrounding area
  - 2.phase 2



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Sincerely,

Kevin Spruell  
Building Inspector  
[KSpruell@PuyallupWA.gov](mailto:KSpruell@PuyallupWA.gov)  
(253) 841-5590