



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Aug 09, 2024

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRCCP20230970

**Property Address:**

**Contractor:** MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

**To construct:** Civil Construction Permit for the East Town Crossing project associated with Preliminary Site Plan/SEPA, P-21-0034.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** McKee connected the live hydrant to a b/o near by for line pressure.

- All service valves were turned on and air burped. 5 - 2" services were checked for leaks with line pressure. (PASSED) 1 - 1" service was checked for leaks with line pressure. (PASSED)

The crew is bedding the services with sand, installing valve cans, and backfilling.

- Hydro test for the stub crossing Shaw (PASSED) 200psi for 1hr w/ zero drop.

Another crew is installing 12" DI between CB9 & CB5. They installed CB5 and began installing 12"DI between CB5 & CB2.

Another crew is setting structures to grade and grouting.

Note: Pipe supplier is on site installing the correct pumper ports on the hydrants.

**Corrections:**

Sincerely,



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Jason Little

Development Engineering Inspector

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 435-3636