



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Aug 12, 2024                      **Inspection Result:**     **NOT READY**

**Permit Number:** B-20-0180

**Property Address:** 3601 9TH ST SW, PUYALLUP, WA 98373;

**Contractor:** THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND  
58104 Roger Olson 4520 36th ave s fargo, ND 58104 (701) 850-9953

**To construct:** HOMEWOOD SUITES SOUTH HILL MALL MOTEL \*FEE DEFERRAL-SWR\*  
REVISION (1) 6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD  
PERIMETER DRAINTILE

On this day we have inspected your construction for **Mechanical Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** cancel per contractor

**Corrections:**

- 1    1. this was a comment inspection  
     2. discussed mech requirements
- 2    date of inspection 7/2/2024  
     1. 5th floor corridors mech partial approval as marked up on city approved plans pages M-205A and M-205B  
     2. provide as-built approval from engineer for pipe size changes
- 3    1.date of inspection 7/15/2024  
     2.this was a comment inspection  
     3. discussed attachment of shaft liner at corridor walls at mech shafts

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive, flowing style.

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684