



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 13, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCTI20221788

Property Address: 401 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: HOWARD S WRIGHT 415 1ST AVE N SEATTLE, WA 98109

To construct: Conversion of existing OR#1 Suite and Auxiliary spaces into a Hybrid OR Suite, reconfiguration of existing control room, storage, and sub-sterile room to accommodate new Hybrid OR Suite. REVISION (1) - 03/22/2024 REVERSE STRUCTURAL DRAWINGS AND CALCS AND MINOR REVISIONS AT CONTROL ROOM 2D02, OR 2D03, ELECTRONICS ROOM 2D09A.

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. head of wall small area above control room approved
- 2 date of inspection 8/13/2024
 - 1.complete fire stopping
 - 2.complete vapor barrier at west exterior wall as discussed with contractor
 - 3.provide clarification on head of wall detail at west soffit
 - 4.complete ceiling framing per manufactures install instructions
 5. wall between control room and O/R approved for cover

Sincerely,

Kevin Spruell
Building Inspector



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

KSpruell@PuyallupWA.gov

(253) 841-5590