



CITY OF PUYALLUP
Development & Permitting Services
 333 S. Meridian, Puyallup, WA 98371
 (253) 864-4165
www.cityofpuyallup.org

Permit No:
 PRFN20241193

FENCE
 Puyallup, WA

Job Address	Address: Parcel # 0420331121	ISSUED August 15, 2024
Owner WESTERN WASHINGTON FAIR ASSOCIATION 110 9TH AVE SW PUYALLUP, WA 98371-6811		
Applicant JMJ TEAM 905 MAIN STREET , SUITE 200 SUMNER, WA 98390 (206) 596-2020 permitting@jmjteam.com		
Contractor ABSHER CONSTRUCTION PO BOX 280 PUYALLUP, WA 98371-0152 pcstempermitinspection@gmail.com WA L&I #:		
Description of Work The existing fence at the Washington State Fairgrounds Gold Gate will be replaced with a new steel fence. - WSF GOLD GATE		
Permit Types	Fence	
Expiration Date: February 11, 2025		
Total ESU's		

Building Components:

Quantity	Units	Description	Total Value of Work:
110	LN FT	Fence (wood or chainlink)	\$0.00

Standard Conditions:

1. * Final approval by the Building Official is required prior to use or occupancy.* Work shall not proceed until the inspector has approved the stages of construction.* Surface storm water shall be diverted from the building site and shall not drain onto adjacent properties.* I hereby acknowledge that I have read this Permit/Application, that the information given is correct; that I am the owner or the duly authorized agent of the owner; that plans submitted herewith are in compliance with all applicable city, county and state laws and that all construction will proceed in accordance with said laws. This permit shall expire if work is not commenced with 180 days or if the work is suspended for a period of 180 days. Permits expire two years from issuance. * By leaving the contractor information section blank, I hereby certify further that contractors (general or subcontractors) will not be hired to perform any work in association with this permit. I also certify that if I do choose to hire a contractor (general or subcontractor) I will only hire those contractors that are licensed by the State of Washington. If you are a property owner, contractor or permittee and you are paying for someone to perform the work, they must have a valid contractor registration and the person(s) installing plumbing inside a structure must meet the plumbing certification requirements. If you have any questions regarding these regulations, you may contact the Washington State Department of Labor and Industries or you can find more information on-line at: <http://www.lni.wa.gov/TradesLicensing/Contractors/HireCon/default.asp>

2. 1. INSTALL ADDRESS NUMBERS PER THE FOLLOWING DISTANCES: 0-50 FOOT SETBACK FROM STREET NUMBERS SHALL BE 6 INCHES IN HEIGHT; 51-100 FEET 12 INCHES IN HEIGHT. ALL NUMBERS SHALL CONTRAST WITH THEIR BACKGROUND. ADDITIONAL NUMBERS MAY BE NEEDED AT DRIVEWAY ENTRANCE IF BUILDING NUMBERS ARE NOT VISIBLE FROM THE STREET. REAR DOORS OF SUITES OR UNITS SHALL ALSO BE LABELED WITH MINIMUM 4 INCH NUMBERS.
2. FIRE HYDRANTS REQUIRED FOR CONSTRUCTION AND FIRE DEPARTMENT ACCESS SHALL BE INSTALLED AND APPROVED BY THE FIRE CODE OFFICIAL PRIOR TO THE STORAGE OR INSTALLATION OF ANY COMBUSTIBLE FRAMING MATERIAL. ACCESS ROADWAY SURFACES SHALL BE DESIGNED TO CITY STANDARDS AND BE DESIGNED TO MAINTAIN THE IMPOSED LOADS OF A 80,000 POUND FIRE APPARATUS. ASPHALT TREATED BASE, ASPHALT OR CONCRETE PAVEMENT CAN BE USED TO PROVIDE THE REQUIRED ALL-WEATHER DRIVING SURFACE.
3. ANY REQUIRED FIRE LANE MARKINGS SHALL BE INSTALLED PRIOR TO FINAL INSPECTION AND PER CITY ORDINANCE.
4. KNOX BOXES, WHEN REQUIRED, SHALL BE INSTALLED USUALLY TO THE RIGHT OF THE MAIN FRONT DOOR AND NO HIGHER THAN 6 FEET OFF OF THE GROUND. ONLY HINGED KNOX BOXES SHALL BE USED. KNOX BOXES AND KEY SWITCHES CAN BE ORDERED ONLINE AT THE "KNOX COMPANY"
5. FIRE EXTINGUISHERS WILL BE REQUIRED PER CHAPTER 9 OF THE INTERNATIONAL FIRE CODE. GENERALLY, 1 FIRE EXTINGUISHER WITH A MINIMUM RATING OF 2A 10BC SHALL BE INSTALLED PER EVERY 3,000 SQUARE FEET OF FLOOR AREA. THE LOCATION OF THE FIRE EXTINGUISHERS SHALL BE NEAR THE EXIT DOORS AND TRAVEL DISTANCE TO AN EXTINGUISHER SHALL NOT EXCEED 75 FEET. ADDITIONAL SIGNAGE MAY BE NECESSARY TO INDICATE THE FIRE EXTINGUISHER LOCATION.
6. FIRE ACCESS SUBJECT TO FIELD VERIFICATION TESTING WITH VEHICLES.

3. Development Engineering standard commercial conditions:

- Prior to starting site work request an inspection for erosion and sediment.
- Sediment control and erosion procedures shall be practiced eliminating and preventing off site damage. Stormwater runoff originating upgrade of exposed areas shall be controlled to reduce erosion and sediment loss during the period of exposure. See civil construction permit PRCCP20231620 for specifications.
- The builder/owner shall be responsible for keeping the existing right-of-way free of debris and dirt. Any violation of PMC chapter 21.14 pertaining to clearing, filling, and grading, erosion and sediment control, and storm water discharges shall be prosecuted to the fullest extent of the law.
- Any addition/expansion to the footprint of the building including decks and porches not originally shown on the approved set of plans must obtain proper permits prior to construction.
- The applicant is responsible to call the utility notification center at 1-800-424-5555 before beginning any excavation. Call before you dig, it's the law.
- No work shall be done in or on the public right of way without a licensed and bonded contractor first obtaining a right of way permit.

4. PERMIT CONDITIONS:

- The contractor shall locate the existing storm, water, and sanitary sewer facilities within proximity to the proposed fence posts prior to construction. Refer to the approved PRCCP20231620 civil plans. The contractor shall take the necessary precautions, at their own expense, to protect the existing utilities during the installation of the proposed fence posts. No proposed footings, posts, or supports shall be constructed on or above any existing public utility connections without first relocating the utility services or protecting it in place. [Yianni Charitou @ 08/15/2024 10:03 AM]

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
JMJ TEAM

