



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 15, 2024

Inspection Result: **PASSED**

Permit Number: PRDE20240877

Property Address: 4102 S MERIDIAN, Unit: D, PUYALLUP, WA 98373;

Contractor:

To construct: Demolition and removal of existing entry feature element and interior spaces (offices/restrooms facilities) associated with previous tenancy, and related site work as required for patch and repair of non-conforming adjacent areas. ~ SOUTH HILL CTR- SPACE #10 DEMO

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Contractor used drain pro plumbing to clean the storm line.

Storm is as clean as its going to get. The bio swale has never been maintained and is backing up the pipe.

Corrections:

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 435-3636