



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Aug 16, 2024

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCCP20230970

**Property Address:**

**Contractor:** MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

**To construct:** Civil Construction Permit for the East Town Crossing project associated with Preliminary Site Plan/SEPA, P-21-0034.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Sewer main was TV'ed today.

- SSMH2 to SSMH1 (PASSED)
- SSMH2 to SSMH3 (PASSED)

McKee is installing storm. They finished the 12" cpep between CB15 and CB14 and installed CB14. They began installation of 12" cpep between CB14 and CB16.

Note: \*Another field change! The engineer and contractor mis-calced the elevations for bottom of storm (w/ ribs) and top of fire line. There is only .15' of clearance between the two. Foam was installed. Another crew is sub-grading the roads for paving.

**Corrections:**

Sincerely,



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

---

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by several vertical, wavy lines that resemble the letters 'LITTLE'. A horizontal line extends from the right side of the signature.

Jason Little

Development Engineering Inspector

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 435-3636