

Seattle 1011 Western Avenue, Suite 810 | Seattle, WA 98104 | 206.292.5076  
Tacoma 1250 Pacific Avenue, Suite 701 | Tacoma, WA 98402 | 253.383.2797  
Portland 101 SW Main Street, Suite 280 | Portland, OR 97204 | 503.232.3746  
[www.pcs-structural.com](http://www.pcs-structural.com)



May 15, 2024

PRCTI20241089

NW Ceiling Lifts  
18389 S Norman Rd  
Oregon City, OR 97045

ATTN: Sam Krause

RE: *MHS Good Samaritan – Rehab Retrofit Ceiling Lifts  
Puyallup, WA*



Dear Sam:

At your request, we have reviewed the ceiling lift support details you sent on May 13, 2024. It is our understanding that the ceiling lifts at the rehab gym, room #36, and room #38 are rated for 1,000# capacity, and the ceiling lift at room #41 is rated for 700# capacity. Our review was limited to the threaded rod hangers, Unistrut bracing of the threaded rod hangers, connections of the threaded rod hangers and Unistrut bracing to the building structure, and evaluation of the existing building structure to support the ceiling lifts. Our review did not include design, stability, or attachment of the ceiling lift rail system.

Following our review, we have determined the ceiling lift support details are acceptable. Additionally, we have determined the existing building structure is acceptable to support the ceiling lifts without retrofit. Our analysis is included in the attached structural calculations.

Thank you for the opportunity to be of continued service. Please contact us if you have any questions.

Very truly yours,

PCS STRUCTURAL SOLUTIONS



Dan C. Tappel, S.E.  
Associate

Reviewed by:  
Todd P. Parke, S.E.  
Managing Principal



DCTdls  
24-364

Attachments: Reference Drawings, Structural Calculations

Note all special inspection(s) required for this project - the final special inspection report(s) must be on site during City inspections.

# REFERENCE DRAWINGS


See City-stamped construction drawings for City notes.

Note all special inspection(s) required for this project - the final special inspection report(s) must be on site during City inspections.



Brown Industries, LLC

# NW Ceiling Lifts




Location:
MC Good Samaritan Hospital 407 14th Avenue SE Puyallup, WA 98371
Project:
Install (04) Patient Lifts in Rehab on Level A

City Stamp:

Note all special inspection(s) required for this project - the final special inspection report(s) must be on site during City inspections.



Project	Rehab Retrofit	By	S. Krause	Sheet No.	Site Plan
Location	Puyallup, WA	Date	04/09/24		
Client	MC Good Samaritan	Revised		Job No.	WO
	SWL 700#	Date			2023-0028



Note all special inspection(s) required for this project - the final special inspection report(s) must be on site during City inspections.



Project	Rehab Retrofit	By	S. Krause	Sheet No.	LA-Floor A
Location	Puyallup, WA	Date	04/09/24		
Client	MC Good Samaritan	Revised		Job No.	WO
	SWL 700#	Date			2023-0028



**Scope of Work** (orange box)  
**Previous Install** (blue box)


NORTH  
  
**LEVEL A FLOOR PLAN**  
**GOOD SAMARITAN HOSPITAL**  
 NOT TO SCALE

Note all special inspection(s) required for this project - the final special inspection report(s) must be on site during City inspections.



Project	Rehab Retrofit	By	S. Krause	Sheet No.	LA-PTGym
Location	Puyallup, WA	Date	04/09/24	Job No.	
Client	MC Good Samaritan	Revised	S. Krause	Date	2023-0028
	SWL 1000#				

Ceiling Height: 9'-0"  
 Rails below ceiling - 1" clearance  
 Aligned to ceiling grid  
 Dims from FFW

Rails lined for continuous charge  
 Power outlet (regular service)  
 Preferred end of rail marked  
 Outlet 6-12" BFC, 12" from rail end



**PT GYM LAYOUT**

- Jumbo Rail
- Midi Rail
-  Power Outlet
-  Support Brace

Note all special inspection(s) required for this project - the final special inspection report(s) must be on site during City inspections.


Project	Rehab Retrofit	By	S. Krause	Sheet No.	LA-Rm36
Location	Puyallup, WA	Date	04/09/24		
Client	MC Good Samaritan	Revised	S. Krause	Job No.	WO
	SWL 1000#	Date	05/13/24		2023-0028

Ceiling Height: 8'-0"  
 Rails below ceiling - 1" clearance  
 Aligned to ceiling grid  
 Dims from FFW

Rails lined for continuous charge  
 Power outlet (regular service)  
 Preferred end of rail marked  
 Outlet 6-12" BFC, 12" from rail end



NOTES:

1. Separate Curtain panels on each side of traverse rail
2. Locate rails for optimal coverage of headwall units. Partial coverage near windows desired.
3. Braces may go in either direction
4. Long brace may be on either support



**ROOM 36 LAYOUT**

Rm36

- Jumbo Rail
- Midi Rail
-  Power Outlet
-  Support Brace

Note all special inspection(s) required for this project - the final special inspection report(s) must be on site during City inspections.




Project	Rehab Retrofit	By	S. Krause	Sheet No.	LA-Rm38
Location	Puyallup, WA	Date	04/09/24	Job No.	
Client	MC Good Samaritan	Revised	S. Krause	Date	2023-0028
	SWL 1000#				

Ceiling Height: 8'-0"  
 Rails below ceiling - 1" clearance  
 Aligned to ceiling grid  
 Dims from FFW

Rails lined for continuous charge  
 Power outlet (regular service)  
 Preferred end of rail marked  
 Outlet 6-12" BFC, 12" from rail end

NOTES:

1. Separate Curtain panels on each side of traverse rail
2. Locate rails for optimal coverage of headwall units.
3. Braces may go in either direction
4. Long brace may be on either support



Rm38

## ROOM 38 LAYOUT

- Jumbo Rail
- Midi Rail
- Power Outlet
- Support Brace

Note all special inspection(s) required for this project - the final special inspection report(s) must be on site during City inspections.






Project	Rehab Retrofit	By	S. Krause	Sheet No.	LA-Rm41
Location	Puyallup, WA	Date	04/09/24		
Client	MC Good Samaritan	Revised	S. Krause	Job No.	WO
	SWL 700#	Date	05/13/24		2023-0028

Ceiling Height: 8'-0"  
 Rails below ceiling - 1" clearance  
 Aligned to ceiling grid  
 Dims from FFW

Rails lined for continuous charge  
 Power outlet (regular service)  
 Preferred end of rail marked  
 Outlet 6-12" BFC, 12" from rail end

NOTES:

1. Separate Curtain panels on each side of traverse rail
2. Locate rails for optimal coverage of headwall units.
3. Braces may go in either direction
4. Long brace may be on either support
5. Building analysis restricts room to SWL 700#




Rm41

ROOM 41 LAYOUT

- Jumbo Rail
- Midi Rail
- Power Outlet
- Support Brace

Note all special inspection(s) required for this project - the final special inspection report(s) must be on site during City inspections.

Project	Rehab Retrofit	By	S. Krause	Sheet No. <b>S401</b>
Location	Puyallup, WA	Date	04/09/24	
Client	MC Good Samaritan	Revised		Job No. <b>WO 2023-0028</b>
	SWL 1000#	Date		



LIFT RAIL	SPAN "L"	CANTILEVER "X"
MIDI	99"	16"
JUMBO	206"	30"

RAIL INDICATES FIXED RAIL  
 L = MAX. SPAN BETWEEN HANGERS  
 X = MAX. CANTILEVER AT EITHER END BEYOND HANGER


**NOTE:**

- WHEN CANTILEVER IS USED, SPAN "L" MUST BE AT LEAST 6x CANTILEVER, TO ENSURE THAT THE MAXIMUM END REACTION AT HANGER IS ACCEPTABLE

# 1 ELEVATION OF FIXED RAILS

Note all special inspection(s) required for this project - the final special inspection report(s) must be on site during City inspections.


Project	Rehab Retrofit	By	S. Krause	Sheet No.	S402
Location	Puyallup, WA	Date	04/09/24	Job No.	
Client	MC Good Samaritan	Revised		Date	2023-0028
	SWL 1000#				



## 2 TYP. TRAPEZE FRAMING

Note all special inspection(s) required for this project - the final special inspection report(s) must be on site during City inspections.

Project	Rehab Retrofit	By	S. Krause	Sheet No. <b>S403</b>
Location	Puyallup, WA	Date	04/09/24	
Client	MC Good Samaritan	Revised		Job No. <b>WO</b>
	SWL 1000#	Date		<b>2023-0028</b>




NOTES:

1. WHERE AN OBSTRUCTION IS IN THE WAY OF THE HANGER. REF. 2/S402.
2. BRACE MAY OCCUR TO EITHER SIDE

**3 TYP. VERTICAL SUPPORT DETAIL**

Note all special inspection(s) required for this project - the final special inspection report(s) must be on site during City inspections.

Project	Rehab Retrofit	By	S. Krause	Sheet No.	S404
Location	Puyallup, WA	Date	04/09/24		
Client	MC Good Samaritan	Revised		Job No.	WO
	SWL 1000#	Date			2023-0028




NOTES:

1. INSTALL ANCHORS IN ACCORDANCE W/ MANUFACTURERS INSTRUCTIONS.
2. OWNER/CONTRACTOR/ARCHITECT TO COORDINATE AND PROVIDE SPECIAL INSPECTION OF CONCRETE ANCHOR INSTALLATION AS REQUIRED BY THE GOVERNING CODE AND ESR-1917.
3. ROD STIFFENER REQUIRED IF ROD LONGER THAN 21". REF. 6/S406.
4. DO NOT DAMAGE REBAR IN (E) SLAB. RELOCATE ANCHORS TO AVOID (E) REBAR.

## 4 SUPPORT CONNECTION AT DECK

Note all special inspection(s) required for this project - the final special inspection report(s) must be on site during City inspections.

Project	Rehab Retrofit	By	S. Krause	Sheet No. <b>S405</b>
Location	Puyallup, WA	Date	04/09/24	
Client	MC Good Samaritan	Revised		Job No. <b>WO</b>
	SWL 1000#	Date		<b>2023-0028</b>




NOTES:

1. INSTALL ANCHORS IN ACCORDANCE W/ MANUFACTURERS INSTRUCTIONS, ESR 1917, INCLUDING PERFORMING PERIODIC INSPECTIONS. INSPECTIONS TO BE COORDINATED BY OWNER/ARCHITECT/CONTRACTOR.
2. DO NOT DAMAGE REBAR IN (E) SLAB.
3. RELOCATE BOLT TO AVOID (E) REBAR.

**5** BRACE CONNECTION AT DECK

Note all special inspection(s) required for this project - the final special inspection report(s) must be on site during City inspections.

Project	Rehab Retrofit	By	S. Krause	Sheet No. <b>S406</b>
Location	Puyallup, WA	Date	04/09/24	
Client	MC Good Samaritan	Revised		Job No. <b>WO</b>
	SWL 1000#	Date		<b>2023-0028</b>



NOTES:

1. LATERAL BRACE PERPENDICULAR TO RAIL ON ALL SUPPORTS. SEE PLANS FOR LONGITUDINAL BRACE LOCATIONS
2. SEE DETAIL 4/S404 FOR DECK CONNECTION
3. ROD STIFFENER REQUIRED IF ROD LONGER THAN 21"

## 6 VERT. BOTTOM CONNECTION

Note all special inspection(s) required for this project - the final special inspection report(s) must be on site during City inspections.

# STRUCTURAL CALCULATIONS





Project: MHS GOOD SAM REHAB CEILING LIFTS Job No: \_\_\_\_\_  
Subject: \_\_\_\_\_ Sheet \_\_\_\_\_ Name: DCT  
Originating Office:  Seattle  Tacoma  Portland Date: 05/15/24

DESIGN APPROACH:

DESIGN CEILING LIFT HANGER SUPPORTS, BRACING, AND ANCHORAGE FOR 1,000# LIFT CAPACITY.

EVALUATE EXISTING STRUCTURE FOR 1,000# LIFT CAPACITY FOR THE CEILING LIFTS AT THE REHAB GYM, ROOM #36, AND ROOM #38.

EVALUATE EXISTING STRUCTURE FOR 700# LIFT CAPACITY FOR THE CEILING LIFT AT ROOM #41.

## Design Criteria

### Dead Load

Lift wt,  $W_{Lift} := 40 \cdot lbf$

Track wt,  $W_{Track} := 10 \cdot lbf$  Trib. to (1) hanger

Total wt,  $W_D := W_{Lift} + W_{Track} = 50 \ lbf$

### Live Load

Lift capacity,  $W_L := 1000 \cdot lbf$

### Lateral Forces

During operation

Transverse,  $V_{Trans} := 0.2 \cdot (W_D + W_L) = 210 \ lbf$  20% of gravity load

Longitudinal,  $V_{Long} := 0.1 \cdot (W_D + W_L) = 105 \ lbf$  10% of gravity load

### Seismic

$S_S := 1.267$

$S_{DS} := 1.013$

$S_I := 0.436$

$S_{DI} := 0.542$

Seismic forces

$$a_p := 2.5$$

$$R_p := 3.5$$

$$Q_o := 2.5$$

$$I_p := 1.5$$

$$z := 11.08 \cdot \text{ft}$$

$$h := 35.25 \cdot \text{ft}$$

ASCE 7-16 T13.5-1 for flexible components w/ high deformability

$$F_{ph} := \frac{0.4 \cdot a_p \cdot S_{DS} \cdot W_D}{\frac{R_p}{I_p}} \cdot \left( 1 + 2 \cdot \left( \frac{z}{h} \right) \right) = 35.4 \text{ lbf}$$

$$F_{p\_min} := 0.3 \cdot S_{DS} \cdot I_p \cdot W_D = 22.8 \text{ lbf}$$

$$F_{p\_max} := 1.6 \cdot S_{DS} \cdot I_p \cdot W_D = 121.6 \text{ lbf}$$

$$F_p := \left\| \begin{array}{l} \text{if } F_{p\_min} > F_{ph} \\ \quad \left\| F_{p\_min} \right\| \\ \text{else if } F_{p\_max} < F_{ph} \\ \quad \left\| F_{p\_max} \right\| \\ \text{else} \\ \quad \left\| F_{ph} \right\| \end{array} \right\| = 35.4 \text{ lbf}$$

$$F_{pv} := 0.2 \cdot S_{DS} \cdot W_D = 10.1 \text{ lbf}$$

## Threaded Rod Hanger

Load in tension

$$T_{R1} := W_D + W_L + 0.7 \cdot \left( F_{pv} + \frac{F_p \cdot \tan\left(\frac{60 \cdot \pi}{180}\right)}{2} \right) = 1078.5 \text{ lbf}$$

$$T_{R2} := W_D + W_L + V_{Trans} \cdot \frac{\tan\left(\frac{60 \cdot \pi}{180}\right)}{2} = 1231.9 \text{ lbf}$$

$$T_R := \max(T_{R1}, T_{R2}) = 1231.9 \text{ lbf}$$

Try 1/2" dia. threaded rod

$$F_y := 36 \text{ ksi}$$


$$A_g := 0.126 \text{ in}^2 \quad \text{root area}$$

$$\Omega := 1.67$$

$$T_a := \frac{F_y \cdot A_g}{\Omega} = 2716.2 \text{ lbf}$$

$$\text{Design} := \begin{cases} \text{if } T_a > T_R \\ \quad \text{“OK”} \\ \text{else} \\ \quad \text{“NG”} \end{cases} = \text{“OK”}$$

∴ Use 1/2" dia. threaded rod



Try (2) 1/2" dia. Hilti KB-TZ to concrete deck - design each anchor for full tension load

$$T_{U1} := 1.2 W_D + W_L + F_{pv} + \frac{F_p \cdot \Omega_o \cdot \tan\left(\frac{60 \cdot \pi}{180}\right)}{2} = 1146.7 \text{ lbf}$$

$$T_{U2} := 1.2 \cdot W_D + 1.6 W_L + \frac{1.6 \cdot V_{Trans} \cdot \tan\left(\frac{60 \cdot \pi}{180}\right)}{2} = 1951 \text{ lbf}$$


$$T_U := \max(T_{U1}, T_{U2}) = 1951 \text{ lbf}$$

Per Hilti Profis

$$DCR_{max} := 0.80$$

$$Design := \begin{cases} \text{if } DCR_{max} < 1 \\ \text{“OK”} \\ \text{else} \\ \text{“NG”} \end{cases} = \text{“OK”}$$

∴ Use (2) 1/2" dia. Hilti KB-TZ (2" embed min)





www.hilti.com

Company:  
 Address:  
 Phone | Fax: |  
 Design: Hanger Anchorage  
 Fastening point:


Page: 1  
 Specifier:  
 E-Mail:  
 Date: 4/26/2024

**Specifier's comments:**

**1 Input data**

<b>Anchor type and diameter:</b>	<b>Kwik Bolt TZ2 - CS 1/2 (2) hnom2</b>	 
Item number:	2210254 KB-TZ2 1/2x3 3/4	
Effective embedment depth:	$h_{ef,act} = 2.000$ in., $h_{nom} = 2.500$ in.	
Material:	Carbon Steel	
Evaluation Service Report:	ESR-4266	
Issued   Valid:	12/1/2023   12/1/2025	
Proof:	Design Method ACI 318-19 / Mech	
Stand-off installation:		
Profile:		
Base material:	cracked concrete, 4000, $f'_c = 4,000$ psi; $h = 10.000$ in.	
<b>Installation:</b>	<b>hammer drilled hole, Installation condition: Dry</b>	
Reinforcement:	tension: not present, shear: not present; no supplemental splitting reinforcement present edge reinforcement: none or < No. 4 bar	

**Geometry [in.] & Loading [lb, in.lb]**





www.hilti.com

Company:		Page:	2
Address:		Specifier:	
Phone   Fax:		E-Mail:	
Design:	Hanger Anchorage	Date:	4/26/2024
Fastening point:			

1.1 Design results

Case	Description	Forces [lb] / Moments [in.lb]	Seismic	Max. Util. Anchor [%]
1	Combination 1	N = 1,951; V <sub>x</sub> = 0; V <sub>y</sub> = 0; M <sub>x</sub> = 0; M <sub>y</sub> = 0; M <sub>z</sub> = 0;	no	80

2 Load case/Resulting anchor forces

Anchor reactions [lb]

Tension force: (+Tension, -Compression)

Anchor	Tension force	Shear force	Shear force x	Shear force y
1	1,951	0	0	0

3 Tension load

	Load N <sub>ua</sub> [lb]	Capacity $\phi$ N <sub>n</sub> [lb]	Utilization $\beta_N = N_{ua} / \phi N_n$	Status
Steel Strength*	1,951	8,433	24	OK
Pullout Strength*	N/A	N/A	N/A	N/A
Concrete Breakout Failure**	1,951	2,442	80	OK

\* highest loaded anchor \*\*anchor group (anchors in tension)



www.hilti.com

Company:		Page:	3
Address:		Specifier:	
Phone   Fax:		E-Mail:	
Design:	Hanger Anchorage	Date:	4/26/2024
Fastening point:			

**3.1 Steel Strength**

$N_{sa}$  = ESR value refer to ICC-ES ESR-4266  
 $\phi N_{sa} \geq N_{ua}$  ACI 318-19 Table 17.5.2

**Variables**

$A_{se,N}$ [in. <sup>2</sup> ]	$f_{uta}$ [psi]
0.10	114,004

**Calculations**

$N_{sa}$ [lb]
11,244

**Results**

$N_{sa}$ [lb]	$\phi_{steel}$	$\phi N_{sa}$ [lb]	$N_{ua}$ [lb]
11,244	0.750	8,433	1,951

**3.2 Concrete Breakout Failure**

$N_{cb} = \left( \frac{A_{Nc}}{A_{Nc0}} \right) \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b$  ACI 318-19 Eq. (17.6.2.1a)

$\phi N_{cb} \geq N_{ua}$  ACI 318-19 Table 17.5.2

$A_{Nc}$  see ACI 318-19, Section 17.6.2.1, Fig. R 17.6.2.1(b)

$A_{Nc0} = 9 h_{ef}^2$  ACI 318-19 Eq. (17.6.2.1.4)

$\psi_{ed,N} = 0.7 + 0.3 \left( \frac{c_{a,min}}{1.5 h_{ef}} \right) \leq 1.0$  ACI 318-19 Eq. (17.6.2.4.1b)

$\psi_{cp,N} = \text{MAX} \left( \frac{c_{a,min}}{c_{ac}}, \frac{1.5 h_{ef}}{c_{ac}} \right) \leq 1.0$  ACI 318-19 Eq. (17.6.2.6.1b)

$N_b = k_c \lambda_a \sqrt{f'_c} h_{ef}^{1.5}$  ACI 318-19 Eq. (17.6.2.2.1)

**Variables**

$h_{ef}$ [in.]	$c_{a,min}$ [in.]	$\psi_{c,N}$	$c_{ac}$ [in.]	$k_c$	$\lambda_a$	$f'_c$ [psi]
2.000	$\infty$	1.000	5.500	21	1.000	4,000

**Calculations**

$A_{Nc}$ [in. <sup>2</sup> ]	$A_{Nc0}$ [in. <sup>2</sup> ]	$\psi_{ed,N}$	$\psi_{cp,N}$	$N_b$ [lb]
36.00	36.00	1.000	1.000	3,757

**Results**

$N_{cb}$ [lb]	$\phi_{concrete}$	$\phi N_{cb}$ [lb]	$N_{ua}$ [lb]
3,757	0.650	2,442	1,951





www.hilti.com

Company:		Page:	4
Address:		Specifier:	
Phone   Fax:		E-Mail:	
Design:	Hanger Anchorage	Date:	4/26/2024
Fastening point:			

### 4 Shear load

	Load $V_{ua}$ [lb]	Capacity $\phi V_n$ [lb]	Utilization $\beta_v = V_{ua} / \phi V_n$	Status
Steel Strength*	N/A	N/A	N/A	N/A
Steel failure (with lever arm)*	N/A	N/A	N/A	N/A
Pryout Strength*	N/A	N/A	N/A	N/A
Concrete edge failure in direction **	N/A	N/A	N/A	N/A

\* highest loaded anchor    \*\*anchor group (relevant anchors)

### 5 Warnings

- The anchor design methods in PROFIS Engineering require rigid anchor plates per current regulations (AS 5216:2021, ETAG 001/Annex C, EOTA TR029 etc.). This means load re-distribution on the anchors due to elastic deformations of the anchor plate are not considered - the anchor plate is assumed to be sufficiently stiff, in order not to be deformed when subjected to the design loading. PROFIS Engineering calculates the minimum required anchor plate thickness with CBFEM to limit the stress of the anchor plate based on the assumptions explained above. The proof if the rigid anchor plate assumption is valid is not carried out by PROFIS Engineering. Input data and results must be checked for agreement with the existing conditions and for plausibility!
- Condition A applies where the potential concrete failure surfaces are crossed by supplementary reinforcement proportioned to tie the potential concrete failure prism into the structural member. Condition B applies where such supplementary reinforcement is not provided, or where pullout or pryout strength governs.
- Refer to the manufacturer's product literature for cleaning and installation instructions.
- For additional information about ACI 318 strength design provisions, please go to <https://submittals.us.hilti.com/PROFISAnchorDesignGuide/>
- Hilti post-installed anchors shall be installed in accordance with the Hilti Manufacturer's Printed Installation Instructions (MPII). Reference ACI 318-19, Section 26.7.

**Fastening meets the design criteria!**



www.hilti.com

Company:		Page:	5
Address:		Specifier:	
Phone   Fax:		E-Mail:	
Design:	Hanger Anchorage	Date:	4/26/2024
Fastening point:			

## 6 Installation data

Profile: -

Hole diameter in the fixture: -

Plate thickness (input): -

Drilling method: Hammer drilled

Cleaning: Manual cleaning of the drilled hole according to instructions for use is required.

Anchor type and diameter: Kwik Bolt TZ2 - CS 1/2 (2) hnom2

Item number: 2210254 KB-TZ2 1/2x3 3/4

Maximum installation torque: 602 in.lb

Hole diameter in the base material: 0.500 in.

Hole depth in the base material: 2.750 in.

Minimum thickness of the base material: 4.000 in.

Hilti KB-TZ2 stud anchor with 2.5 in embedment, 1/2 (2) hnom2, Carbon steel, installation per ESR-4266

### 6.1 Recommended accessories

Drilling	Cleaning	Setting
<ul style="list-style-type: none"> <li>• Suitable Rotary Hammer</li> <li>• Properly sized drill bit</li> </ul>	<ul style="list-style-type: none"> <li>• Manual blow-out pump</li> </ul>	<ul style="list-style-type: none"> <li>• Torque controlled cordless impact tool</li> <li>• Torque wrench</li> <li>• Hammer</li> </ul>

### Coordinates Anchor in.

Anchor	x	y	C <sub>-x</sub>	C <sub>+x</sub>	C <sub>-y</sub>	C <sub>+y</sub>
1	0.000	0.000	-	-	-	-



www.hilti.com

---

Company:		Page:	6
Address:		Specifier:	
Phone   Fax:		E-Mail:	
Design:	Hanger Anchorage	Date:	4/26/2024
Fastening point:			

---

## 7 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

Load in compression

$$C_{R1} := 0.6 \cdot W_D - 0.7 \cdot \left( F_{pv} + \frac{F_p \cdot \tan\left(\frac{60 \cdot \pi}{180}\right)}{2} \right) = 1.5 \text{ lbf}$$

$$C_{R2} := 0.6 \cdot W_D - V_{Trans} \cdot \frac{\tan\left(\frac{60 \cdot \pi}{180}\right)}{2} = -151.9 \text{ lbf}$$

$$C_R := \min(C_{R1}, C_{R2}) = -151.9 \text{ lbf}$$

Try P1000 w/ P2486 @ 21" o.c.

Per Unistrut


$$f_a := 3745 \text{ psi}$$

$$A_g := 0.126 \text{ in}^2 \quad \text{root area}$$

$$C_a := f_a \cdot A_g = 471.87 \text{ lbf}$$

$$Design := \begin{cases} \text{if } C_a > |C_R| \\ \quad \text{"OK"} \\ \text{else} \\ \quad \text{"NG"} \end{cases} = \text{"OK"}$$

Use 1/2" dia. threaded rod w/ P1000 & P2486 @ 21" o.c.





1 5/8" Channel

Telestrut

Nuts & Hardware

General Fittings

Pipe/Conduit Supports



Electrical Fittings

Concrete Inserts

Solar


Unipier®

## SLOT ADAPTER™




Part No.	Bolt Size	Wt/100 pcs Lbs (kg)
HOCW025	1/4" (6.4)	1 (0.5)
HOCW037	3/8" (9.5)	1.5 (0.7)



## KWIK WASHER™



Overhead installation with one hand.  
Available in zinc plated and hot dip galvanized




## P2486 SEISMIC ROD STIFFENER




Wt/100 pcs: 16 Lbs (7.3 kg)

Part No.	Size In (mm)	Load Lbs (kN)	Wt/100 pcs Lbs (kg)
K1062	1/4" (6.4)	250 (1.11)	1.2 (0.5)
K1063	3/8" (9.5)	610 (2.71)	2.6 (1.2)
K1064	1/2" (12.7)	1,130 (5.03)	9.3 (4.2)

## P2485 CRADLE CLIP






Cradle clip only, order other items separately.



## P2485K

## SEISMIC CRADLE CLIP ASSEMBLY



Wt/100 pcs: 3.0 Lbs (1.4 kg)

## P2485 & P2486 – SPACING CHART

Rod Size In (mm)	Root Area In <sup>2</sup> (mm <sup>2</sup> )	Radius of Gyration In (mm)	Design Load Lbs (kN)	.....Rod Stiffener Clip Spacing (L).....			
				Rod Stress @100% 10,700 PSI In (mm)	Rod Stress @75% 8,025 PSI In (mm)	Rod Stress @50% 5,350 PSI In (mm)	Rod Stress @35% 3,745 PSI In (mm)
3/8	0.068	0.074	730	9	11	13	15
9.5	19.5	1.99	3.25	228.6	279.4	330.2	381.0
1/2	0.126	0.100	1,350	12	14	17	21
12.7	72.4	2.40	6.01	304.8	355.6	431.8	533.4
5/8	0.202	0.127	2,160	15	18	22	26
15.9	138.3	3.32	9.61	381.0	457.2	558.8	660.4

Notes:

1. Minimum Tensile Stress is 50,000 psi (345MPa)
2. Working Stress is 10,700 psi (73.9 MPa) – Same as for Tension
3. Compression Will Only Occur During a Seismic Event
4. Compression Requires the Use of Rod Stiffeners
5. KL/r = 200 When Rod Stress is at 35%

Refer to seismic bracing systems catalog for more detailed information.

## Unistrut Trapeze

Loads (from previous calculations)

$$T_{R\_Trap} := \max(T_R, 1.25 \cdot W_L) = 1250 \text{ lbf}$$

Try Unistrut channels

P1000T

$$M_{a\_Unfactored} := 5070 \text{ in} \cdot \text{lbf}$$

$$I_x := 0.185 \text{ in}^4$$

$$E := 29 \cdot 10^6 \text{ psi}$$

$$L := 13 \cdot \text{in} \quad \text{Maximum span}$$

$$C_{Unbr} := 1 \quad \text{Unbraced length factor}$$


$$C_{Pierce} := 0.85 \quad \text{Pierced channel factor}$$

$$M_a := M_{a\_Unfactored} \cdot C_{Unbr} \cdot C_{Pierce} = 4309.5 \text{ in} \cdot \text{lbf}$$

$$M_R := \frac{T_{R\_Trap} \cdot L}{4} = 4062.5 \text{ in} \cdot \text{lbf}$$

$$\Delta := \frac{T_{R\_Trap} \cdot L^3}{48 \cdot E \cdot I_x} = 0.01 \text{ in}$$

$$\Delta_{max} := 0.25 \cdot \text{in}$$





1 5/8" Channel

Telestrut

Nuts & Hardware

General Fittings

Pipe/Conduit Supports

Electrical Fittings




Concrete Inserts

Solar

Unipier®

### P1000®




DF GR HG PG PL



Wt/100 Ft: 189 Lbs (281 kg/100 m)  
 Allowable Moment 5,070 In-Lbs (570 NŁm)  
 12 Gauge Nominal Thickness .105" (2.7mm)

### P1001

DF GR HG PG PL



Wt/100 Ft: 378 Lbs (562 kg/100 m)  
 Allowable Moment 14,360 In-Lbs (1,620 NŁm)  
 12 Gauge Nominal Thickness .105" (2.7mm)

### P1000 DS

### P1000 H3

GR HG PG PL


### P1000 HS

GR HG PG PL


### P1000 KO

GR PG


Slots are 2 3/4" (69.9) x 7/8" (22.2)  
 3 1/2" (88.9) on Center




9/16" (14.3) Dia. Holes  
 1 7/8" (47.6) on Center



9/16" (14.3) Dia. Holes  
 1 7/8" (47.6) on Center



7/8" (22.2) Knockouts  
 6" (152.4) on Center



Wt/100 Ft: 173 Lbs (257 kg/100 m) Wt/100 Ft: 175 Lbs (260 kg/100 m) Wt/100 Ft: 190 Lbs (283 kg/100 m)

Wt/100 Ft: 185 Lbs (275 kg/100 m)

### P1000 SL

GR HG PG PL


### P1000 T

DF GR HG PG PL

### P1000 WT


DF GR HG PG PL

Slots are 3" (76.2) x 3/2" (10.3)  
 4" (101.6) on Center




Wt/100 Ft: 185 Lbs (275 kg/100 m)

Slots are 1 1/8" (28.6) x 9/16" (14.3)  
 2" (50.8) on Center



Wt/100 Ft: 185 Lbs (275 kg/100 m)


Slots are 2" (50.8) x 1 1/8" (17.5)  
 3" (76.2) on Center



Wt/100 Ft: 185 Lbs (275 kg/100 m)

### CHANNEL NUTS (REFER TO PAGES 73,74 FOR DETAILS)


SEE PAGE 73, 74



P1006-0832  
 P1006-1024  
 P1006-1420  
 P1007  
 P1008  
 P1009  
 P1010



P1008T  
 P1006T1420  
 P1010T



P1024  
 P1012S  
 P1023S



P3006-0832  
 P3006-1024  
 P3006-1420  
 P3007  
 P3008  
 P3009  
 P3010



P3016-0632  
 P3016-0832  
 P3016-1024  
 P3016-1420



P1012  
 P1023  
 P1024S

Channel Finishes: DF, PL, GR, HG, PG, ZD; Standard Lengths: 10' & 20'

P1000 - BEAM LOADING

Span In	Max. Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	1,690	0.06	1,690	1,690	1,690
36	1,130	0.13	1,130	1,130	900
48	850	0.22	850	760	500
60	680	0.35	650	480	320
72	560	0.50	450	340	220
84	480	0.68	330	250	160
96	420	0.89	250	190	130
108	380	1.14	200	150	100
120	340	1.40	160	120	80
144	280	2.00	110	80	60
168	240	2.72	80	60	40
192	210	3.55	60	50	NR
216	190	4.58	50	40	NR
240	170	5.62	40	NR	NR

P1001 - BEAM LOADING

Span In	Max. Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	3,500*	0.02	3,500*	3,500*	3,500*
36	3,190	0.07	3,190	3,190	3,190
48	2,390	0.13	2,390	2,390	2,390
60	1,910	0.20	1,910	1,910	1,620
72	1,600	0.28	1,600	1,600	1,130
84	1,370	0.39	1,370	1,240	830
96	1,200	0.51	1,200	950	630
108	1,060	0.64	1,000	750	500
120	960	0.79	810	610	410
144	800	1.14	560	420	280
168	680	1.53	410	310	210
192	600	2.02	320	240	160
216	530	2.54	250	190	130
240	480	3.16	200	150	100

P1000 - COLUMN LOADING

Unbraced Height In	Max. Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	3,550	10,740	9,890	8,770	7,740
36	3,190	8,910	7,740	6,390	5,310
48	2,770	7,260	6,010	4,690	3,800
60	2,380	5,910	4,690	3,630	2,960
72	2,080	4,840	3,800	2,960	2,400
84	1,860	4,040	3,200	2,480	1,980
96	1,670	3,480	2,750	2,110	1,660
108	1,510	3,050	2,400	1,810	**
120	1,380	2,700	2,110	**	**
144	1,150	2,180	1,660	**	**

P1001 - COLUMN LOADING

Unbraced Height In	Max. Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	6,430	24,280	23,610	22,700	21,820
36	6,290	22,810	21,820	20,650	19,670
48	6,160	21,410	20,300	18,670	16,160
60	6,000	20,210	18,670	15,520	12,390
72	5,620	18,970	16,160	12,390	8,950
84	5,170	16,950	13,630	9,470	6,580
96	4,690	14,890	11,190	7,250	5,040
108	4,170	12,850	8,950	5,730	3,980
120	3,690	10,900	7,250	4,640	**
144	2,930	7,630	5,040	**	**

P1000/P1001 - ELEMENTS OF SECTION

Parameter	P1000	P1001
Area of Section	0.555 In <sup>2</sup>	1.111 In <sup>2</sup>
Axis 1-1		
Moment of Inertia (I)	0.185 In <sup>4</sup>	0.928 In <sup>4</sup>
Section Modulus (S)	0.202 In <sup>3</sup>	0.571 In <sup>3</sup>
Radius of Gyration (r)	0.577 In	0.914 In
Axis 2-2		
Moment of Inertia (I)	0.236 In <sup>4</sup>	0.471 In <sup>4</sup>
Section Modulus (S)	0.290 In <sup>3</sup>	0.580 In <sup>3</sup>
Radius of Gyration (r)	0.651 In	0.651 In

Notes:

\* Load limited by spot weld shear.

. / » U !

NR = Not Recommended.

- Beam loads are given as total uniform load (W Lbs) not uniform load (w lbs/ft or w lbs/in).
- Beam loads are based on a simple span and assumed to be adequately laterally braced. Unbraced spans can reduce beam load carrying capacity. Refer to Page 18 for reduction factors for unbraced lengths.
- For pierced channel, multiply beam loads by the following factor:
 

"KO" Series.....95%	"T" Series.....85%
"HS" Series.....90%	"SL" Series.....85%
"H3" Series.....90%	"DS" Series.....70%
"WT" Series.....85%	

- Deduct channel weight from the beam loads.
- For concentrated midspan point loads, multiply beam loads by 50% and the corresponding deflection by 80%. For other load conditions refer to page 18.
- All beam loads are for bending about Axis 1-1.

1 1/8" Channel  
Telestrut  
Nuts & Hardware  
General Fittings  
Pipe/Conduit Supports  
Electrical Fittings  
Concrete Inserts  
Solar  
Unipipe®



```
Design := || if  $M_d > M_R$  || = "OK"  
          || || | |
          || if  $\Delta < \Delta_{max}$  ||  
          || || "OK" ||  
          || else ||  
          || || "NG" ||  
          || else ||  
          || || "NG" ||
```

**.:Use P1000T for L=13in max**

## P1000

Same as P1000T, except

$L := 16 \cdot \text{in}$  Maximum span

$C_{Unbr} := 1$  Unbraced length factor

$C_{Pierce} := 1$  Pierced channel factor

$$M_a := M_{a\_Unfactored} \cdot C_{Unbr} \cdot C_{Pierce} = 5070 \text{ in} \cdot \text{lbf}$$

$$M_R := \frac{T_{R\_Trap} \cdot L}{4} = 5000 \text{ in} \cdot \text{lbf}$$

$$\Delta := \frac{T_{R\_Trap} \cdot L^3}{48 \cdot E \cdot I_x} = 0.02 \text{ in}$$

$$\Delta_{max} := 0.25 \cdot \text{in}$$

$$Design := \begin{cases} \text{if } M_a > M_R \\ \quad \begin{cases} \text{if } \Delta < \Delta_{max} \\ \quad \text{“OK”} \\ \quad \text{else} \\ \quad \quad \text{“NG”} \end{cases} \\ \quad \text{else} \\ \quad \quad \text{“NG”} \end{cases} = \text{“OK”}$$

**∴ Use P1000 for L=16in max**

## P5500T

$$M_{a\_Unfactored} := 9820 \text{ in} \cdot \text{lb}f$$

$$I_x := 0.522 \text{ in}^4$$

$$L := 25 \cdot \text{in} \quad \text{Maximum span}$$

$$C_{Unbr} := 0.98 \quad \text{Unbraced length factor}$$

$$C_{Pierce} := 0.85 \quad \text{Pierced channel factor}$$

$$M_a := M_{a\_Unfactored} \cdot C_{Unbr} \cdot C_{Pierce} = 8180.1 \text{ in} \cdot \text{lb}f$$

$$M_R := \frac{T_{R\_Trap} \cdot L}{4} = 7812.5 \text{ in} \cdot \text{lb}f$$

$$\Delta := \frac{T_{R\_Trap} \cdot L^3}{48 \cdot E \cdot I_x} = 0.03 \text{ in}$$



$$\Delta_{max} := 0.25 \cdot \text{in}$$

$$Design := \begin{cases} \text{if } M_a > M_R \\ \quad \begin{cases} \text{if } \Delta < \Delta_{max} \\ \quad \text{"OK"} \\ \quad \text{else} \\ \quad \quad \text{"NG"} \end{cases} \\ \quad \text{else} \\ \quad \quad \text{"NG"} \end{cases} = \text{"OK"}$$

**∴ Use P5500T for L=25in max**

**P5500**



GR PG



Wt/100 Ft: 247 Lbs (367 kg/100 m)  
**Allowable Moment 9,820 In-Lbs (1,111 NŁm)**  
 12 Gauge Nominal Thickness .105" (2.7mm)

**P5501**

GR PG



Wt/100 Ft: 494 Lbs (734 kg/100 m)  
 Allowable Moment 28,940 In-Lbs (3,270 NŁm)  
 12 Gauge Nominal Thickness .105" (2.7mm)

**P5500 HS**

GR PG


**P5500 KO**

GR PG

**P5500 SL**


GR PG

9/16" (14.3) Dia. Holes  
 1 7/8" (47.6) on Center




Wt/100 Ft: 242 Lbs (360 kg/100 m)

7/8" (22.2) Knockouts  
 6" (152.4) on Center



Wt/100 Ft: 247 Lbs (368 kg/100 m)

Slots are  
 3" (76.2) x 13/32" (10.3)  
 4" (101.6) on Center



Wt/100 Ft: 242 Lbs (360 kg/100 m)


**P5500 T**

GR PG

**P5500 WT**


DF GR HG PG PL

Slots are  
 1 1/8" (28.6) x 9/16" (14.3)  
 2" (50.8) on Center



Wt/100 Ft: 242 Lbs (360 kg/100 m)


Slots are  
 2" (50.8) x 1 1/8" (17.5)  
 3" (76.2) on Center



Wt/100 Ft: 242 Lbs (360 kg/100 m)

**CHANNEL NUTS** (REFER TO PAGES 73,74 FOR DETAILS)

SEE PAGE 73, 74



**P5506-0832**  
**P5506-1024**  
**P5506-1420**  
**P5507**  
**P5508**  
**P5509**  
**P5510**



**P1006T1420**  
**P1008T**  
**P1010T**



**P1012**  
**P1023**  
**P1024**



**P3006-0832**  
**P3006-1024**  
**P3006-1420**  
**P3007**  
**P3008**  
**P3009**  
**P3010**



**P3016-0632**  
**P3016-0832**  
**P3016-1024**  
**P3016-1420**

Channel Finishes: PL, GR, HG, PG, ZD; Standard Lengths: 10' & 20'



1 1/8" Channel

Telestrut

Nuts & Hardware

General Fittings

Pipe/Conduit Supports

Electrical Fittings

Concrete Inserts

Solar

Unipier®

### P5500 - BEAM LOADING

Span In	Max Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	3,270	0.04	3,270	3,270	3,270
36	2,180	0.09	2,180	2,180	2,180
48	1,640	0.15	1,640	1,640	1,420
60	1,310	0.24	1,310	1,310	910
72	1,090	0.34	1,090	950	630
84	940	0.47	930	700	470
96	820	0.61	710	530	360
108	730	0.78	560	420	280
120	650	0.95	460	340	230
144	550	1.39	320	240	160
168	470	1.89	230	170	120
192	410	2.46	180	130	90
216	360	3.07	140	110	70
240	330	3.86	110	90	60

### P5501 - BEAM LOADING

Span In	Max Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	5,220*	0.01	5,220*	5,220*	5,220*
36	5,220*	0.04	5,220*	5,220*	5,220*
48	4,820	0.08	4,820	4,820	4,820
60	3,860	0.13	3,860	3,860	3,860
72	3,220	0.19	3,220	3,220	3,220
84	2,760	0.26	2,760	2,760	2,500
96	2,410	0.34	2,410	2,410	1,920
108	2,140	0.42	2,140	2,140	1,510
120	1,930	0.52	1,930	1,840	1,230
144	1,610	0.76	1,610	1,280	850
168	1,380	1.03	1,250	940	630
192	1,210	1.35	960	720	480
216	1,070	1.70	760	570	380
240	960	2.09	610	460	310

### P5500 - COLUMN LOADING

Unbraced Height In	Maximum Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	4,640	13,840	12,570	10,840	9,190
36	3,970	11,050	9,190	7,030	5,370
48	3,180	8,420	6,390	4,620	3,630
60	2,550	6,250	4,620	3,450	2,780
72	2,120	4,790	3,630	2,780	2,260
84	1,810	3,890	3,010	2,330	1,910
96	1,580	3,290	2,580	2,020	1,650
108	1,400	2,860	2,260	1,770	1,440
120	1,270	2,530	2,020	1,580	**
144	1,060	2,070	1,650	**	**
168	920	1,750	1,380	**	**

### P5501 - COLUMN LOADING

Unbraced Height In	Maximum Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	8,580	31,810	30,880	29,520	28,100
36	8,350	29,700	28,100	26,000	24,070
48	8,080	27,390	25,330	22,910	20,940
60	7,720	25,170	22,910	20,510	17,170
72	7,270	23,190	20,940	17,170	12,700
84	6,780	21,510	18,740	13,430	9,330
96	6,130	20,110	15,630	10,290	7,150
108	5,450	17,750	12,700	8,130	5,650
120	4,800	15,260	10,290	6,590	**
144	3,760	10,830	7,150	**	**
168	2,970	7,950	5,250	**	**

### P5500/P5501 - ELEMENTS OF SECTION

Parameter	P5500	P5501
Area of Section	0.726 In <sup>2</sup>	1.452 In <sup>2</sup>
Axis 1-1		
Moment of Inertia (I)	0.522 In <sup>4</sup>	2.805 In <sup>4</sup>
Section Modulus (S)	0.390 In <sup>3</sup>	1.151 In <sup>3</sup>
Radius of Gyration (r)	0.848 In	1.390 In
Axis 2-2		
Moment of Inertia (I)	0.334 In <sup>4</sup>	0.669 In <sup>4</sup>
Section Modulus (S)	0.411 In <sup>3</sup>	0.823 In <sup>3</sup>
Radius of Gyration (r)	0.679 In	0.679 In

Notes:

\* Load limited by spot weld shear.

. / > U !

NR = Not Recommended.

- Beam loads are given as total uniform load (W Lbs) not uniform load (w lbs/ft or w lbs/in).
- Beam loads are based on a simple span and assumed to be adequately laterally braced. Unbraced spans can reduce beam load carrying capacity. Refer to Page 62 for reduction factors for unbraced lengths.
- For pierced channel, multiply beam loads by the following factor:
 

"KO" Series.....95%	"T" Series .....85%
"HS" Series .....90%	"SL" Series .....85%
"WT" Series.....85%	
- Deduct channel weight from the beam loads.
- For concentrated midspan point loads, multiply beam loads by 50% and the corresponding deflection by 80%. For other load conditions refer to page 18.
- All beam loads are for bending about Axis 1-1.

P5500

Same as P5500T, except

$L := 29 \cdot \text{in}$  Maximum span

$C_{Unbr} := 0.95$  Unbraced length factor

$C_{Pierce} := 1$  Pierced channel factor

$$M_a := M_{a\_Unfactored} \cdot C_{Unbr} \cdot C_{Pierce} = 9329 \text{ in} \cdot \text{lb}f$$

$$M_R := \frac{T_{R\_Trap} \cdot L}{4} = 9062.5 \text{ in} \cdot \text{lb}f$$

$$\Delta := \frac{T_{R\_Trap} \cdot L^3}{48 \cdot E \cdot I_x} = 0.04 \text{ in}$$

$$\Delta_{max} := 0.25 \cdot \text{in}$$

$$Design := \begin{cases} \text{if } M_a > M_R \\ \quad \begin{cases} \text{if } \Delta < \Delta_{max} \\ \quad \text{“OK”} \\ \quad \text{else} \\ \quad \quad \text{“NG”} \end{cases} \\ \quad \text{else} \\ \quad \quad \text{“NG”} \end{cases} = \text{“OK”}$$

**∴ Use P5500 for L=29in max**

P5000T

$$M_{a\_Unfactored} := 15770 \text{ in} \cdot \text{lbf}$$

$$I_x := 1.098 \text{ in}^4$$

$$L := 36 \cdot \text{in} \quad \text{Maximum span}$$

$$C_{Unbr} := 0.85 \quad \text{Unbraced length factor}$$

$$C_{Pierce} := 0.85 \quad \text{Pierced channel factor}$$

$$M_a := M_{a\_Unfactored} \cdot C_{Unbr} \cdot C_{Pierce} = 11393.8 \text{ in} \cdot \text{lbf}$$

$$M_R := \frac{T_{R\_Trap} \cdot L}{4} = 11250 \text{ in} \cdot \text{lbf}$$

$$\Delta := \frac{T_{R\_Trap} \cdot L^3}{48 \cdot E \cdot I_x} = 0.04 \text{ in}$$

$$\Delta_{max} := 0.25 \cdot \text{in}$$

$$Design := \begin{cases} \text{if } M_a > M_R \\ \quad \text{if } \Delta < \Delta_{max} \\ \quad \quad \text{"OK"} \\ \quad \text{else} \\ \quad \quad \text{"NG"} \\ \text{else} \\ \quad \text{"NG"} \end{cases} = \text{"OK"}$$

**∴ Use P5000T for L=36in max**



1 5/8" Channel

Telestrut

Nuts & Hardware

General Fittings

Pipe/Conduit Supports

Electrical Fittings



Concrete Inserts

Solar

Unipier®

### P5000



DF GR PL PG



Wt/100 Ft: 305 Lbs (145 kg/100 m)  
**Allowable Moment 15,770 In-Lbs (1,780 N·m)**  
 12 Gauge Nominal Thickness .105" (2.7mm)

### P5001

DF GR PG



Wt/100 Ft: 610 Lbs (907 kg/100 m)  
 Allowable Moment 48,180 In-Lbs (5,440 N·m)  
 12 Gauge Nominal Thickness .105" (2.7mm)


### P5000 HS

GR PG


### P5000 KO

GR PG

9/16" (14.3) Dia. Holes  
 1 7/8" (47.6) on Center



7/8" (22.2) Knockouts  
 6" (152.4) on Center



Wt/100 Ft: 300 Lbs (446 kg/100 m)

Wt/100 Ft: 305 Lbs (454 kg/100 m)

### P5000 SL

GR PG


### P5000 T

DF GR PG


### P5000 WT

DF GR HG PG PL


Slots are  
 3" (76.2) x 3/32" (10.3)  
 4" (101.6) on Center



Slots are  
 1 1/8" (28.6) x 9/16" (14.3)  
 2" (50.8) on Center



Slots are  
 2" (50.8) x 1 1/8" (17.5)  
 3" (76.2) on Center



Wt/100 Ft: 300 Lbs (446 kg/100 m)

Wt/100 Ft: 300 Lbs (446 kg/100 m)

Wt/100 Ft: 300 Lbs (446 kg/100 m)

### CHANNEL NUTS (REFER TO PAGES 73,74 FOR DETAILS)

SEE PAGE 73, 74



**P5506-0832**  
**P5506-1024**  
**P5506-1420**  
**P5507**  
**P5508**  
**P5509**  
**P5510**



**P1006T1420**  
**P1008T**  
**P1010T**



**P1012**  
**P1023**  
**P1024**



**P3006-0832**  
**P3006-1024**  
**P3006-1420**  
**P3007**  
**P3008**  
**P3009**  
**P3010**



**P3016-0632**  
**P3016-0832**  
**P3016-1024**  
**P3016-1420**

Channel Finishes: DF, PL, GR, HG, PG, ZD; Standard Lengths: 10' & 20'



P5000 - BEAM LOADING

Span In	Max Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	5,260	0.03	5,260	5,260	5,260
36	3,500	0.07	3,500	3,500	3,500
48	2,630	0.12	2,630	2,630	2,630
60	2,100	0.18	2,100	2,100	1,920
72	1,750	0.26	1,750	1,750	1,330
84	1,500	0.36	1,500	1,470	980
96	1,310	0.47	1,310	1,120	750
108	1,170	0.59	1,170	890	590
120	1,050	0.73	960	720	480
144	880	1.06	670	500	330
168	750	1.43	490	370	240
192	660	1.88	370	280	190
216	580	2.35	300	220	150
240	530	2.95	240	180	120

P5001 - BEAM LOADING

Span In	Max Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	6,890*	0.01	6,890*	6,890*	6,890*
36	6,890*	0.02	6,890*	6,890*	6,890*
48	6,890*	0.05	6,890*	6,890*	6,890*
60	6,420	0.10	6,420	6,420	6,420
72	5,350	0.14	5,350	5,350	5,350
84	4,590	0.19	4,590	4,590	4,590
96	4,020	0.25	4,020	4,020	4,020
108	3,570	0.32	3,570	3,570	3,360
120	3,210	0.39	3,210	3,210	2,720
144	2,680	0.57	2,680	2,680	1,890
168	2,290	0.77	2,290	2,080	1,390
192	2,010	1.01	2,010	1,590	1,060
216	1,780	1.27	1,680	1,260	840
240	1,610	1.58	1,360	1,020	680

P5000 - COLUMN LOADING

Unbraced Height In	Maximum Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	5,650	16,870	15,180	12,850	10,600
36	4,690	13,140	10,600	7,650	5,660
48	3,560	9,550	6,860	4,790	3,660
60	2,730	6,680	4,790	3,450	2,710
72	2,160	4,980	3,660	2,710	2,170
84	1,760	3,950	2,960	2,240	1,820
96	1,500	3,270	2,500	1,930	1,580
108	1,310	2,800	2,170	1,690	1,390
120	1,170	2,450	1,930	1,510	**
144	980	1,980	1,580	**	**
168	850	1,670	1,340	**	**

P5001 - COLUMN LOADING

Unbraced Height In	Maximum Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	10,670	39,230	38,030	36,210	34,240
36	10,350	36,450	34,240	31,200	28,260
48	9,940	33,220	30,200	26,430	23,190
60	9,290	29,950	26,430	22,470	19,380
72	8,560	26,880	23,190	19,380	16,450
84	7,860	24,140	20,520	17,040	12,090
96	7,220	21,790	18,370	13,330	9,250
108	6,600	19,790	16,450	10,530	7,310
120	5,760	18,130	13,330	8,530	**
144	4,390	14,020	9,250	**	**
168	3,420	10,300	6,800	**	**

P5000/P5001 - ELEMENTS OF SECTION

Parameter	P5000	P5001
Area of Section	0.897 In <sup>2</sup>	1.793 In <sup>2</sup>
Axis 1-1		
Moment of Inertia (I)	1.098 In <sup>4</sup>	6.227 In <sup>4</sup>
Section Modulus (S)	0.627 In <sup>3</sup>	1.916 In <sup>3</sup>
Radius of Gyration (r)	1.107 In	1.864 In
Axis 2-2		
Moment of Inertia (I)	0.433 In <sup>4</sup>	0.866 In <sup>4</sup>
Section Modulus (S)	0.533 In <sup>3</sup>	1.066 In <sup>3</sup>
Radius of Gyration (r)	0.695 In	0.695 In

Notes:

\* Load limited by spot weld shear.

./ » U !

NR = Not Recommended.

- Beam loads are given as total uniform load (W Lbs) not uniform load (w lbs/ft or w lbs/in).
- Beam loads are based on a simple span and assumed to be adequately laterally braced. Unbraced spans can reduce beam load carrying capacity. Refer to Page 18 for reduction factors for unbraced lengths.
- For pierced channel, multiply beam loads by the following factor:  

"KO" Series.....95%	"T" Series .....85%
"HS" Series .....90%	"SL" Series .....85%
"WT" Series.....85%	
- Deduct channel weight from the beam loads.
- For concentrated midspan point loads, multiply beam loads by 50% and the corresponding deflection by 80%. For other load conditions refer to page 18.
- All beam loads are for bending about Axis 1-1.

1 1/8" Channel  
Telestrut  
Nuts & Hardware  
General Fittings  
Pipe/Conduit Supports  
Electrical Fittings  
Concrete Inserts  
Solar  
Uniper®

P5000

Same as P5000T, except

$L := 40 \cdot \text{in}$  Maximum span

$C_{Unbr} := 0.80$  Unbraced length factor

$C_{Pierce} := 1$  Pierced channel factor

$$M_a := M_{a\_Unfactored} \cdot C_{Unbr} \cdot C_{Pierce} = 12616 \text{ in} \cdot \text{lb}f$$

$$M_R := \frac{T_{R\_Trap} \cdot L}{4} = 12500 \text{ in} \cdot \text{lb}f$$

$$\Delta := \frac{T_{R\_Trap} \cdot L^3}{48 \cdot E \cdot I_x} = 0.05 \text{ in}$$

$$\Delta_{max} := 0.25 \cdot \text{in}$$

$$\text{Design} := \left\| \begin{array}{l} \text{if } M_a > M_R \\ \left\| \begin{array}{l} \text{if } \Delta < \Delta_{max} \\ \left\| \begin{array}{l} \text{“OK”} \\ \text{else} \\ \left\| \begin{array}{l} \text{“NG”} \end{array} \right\| \\ \text{else} \\ \left\| \begin{array}{l} \text{“NG”} \end{array} \right\| \end{array} \right\| \end{array} \right\| = \text{“OK”}$$

**.:Use P5000 for L=40in max**

## P1001

$$M_{a\_Unfactored} := 14360 \text{ in} \cdot \text{lb}f$$

$$I_x := 0.928 \text{ in}^4$$

$$L := 45 \cdot \text{in} \quad \text{Maximum span}$$

$$C_{Unbr} := 1 \quad \text{Unbraced length factor}$$

$$C_{Pierce} := 1 \quad \text{Pierced channel factor}$$

$$M_a := M_{a\_Unfactored} \cdot C_{Unbr} \cdot C_{Pierce} = 14360 \text{ in} \cdot \text{lb}f$$

$$M_R := \frac{T_{R\_Trap} \cdot L}{4} = 14062.5 \text{ in} \cdot \text{lb}f$$

$$\Delta := \frac{T_{R\_Trap} \cdot L^3}{48 \cdot E \cdot I_x} = 0.09 \text{ in}$$

$$\Delta_{max} := 0.25 \cdot \text{in}$$

$$Design := \begin{cases} \text{if } M_a > M_R \\ \quad \text{if } \Delta < \Delta_{max} \\ \quad \quad \text{"OK"} \\ \quad \text{else} \\ \quad \quad \text{"NG"} \\ \text{else} \\ \quad \text{"NG"} \end{cases} = \text{"OK"}$$

**∴ Use P1001 for L=45in max**



1 5/8" Channel

Telestrut

Nuts & Hardware

General Fittings

Pipe/Conduit Supports

Electrical Fittings




Concrete Inserts

Solar

Unipier®

### P1000®




DF GR HG PG PL



Wt/100 Ft: 189 Lbs (281 kg/100 m)  
 Allowable Moment 5,070 In-Lbs (570 NŁm)  
 12 Gauge Nominal Thickness .105" (2.7mm)

### P1001

DF GR HG PG PL



Wt/100 Ft: 378 Lbs (562 kg/100 m)  
 Allowable Moment 14,360 In-Lbs (1,620 NŁm)  
 12 Gauge Nominal Thickness .105" (2.7mm)

### P1000 DS

### P1000 H3

GR HG PG PL


### P1000 HS

GR HG PG PL

### P1000 KO


GR PG

Slots are 2 3/4" (69.9) x 7/8" (22.2)  
 3 1/2" (88.9) on Center




Pipe Clamps can be Mounted on Both S


9/16" (14.3) Dia. Holes  
 1 7/8" (47.6) on Center



9/16" (14.3) Dia. Holes  
 1 7/8" (47.6) on Center



7/8" (22.2) Knockouts  
 6" (152.4) on Center



Wt/100 Ft: 173 Lbs (257 kg/100 m)

Wt/100 Ft: 175 Lbs (260 kg/100 m)

Wt/100 Ft: 190 Lbs (283 kg/100 m)

Wt/100 Ft: 185 Lbs (275 kg/100 m)

### P1000 SL

GR HG PG PL


### P1000 T

DF GR HG PG PL

### P1000 WT


DF GR HG PG PL

Slots are 3" (76.2) x 3/32" (10.3)  
 4" (101.6) on Center




Wt/100 Ft: 185 Lbs (275 kg/100 m)

Slots are 1 1/8" (28.6) x 9/16" (14.3)  
 2" (50.8) on Center



Wt/100 Ft: 185 Lbs (275 kg/100 m)


Slots are 2" (50.8) x 1 1/8" (17.5)  
 3" (76.2) on Center



Wt/100 Ft: 185 Lbs (275 kg/100 m)

### CHANNEL NUTS (REFER TO PAGES 73,74 FOR DETAILS)


SEE PAGE 73, 74



P1006-0832  
 P1006-1024  
 P1006-1420  
 P1007  
 P1008  
 P1009  
 P1010



P1008T  
 P1006T1420  
 P1010T



P1024  
 P1012S  
 P1023S



P3006-0832  
 P3006-1024  
 P3006-1420  
 P3007  
 P3008  
 P3009  
 P3010



P3016-0632  
 P3016-0832  
 P3016-1024  
 P3016-1420



P1012  
 P1023  
 P1024S

Channel Finishes: DF, PL, GR, HG, PG, ZD; Standard Lengths: 10' & 20'

P1000 - BEAM LOADING

Span In	Max. Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	1,690	0.06	1,690	1,690	1,690
36	1,130	0.13	1,130	1,130	900
48	850	0.22	850	760	500
60	680	0.35	650	480	320
72	560	0.50	450	340	220
84	480	0.68	330	250	160
96	420	0.89	250	190	130
108	380	1.14	200	150	100
120	340	1.40	160	120	80
144	280	2.00	110	80	60
168	240	2.72	80	60	40
192	210	3.55	60	50	NR
216	190	4.58	50	40	NR
240	170	5.62	40	NR	NR

P1001 - BEAM LOADING

Span In	Max. Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	3,500*	0.02	3,500*	3,500*	3,500*
36	3,190	0.07	3,190	3,190	3,190
48	2,390	0.13	2,390	2,390	2,390
60	1,910	0.20	1,910	1,910	1,620
72	1,600	0.28	1,600	1,600	1,130
84	1,370	0.39	1,370	1,240	830
96	1,200	0.51	1,200	950	630
108	1,060	0.64	1,000	750	500
120	960	0.79	810	610	410
144	800	1.14	560	420	280
168	680	1.53	410	310	210
192	600	2.02	320	240	160
216	530	2.54	250	190	130
240	480	3.16	200	150	100

P1000 - COLUMN LOADING

Unbraced Height In	Max. Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	3,550	10,740	9,890	8,770	7,740
36	3,190	8,910	7,740	6,390	5,310
48	2,770	7,260	6,010	4,690	3,800
60	2,380	5,910	4,690	3,630	2,960
72	2,080	4,840	3,800	2,960	2,400
84	1,860	4,040	3,200	2,480	1,980
96	1,670	3,480	2,750	2,110	1,660
108	1,510	3,050	2,400	1,810	**
120	1,380	2,700	2,110	**	**
144	1,150	2,180	1,660	**	**

P1001 - COLUMN LOADING

Unbraced Height In	Max. Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	6,430	24,280	23,610	22,700	21,820
36	6,290	22,810	21,820	20,650	19,670
48	6,160	21,410	20,300	18,670	16,160
60	6,000	20,210	18,670	15,520	12,390
72	5,620	18,970	16,160	12,390	8,950
84	5,170	16,950	13,630	9,470	6,580
96	4,690	14,890	11,190	7,250	5,040
108	4,170	12,850	8,950	5,730	3,980
120	3,690	10,900	7,250	4,640	**
144	2,930	7,630	5,040	**	**

P1000/P1001 - ELEMENTS OF SECTION

Parameter	P1000	P1001
Area of Section	0.555 In <sup>2</sup>	1.111 In <sup>2</sup>
Axis 1-1		
Moment of Inertia (I)	0.185 In <sup>4</sup>	0.928 In <sup>4</sup>
Section Modulus (S)	0.202 In <sup>3</sup>	0.571 In <sup>3</sup>
Radius of Gyration (r)	0.577 In	0.914 In
Axis 2-2		
Moment of Inertia (I)	0.236 In <sup>4</sup>	0.471 In <sup>4</sup>
Section Modulus (S)	0.290 In <sup>3</sup>	0.580 In <sup>3</sup>
Radius of Gyration (r)	0.651 In	0.651 In

Notes:

\* Load limited by spot weld shear.

. / » U !

NR = Not Recommended.

- Beam loads are given as total uniform load (W Lbs) not uniform load (w lbs/ft or w lbs/in).
- Beam loads are based on a simple span and assumed to be adequately laterally braced. Unbraced spans can reduce beam load carrying capacity. Refer to Page 18 for reduction factors for unbraced lengths.
- For pierced channel, multiply beam loads by the following factor:
 

"KO" Series.....95%	"T" Series.....85%
"HS" Series.....90%	"SL" Series.....85%
"H3" Series.....90%	"DS" Series.....70%
"WT" Series.....85%	
- Deduct channel weight from the beam loads.
- For concentrated midspan point loads, multiply beam loads by 50% and the corresponding deflection by 80%. For other load conditions refer to page 18.
- All beam loads are for bending about Axis 1-1.

1 1/8" Channel  
Telestrut  
Nuts & Hardware  
General Fittings  
Pipe/Conduit Supports  
Electrical Fittings  
Concrete Inserts  
Solar  
Unipipe®

P5501

$$M_{a\_Unfactored} := 28940 \text{ in} \cdot \text{lb}f$$

$$I_x := 2.805 \text{ in}^4$$

$$L := 77 \cdot \text{in} \quad \text{Maximum span}$$

$$C_{Unbr} := 0.85 \quad \text{Unbraced length factor}$$

$$C_{Pierce} := 1 \quad \text{Pierced channel factor}$$

$$M_a := M_{a\_Unfactored} \cdot C_{Unbr} \cdot C_{Pierce} = 24599 \text{ in} \cdot \text{lb}f$$

$$M_R := \frac{T_{R\_Trap} \cdot L}{4} = 24062.5 \text{ in} \cdot \text{lb}f$$

$$\Delta := \frac{T_{R\_Trap} \cdot L^3}{48 \cdot E \cdot I_x} = 0.15 \text{ in}$$




$$\Delta_{max} := 0.25 \cdot \text{in}$$

$$Design := \begin{cases} \text{if } M_a > M_R \\ \quad \text{if } \Delta < \Delta_{max} \\ \quad \quad \text{"OK"} \\ \quad \text{else} \\ \quad \quad \text{"NG"} \\ \text{else} \\ \quad \text{"NG"} \end{cases} = \text{"OK"}$$

**∴ Use P5501 for L=77in max**

P5500




GR PG



Wt/100 Ft: 247 Lbs (367 kg/100 m)  
 Allowable Moment 9,820 In-Lbs (1,110 NLM)  
 12 Gauge Nominal Thickness .105" (2.7mm)

P5501

GR PG



Wt/100 Ft: 404 Lbs (734 kg/100 m)  
 Allowable Moment 28,940 In-Lbs (3,270 NLM)  
 12 Gauge Nominal Thickness .105" (2.7mm)

P5500 HS

GR PG


P5500 KO

GR PG

P5500 SL


GR PG

9/16" (14.3) Dia. Holes  
 1 7/8" (47.6) on Center




Wt/100 Ft: 242 Lbs (360 kg/100 m)

7/8" (22.2) Knockouts  
 6" (152.4) on Center



Wt/100 Ft: 247 Lbs (368 kg/100 m)

Slots are  
 3" (76.2) x 1 3/32" (10.3)  
 4" (101.6) on Center



Wt/100 Ft: 242 Lbs (360 kg/100 m)


P5500 T

GR PG

P5500 WT


DF GR HG PG PL

Slots are  
 1 1/8" (28.6) x 9/16" (14.3)  
 2" (50.8) on Center



Wt/100 Ft: 242 Lbs (360 kg/100 m)


Slots are  
 2" (50.8) x 1 1/8" (17.5)  
 3" (76.2) on Center



Wt/100 Ft: 242 Lbs (360 kg/100 m)

CHANNEL NUTS (REFER TO PAGES 73,74 FOR DETAILS)

SEE PAGE 73, 74



P5506-0832  
 P5506-1024  
 P5506-1420  
 P5507  
 P5508  
 P5509  
 P5510



P1006T1420  
 P1008T  
 P1010T



P1012  
 P1023  
 P1024



P3006-0832  
 P3006-1024  
 P3006-1420  
 P3007  
 P3008  
 P3009  
 P3010



P3016-0632  
 P3016-0832  
 P3016-1024  
 P3016-1420

Channel Finishes: PL, GR, HG, PG, ZD; Standard Lengths: 10' & 20'



1 1/8" Channel

Telestrut

Nuts & Hardware

General Fittings

Pipe/Conduit Supports

Electrical Fittings

Concrete Inserts

Solar

Unipier®

### P5500 - BEAM LOADING

Span In	Max Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	3,270	0.04	3,270	3,270	3,270
36	2,180	0.09	2,180	2,180	2,180
48	1,640	0.15	1,640	1,640	1,420
60	1,310	0.24	1,310	1,310	910
72	1,090	0.34	1,090	950	630
84	940	0.47	930	700	470
96	820	0.61	710	530	360
108	730	0.78	560	420	280
120	650	0.95	460	340	230
144	550	1.39	320	240	160
168	470	1.89	230	170	120
192	410	2.46	180	130	90
216	360	3.07	140	110	70
240	330	3.86	110	90	60

### P5501 - BEAM LOADING

Span In	Max Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	5,220*	0.01	5,220*	5,220*	5,220*
36	5,220*	0.04	5,220*	5,220*	5,220*
48	4,820	0.08	4,820	4,820	4,820
60	3,860	0.13	3,860	3,860	3,860
72	3,220	0.19	3,220	3,220	3,220
84	2,760	0.26	2,760	2,760	2,500
96	2,410	0.34	2,410	2,410	1,920
108	2,140	0.42	2,140	2,140	1,510
120	1,930	0.52	1,930	1,840	1,230
144	1,610	0.76	1,610	1,280	850
168	1,380	1.03	1,250	940	630
192	1,210	1.35	960	720	480
216	1,070	1.70	760	570	380
240	960	2.09	610	460	310

### P5500 - COLUMN LOADING

Unbraced Height In	Maximum Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	4,640	13,840	12,570	10,840	9,190
36	3,970	11,050	9,190	7,030	5,370
48	3,180	8,420	6,390	4,620	3,630
60	2,550	6,250	4,620	3,450	2,780
72	2,120	4,790	3,630	2,780	2,260
84	1,810	3,890	3,010	2,330	1,910
96	1,580	3,290	2,580	2,020	1,650
108	1,400	2,860	2,260	1,770	1,440
120	1,270	2,530	2,020	1,580	**
144	1,060	2,070	1,650	**	**
168	920	1,750	1,380	**	**

### P5501 - COLUMN LOADING

Unbraced Height In	Maximum Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	8,580	31,810	30,880	29,520	28,100
36	8,350	29,700	28,100	26,000	24,070
48	8,080	27,390	25,330	22,910	20,940
60	7,720	25,170	22,910	20,510	17,170
72	7,270	23,190	20,940	17,170	12,700
84	6,780	21,510	18,740	13,430	9,330
96	6,130	20,110	15,630	10,290	7,150
108	5,450	17,750	12,700	8,130	5,650
120	4,800	15,260	10,290	6,590	**
144	3,760	10,830	7,150	**	**
168	2,970	7,950	5,250	**	**

### P5500/P5501 - ELEMENTS OF SECTION

Parameter	P5500	P5501
Area of Section	0.726 In <sup>2</sup>	1.452 In <sup>2</sup>
Axis 1-1		
Moment of Inertia (I)	0.522 In <sup>4</sup>	2.805 In <sup>4</sup>
Section Modulus (S)	0.330 In <sup>3</sup>	1.151 In <sup>3</sup>
Radius of Gyration (r)	0.848 In	1.390 In
Axis 2-2		
Moment of Inertia (I)	0.334 In <sup>4</sup>	0.669 In <sup>4</sup>
Section Modulus (S)	0.411 In <sup>3</sup>	0.823 In <sup>3</sup>
Radius of Gyration (r)	0.679 In	0.679 In

Notes:

\* Load limited by spot weld shear.

. / » U !

NR = Not Recommended.

- Beam loads are given as total uniform load (W Lbs) not uniform load (w lbs/ft or w lbs/in).
- Beam loads are based on a simple span and assumed to be adequately laterally braced. Unbraced spans can reduce beam load carrying capacity. Refer to Page 62 for reduction factors for unbraced lengths.
- For pierced channel, multiply beam loads by the following factor:  

"KO" Series.....95%	"T" Series .....85%
"HS" Series .....90%	"SL" Series .....85%
"WT" Series.....85%	
- Deduct channel weight from the beam loads.
- For concentrated midspan point loads, multiply beam loads by 50% and the corresponding deflection by 80%. For other load conditions refer to page 18.
- All beam loads are for bending about Axis 1-1.



P5001

$$M_{a\_Unfactored} := 48180 \text{ in} \cdot \text{lb}$$

$$I_x := 6.227 \text{ in}^4$$

$L := 100 \cdot \text{in}$  Maximum span

$C_{Unbr} := 0.66$  Unbraced length factor

$C_{Pierce} := 1$  Pierced channel factor

$$M_a := M_{a\_Unfactored} \cdot C_{Unbr} \cdot C_{Pierce} = 31798.8 \text{ in} \cdot \text{lb}$$

$$M_R := \frac{T_{R\_Trap} \cdot L}{4} = 31250 \text{ in} \cdot \text{lb}$$

$$\Delta := \frac{T_{R\_Trap} \cdot L^3}{48 \cdot E \cdot I_x} = 0.14 \text{ in}$$

$$\Delta_{max} := 0.25 \cdot \text{in}$$

$$Design := \begin{cases} \text{if } M_a > M_R & \text{=} \text{"OK"} \\ \text{if } \Delta < \Delta_{max} & \text{"OK"} \\ \text{else} & \text{"NG"} \\ \text{else} & \text{"NG"} \end{cases}$$

**∴ Use P5001 for L=100in max**



1 5/8" Channel

Telestrut

Nuts & Hardware

General Fittings

Pipe/Conduit Supports

Electrical Fittings



Concrete Inserts

Solar

Unipier®

### P5000



DF GR PL PG



Wt/100 Ft: 305 Lbs (454 kg/100 m)  
 Allowable Moment 15,770 In-Lbs (1,780 NŁm)  
 12 Gauge Nominal Thickness .105" (2.7mm)

### P5001

DF GR PG



Wt/100 Ft: 610 Lbs (907 kg/100 m)  
 Allowable Moment 48,180 In-Lbs (5,440 NŁm)  
 12 Gauge Nominal Thickness .105" (2.7mm)


### P5000 HS

GR PG


### P5000 KO

GR PG

9/16" (14.3) Dia. Holes  
 1 7/8" (47.6) on Center



7/8" (22.2) Knockouts  
 6" (152.4) on Center



Wt/100 Ft: 300 Lbs (446 kg/100 m)

Wt/100 Ft: 305 Lbs (454 kg/100 m)

### P5000 SL

GR PG


### P5000 T

DF GR PG


### P5000 WT

DF GR HG PG PL


Slots are  
 3" (76.2) x 3/32" (10.3)  
 4" (101.6) on Center



Slots are  
 1 1/8" (28.6) x 9/16" (14.3)  
 2" (50.8) on Center



Slots are  
 2" (50.8) x 1 1/8" (17.5)  
 3" (76.2) on Center




Wt/100 Ft: 300 Lbs (446 kg/100 m)

Wt/100 Ft: 300 Lbs (446 kg/100 m)

Wt/100 Ft: 300 Lbs (446 kg/100 m)

### CHANNEL NUTS (REFER TO PAGES 73,74 FOR DETAILS)

SEE PAGE 73, 74



**P5506-0832**  
**P5506-1024**  
**P5506-1420**  
**P5507**  
**P5508**  
**P5509**  
**P5510**



**P1006T-1420**  
**P1008T**  
**P1010T**



**P1012**  
**P1023**  
**P1024**



**P3006-0832**  
**P3006-1024**  
**P3006-1420**  
**P3007**  
**P3008**  
**P3009**  
**P3010**



**P3016-0632**  
**P3016-0832**  
**P3016-1024**  
**P3016-1420**

Channel Finishes: DF, PL, GR, HG, PG, ZD; Standard Lengths: 10' & 20'

P5000 - BEAM LOADING

Span In	Max Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	5,260	0.03	5,260	5,260	5,260
36	3,500	0.07	3,500	3,500	3,500
48	2,630	0.12	2,630	2,630	2,630
60	2,100	0.18	2,100	2,100	1,920
72	1,750	0.26	1,750	1,750	1,330
84	1,500	0.36	1,500	1,470	980
96	1,310	0.47	1,310	1,120	750
108	1,170	0.59	1,170	890	590
120	1,050	0.73	960	720	480
144	880	1.06	670	500	330
168	750	1.43	490	370	240
192	660	1.88	370	280	190
216	580	2.35	300	220	150
240	530	2.95	240	180	120

P5001 - BEAM LOADING

Span In	Max Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	6,890*	0.01	6,890*	6,890*	6,890*
36	6,890*	0.02	6,890*	6,890*	6,890*
48	6,890*	0.05	6,890*	6,890*	6,890*
60	6,420	0.10	6,420	6,420	6,420
72	5,350	0.14	5,350	5,350	5,350
84	4,590	0.19	4,590	4,590	4,590
96	4,020	0.25	4,020	4,020	4,020
108	3,570	0.32	3,570	3,570	3,360
120	3,210	0.39	3,210	3,210	2,720
144	2,680	0.57	2,680	2,680	1,890
168	2,290	0.77	2,290	2,080	1,390
192	2,010	1.01	2,010	1,590	1,060
216	1,780	1.27	1,680	1,260	840
240	1,610	1.58	1,360	1,020	680

P5000 - COLUMN LOADING

Unbraced Height In	Maximum Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	5,650	16,870	15,180	12,850	10,600
36	4,690	13,140	10,600	7,650	5,660
48	3,560	9,550	6,860	4,790	3,660
60	2,730	6,680	4,790	3,450	2,710
72	2,160	4,980	3,660	2,710	2,170
84	1,760	3,950	2,960	2,240	1,820
96	1,500	3,270	2,500	1,930	1,580
108	1,310	2,800	2,170	1,690	1,390
120	1,170	2,450	1,930	1,510	**
144	980	1,980	1,580	**	**
168	850	1,670	1,340	**	**

P5001 - COLUMN LOADING

Unbraced Height In	Maximum Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	10,670	39,230	38,030	36,210	34,240
36	10,350	36,450	34,240	31,200	28,260
48	9,940	33,220	30,200	26,430	23,190
60	9,290	29,950	26,430	22,470	19,380
72	8,560	26,880	23,190	19,380	16,450
84	7,860	24,140	20,520	17,040	12,090
96	7,220	21,790	18,370	13,330	9,250
108	6,600	19,790	16,450	10,530	7,310
120	5,760	18,130	13,330	8,530	**
144	4,390	14,020	9,250	**	**
168	3,420	10,300	6,800	**	**

P5000/P5001 - ELEMENTS OF SECTION

Parameter	P5000		P5001	
Area of Section	0.897	In <sup>2</sup>	1.793	In <sup>2</sup>
Axis 1-1				
Moment of Inertia (I)	1.098	In <sup>4</sup>	6.227	In <sup>4</sup>
Section Modulus (S)	0.627	In <sup>3</sup>	1.916	In <sup>3</sup>
Radius of Gyration (r)	1.107	In	1.864	In
Axis 2-2				
Moment of Inertia (I)	0.433	In <sup>4</sup>	0.866	In <sup>4</sup>
Section Modulus (S)	0.533	In <sup>3</sup>	1.066	In <sup>3</sup>
Radius of Gyration (r)	0.695	In	0.695	In

Notes:

\* Load limited by spot weld shear.

./ » U !

NR = Not Recommended.

- Beam loads are given as total uniform load (W Lbs) not uniform load (w lbs/ft or w lbs/in).
- Beam loads are based on a simple span and assumed to be adequately laterally braced. Unbraced spans can reduce beam load carrying capacity. Refer to Page 18 for reduction factors for unbraced lengths.
- For pierced channel, multiply beam loads by the following factor:  

"KO" Series.....95%	"T" Series .....85%
"HS" Series .....90%	"SL" Series .....85%
"WT" Series.....85%	
- Deduct channel weight from the beam loads.
- For concentrated midspan point loads, multiply beam loads by 50% and the corresponding deflection by 80%. For other load conditions refer to page 18.
- All beam loads are for bending about Axis 1-1.

1 1/8" Channel  
Telestrut  
Nuts & Hardware  
General Fittings  
Pipe/Conduit Supports  
Electrical Fittings  
Concrete Inserts  
Solar  
Uniper®

## Brace

Load in tension/compression

$$P_{R1} := \frac{0.7 \cdot F_p}{\cos\left(\frac{60 \cdot \pi}{180}\right) \cdot 2} = 24.7 \text{ lbf}$$

$$P_{R2} := \frac{V_{Trans}}{\cos\left(\frac{60 \cdot \pi}{180}\right) \cdot 2} = 210 \text{ lbf}$$

$$P_R := \max(P_{R1}, P_{R2}) = 210 \text{ lbf}$$

Check capacity at min brace angle = 30° as worst case


Try Unistrut P1000 for  $L = (3.08\text{ft}) / \tan(30) = 7.3\text{ft} \Rightarrow$  use 6ft

Per Unistrut

$$P_a := 2080 \text{ lbf}$$

$$Design := \begin{cases} \text{if } P_a > P_R \\ \text{“OK”} \\ \text{else} \\ \text{“NG”} \end{cases} = \text{“OK”}$$

∴ Use P1000 brace



P1000 - BEAM LOADING

Span In	Max. Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	1,690	0.06	1,690	1,690	1,690
36	1,130	0.13	1,130	1,130	900
48	850	0.22	850	760	500
60	680	0.35	650	480	320
72	560	0.50	450	340	220
84	480	0.68	330	250	160
96	420	0.89	250	190	130
108	380	1.14	200	150	100
120	340	1.40	160	120	80
144	280	2.00	110	80	60
168	240	2.72	80	60	40
192	210	3.55	60	50	NR
216	190	4.58	50	40	NR
240	170	5.62	40	NR	NR

P1001 - BEAM LOADING

Span In	Max. Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	3,500*	0.02	3,500*	3,500*	3,500*
36	3,190	0.07	3,190	3,190	3,190
48	2,390	0.13	2,390	2,390	2,390
60	1,910	0.20	1,910	1,910	1,620
72	1,600	0.28	1,600	1,600	1,130
84	1,370	0.39	1,370	1,240	830
96	1,200	0.51	1,200	950	630
108	1,060	0.64	1,000	750	500
120	960	0.79	810	610	410
144	800	1.14	560	420	280
168	680	1.53	410	310	210
192	600	2.02	320	240	160
216	530	2.54	250	190	130
240	480	3.16	200	150	100

P1000 - COLUMN LOADING

Unbraced Height In	Max. Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	3,550	10,740	9,890	8,770	7,740
36	3,190	8,910	7,740	6,390	5,310
48	2,770	7,260	6,010	4,690	3,800
60	2,380	5,910	4,690	3,630	2,960
72	2,080	4,840	3,800	2,960	2,400
84	1,860	4,040	3,200	2,480	1,980
96	1,670	3,480	2,750	2,110	1,660
108	1,510	3,050	2,400	1,810	**
120	1,380	2,700	2,110	**	**
144	1,150	2,180	1,660	**	**

P1001 - COLUMN LOADING

Unbraced Height In	Max. Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	6,430	24,280	23,610	22,700	21,820
36	6,290	22,810	21,820	20,650	19,670
48	6,160	21,410	20,300	18,670	16,160
60	6,000	20,210	18,670	15,520	12,390
72	5,620	18,970	16,160	12,390	8,950
84	5,170	16,950	13,630	9,470	6,580
96	4,690	14,890	11,190	7,250	5,040
108	4,170	12,850	8,950	5,730	3,980
120	3,690	10,900	7,250	4,640	**
144	2,930	7,630	5,040	**	**

P1000/P1001 - ELEMENTS OF SECTION

Parameter	P1000		P1001	
Area of Section	0.555	In <sup>2</sup>	1.111	In <sup>2</sup>
Axis 1-1				
Moment of Inertia (I)	0.185	In <sup>4</sup>	0.928	In <sup>4</sup>
Section Modulus (S)	0.202	In <sup>3</sup>	0.571	In <sup>3</sup>
Radius of Gyration (r)	0.577	In	0.914	In
Axis 2-2				
Moment of Inertia (I)	0.236	In <sup>4</sup>	0.471	In <sup>4</sup>
Section Modulus (S)	0.290	In <sup>3</sup>	0.580	In <sup>3</sup>
Radius of Gyration (r)	0.651	In	0.651	In

Notes:

\* Load limited by spot weld shear.

\*\* KL/r > 200

NR = Not Recommended.

- Beam loads are given in total uniform load (W Lbs) not uniform load (w lbs/ft or w lbs/in).
- Beam loads are based on a simple span and assumed to be adequately laterally braced. Unbraced spans can reduce beam load carrying capacity. Refer to Page 62 for reduction factors for unbraced lengths.
- For pierced channel, multiply beam loads by the following factor:  

"KO" Series.....95%	"T" Series .....85%
"HS" Series .....90%	"SL" Series .....85%
"H3" Series.....90%	"DS" Series.....70%
"WT" Series.....85%	
- Deduct channel weight from the beam loads.
- For concentrated midspan point loads, multiply beam loads by 50% and the corresponding deflection by 80%. For other load conditions refer to page 18.
- All beam loads are for bending about Axis 1-1.

1 1/8" Channel  
Telestrut  
Nuts & Hardware  
General Fittings  
Pipe/Conduit Supports  
Electrical Fittings  
Concrete Inserts  
Solar  
Unipier®

Check brace anchorage

$$V_R := P_R = 210 \text{ lbf}$$


Try Unistrut channel nut to brace

Per Unistrut

$$V_a := 800 \text{ lbf}$$

$$Design := \begin{cases} \text{if } V_a > V_R \\ \quad \begin{cases} \text{“OK”} \\ \text{else} \\ \text{“NG”} \end{cases} \end{cases} = \text{“OK”}$$

∴ Use Unistrut channel nut





1 5/8" Channel

Telestrut

Nuts & Hardware

General Fittings

Pipe/Conduit Supports


Electrical Fittings

Concrete Inserts


Solar

Unipier®

### Channel Nuts With Spring



P1006 - P1010  
Pg 73




P1012S - P1024S  
Pg 73



P4006 - P4010  
Pg 73



P5506 - P5510  
Pg 73



P2378 - P2382  
Pg 74

### Channel Nuts Without Spring



P3016  
Pg 73



P3006 - P3013  
Pg 73




P1012 - P1024  
Pg 73



P4012 - P4023  
Pg 73



P1006T - P1010T, P4010T  
Pg 73



P4908  
Pg 73



P1016  
Pg 73

### Hardware



HHCS  
Pg 74



HFMS  
Pg 74



HRMS  
Pg 74



HSHS  
Pg 74



HCSS  
Pg 74



HSQN  
Pg 75




HHXN  
Pg 75




HFLW  
Pg 75



HLKW  
Pg 75



HOCW  
Pg 76



HTHR  
Pg 75



HRCN  
Pg 75




P2486  
Pg 76



P2485  
Pg 76



P2485K  
Pg 76



K1062 - K1064  
Pg 76

### MAXIMUM ALLOWABLE PULL-OUT AND SLIP LOADS

Channel	Channel Nut Size-Thread	Gauge	Allowable Pull-Out Strength Lbs (kN)	Resistance to Slip Lbs (kN)	Torque Ft-Lbs (N·m)
P1000 P3000 P4400 P4526 P5000 P5500	3/8" - 9	12	2,500	1,700	*125
			11.12	7.56	170
	3/4" - 10	12	2,500	1,700	*125
			11.12	7.56	170
	5/8" - 11	12	2,500	1,500	*100
			11.12	6.67	135
	1/2" - 13	12	2,000	1,500	50
			8.90	6.67	70
P3300	1/2" - 13	12	1,500	1,500	50
			6.67	6.67	70
	3/8" - 16	12	1,000	800	19
			4.45	3.56	25
5/16" - 18	12	800	500	11	
		3.56	2.22	15	
1/4" - 20	12	600	300	6	
		2.67	1.33	8	

Channel	Channel Nut Size-Thread	Gauge	Allowable Pull-Out Strength Lbs (kN)	Resistance to Slip Lbs (kN)	Torque Ft-Lbs (N·m)
P1100 & P4100	1/2" - 13	14	1,400	1,000	50
			6.23	4.45	70
	3/8" - 16	14	1,000	750	19
			4.45	3.34	25
P2000 & P4000	5/16" - 18	14	800	400	11
			3.56	1.78	15
	1/4" - 20	14	600	300	6
			2.67	1.33	8
P2000 & P4000	1/2" - 13	16	1,000	1,000	50
			4.45	4.54	70
	3/8" - 16	16	1,000	750	19
			4.45	3.34	25
5/16" - 18	16	800	400	11	
		3.56	1.78	15	
1/4" - 20	16	600	300	6	
		2.67	1.33	8	

\* May require 3/8" or 1/2" thick fitting.

Nut design loads include a minimum safety factor of 3.

Note: Refer to the Channel Nut Selection Chart on the following two pages for the part number.


Try (1) 1/2" dia. Hilti KB-TZ to concrete deck

$$V_{U1} := \frac{F_p \cdot \Omega_o}{2} = 44.2 \text{ lbf}$$

$$V_{U2} := \frac{1.6 \cdot V_{Trans}}{2} = 168 \text{ lbf}$$

$$V_U := \max(V_{U1}, V_{U2}) = 168 \text{ lbf}$$

$$T_U := V_U \cdot \tan\left(\frac{60 \cdot \pi}{180}\right) = 291 \text{ lbf}$$



1/2" dia. Hilti KB-TZ2 ok by inspection due to lower tension load than threaded rod hanger

∴ Use (1) 1/2" dia. Hilti KB-TZ (2" embed min)



(E) FLOOR FRAMING

CONFIRM (E) FLOOR FRAMING CAN SUPPORT CEILING LIFTS

LOADS

$$P_D = 150 \text{pcf} \left( \frac{10 \text{ in}}{12} \right) + 10 + 20 \text{ psf} = 155 \text{ psf}$$

SUPERIMPOSED DL  
 PARTITION PER UBC

$$P_L = \begin{cases} 50 \text{ psf AT ORIG BLDG} \\ 80 \text{ psf AT ADDN} \end{cases}$$

$$P_D = 50 \#$$

$$P_L = \begin{cases} 1000 \# \text{ TYPICAL} \\ 700 \# \text{ LIFT \#41} \end{cases} \text{ CEILING LIFT}$$

AT REHAB GYM

IN E/W

EXISTING

$$V_u = \begin{cases} 21.91 \text{ K SPAN 3, TYP} \\ 18.84 \text{ K SPAN 4, TYP} \end{cases}$$

$$M_u = \begin{cases} 58.30 \text{ 'K} \\ 37.27 \text{ 'K} \end{cases}$$

**Kaplan/  
McLaughlin/  
Diaz**

ARCHITECTS/PLANNERS  
222 VALLEJO STREET  
SAN FRANCISCO 94111  
415-398-5191

**BJSS**

ARCHITECTS/PLANNERS  
320 WEST BAY DRIVE  
OLYMPIA, WASHINGTON  
206-943-4650

STRUCTURAL ENGINEERS  
HAROLD V. SARGENT & ASSOC  
320 WEST BAY DRIVE  
SUITE 218  
OLYMPIA, WA. 98502  
206-943-3590

MECHANICAL ENGINEERS  
BENJAMIN S. NOTKIN &  
ASSOCIATES, INC.  
820 JOHN STREET  
SEATTLE, WA. 98109  
206-682-3611

ELECTRICAL ENGINEERS  
SPARLING & ASSOC., INC.  
1920 EASTLAKE AVE EAST  
SEATTLE, WA. 98102  
206-325-7770

**GOOD  
SAMARITAN  
HOSPITAL**

Puyallup, Washington


SHEET TITLE  
LEVEL 1 FLAT SLAB PLAN



REVISIONS  
NO. DATE DESCRIPTION

SCALE NOTED DATE SEPT 5, 1980

SHEET **S-14**




**NOTES:**  
**SLAB PLACING SEQUENCE**  
 1. PLACE N-S BOTTOM BARS IN COLUMN & MIDDLE STRIPS.  
 2. PLACE E-W BOTTOM BARS IN COLUMN & MIDDLE STRIPS.  
 3. PLACE N-S TOP BARS IN COLUMN STRIPS.  
 4. PLACE E-W TOP BARS IN COLUMN STRIPS.  
 5. PLACE N-S MIDDLE STRIP TOP BARS.  
 6. PLACE E-W MIDDLE STRIP TOP BARS.  
**CODES:**  
 B = BOTTOM  
 T = TOP  
 a = 5'x5' OVER COLUMN  
 b = 7'x7' OVER COLUMN  
 c = 7'x5' OVER COLUMN  
 d = 5'x5' OVER COLUMN

**NOTE:**  
 MINIMUM REINFORCING SHALL BE 10#5 @ 18" ON CENTER FOR CHASE, NEWS & PARAPET WALLS. SEE SHEET S-5.

**LEVEL 1 FLAT SLAB PLAN**

**NOTE:**  
 ALL SLAB REINFORCING SHALL BE GRADE 60



Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** PT Gym - E/W Existing 1000#

### General Beam Properties

Elastic Modulus	29,000.0 ksi		
<b>Span #1</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup>
<b>Span #2</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup>
<b>Span #3</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup>
<b>Span #4</b>	Span Length =	17.750 ft	Area = 10.0 in <sup>2</sup>
			Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

### DESIGN SUMMARY

<b>Maximum Bending =</b>	99.854 k-ft	<b>Maximum Shear =</b>	21.907 k
Load Combination: 1.0L+0.50S+1.60H, LL Comb Run (L*L*)		Load Combination: 1.0L+0.50S+1.60H, LL Comb Run (*LL*)	
Span # where maximum occurs	Span # 1	Span # where maximum occurs	Span # 2
Location of maximum on span	0.000 ft	Location of maximum on span	26.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	1.343 in		232
Max Upward Transient Deflection	-0.345 in		904
Max Downward Total Deflection	1.343 in		232
Max Upward Total Deflection	-0.114 in		1869


**General Beam Analysis**

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** PT Gym - E/W Existing 1000#



- +1.4DD+1.6DH
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LL\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LLL\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LLLL)



- +1.4DD+1.6DH
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LL\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LLL\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LLLL)

**General Beam Analysis**


Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27

PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** PT Gym - E/W Existing 1000#



New

$$V_u = \left\{ \begin{array}{l} 20.71k \text{ SPAN 3, TYP} \approx 5.5\% \text{ DECREASE} \therefore \text{OK} \\ \text{NOTE: USE 75\% OF LL AT FLOOR ABOVE FOR SPAN 3 ANALYSIS BECAUSE FULL LL PLUS FULL CEILING LIFT LOADINGS IS UNLIKELY} \\ 20.04k \text{ SPAN 4, TYP} \approx 6.4\% \text{ INCREASE} > 5\% \therefore \text{CHECK BY HAND} \end{array} \right.$$

$$M_u = \left\{ \begin{array}{l} 56.67 \text{ k-ft} \approx 2.8\% \text{ DECREASE} \therefore \text{OK} \\ 40.48 \text{ k-ft} \approx 8.6\% \text{ INCREASE} > 5\% \therefore \text{CHECK BY HAND} \end{array} \right.$$

CHECK SHEAR IN SPAN 4, ASSUME 6' WIDTH ENGAGED

$$\phi V_n = \phi 2\lambda \sqrt{f'_c} b_w d$$

WHERE  $\phi = 0.75$

$$f'_c = 4000 \text{ psi PER CR16 DWGS}$$

$$b_w = 72 \text{ in}$$

$$d = 10 - \underset{\substack{\uparrow \\ \text{COVER}}}{\frac{3}{4}} - 1.5 \underset{\substack{\uparrow \\ \text{#5}}}{(5/8 \text{ in})} = 8.31 \text{ in}$$

$$\begin{aligned} \therefore \phi V_n &= 0.75 (2(1) \sqrt{4000 \text{ psi}}) (72 \text{ in}) (8.31 \text{ in}) \\ &= 56.76k > V_u \therefore \text{OK} \end{aligned}$$

Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** PT Gym - E/W New 1000# Span 3

### General Beam Properties

Elastic Modulus	29,000.0 ksi		
<b>Span #1</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup>
<b>Span #2</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup>
<b>Span #3</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup>
<b>Span #4</b>	Span Length =	17.750 ft	Area = 10.0 in <sup>2</sup>
			Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.0380 k/ft. Tributary Width = 6.0 ft

Load(s) for Span Number 3

Point Load : D = 0.050, L = 1.0 k @ 17.417 ft



*0.75\*50psf*

### DESIGN SUMMARY

<b>Maximum Bending =</b>	93.011 k-ft	<b>Maximum Shear =</b>	20.711 k
Load Combination = 1.60L+0.50S+1.60H, LL Comb Run (*LL*)		Load Combination = 1.60L+0.50S+1.60H, LL Comb Run (*LL*)	
Span # where maximum occurs	Span # 2	Span # where maximum occurs	Span # 2
Location of maximum on span	26.000 ft	Location of maximum on span	26.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	1.304 in		239
Max Upward Transient Deflection	-0.288 in		1081
Max Downward Total Deflection	1.304 in		239
Max Upward Total Deflection	-0.110 in		1939

**General Beam Analysis**

**DESCRIPTION: PT Gym - E/W New 1000# Span 3**







Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** PT Gym - E/W New 1000# Span 4

### General Beam Properties

Elastic Modulus	29,000.0 ksi		
<b>Span #1</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup>
<b>Span #2</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup>
<b>Span #3</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup>
<b>Span #4</b>	Span Length =	17.750 ft	Area = 10.0 in <sup>2</sup>
			Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

Load(s) for Span Number 4


Point Load : D = 0.050, L = 1.0 k @ 6.417 ft

### DESIGN SUMMARY


<b>Maximum Bending =</b>	99.850 k-ft	<b>Maximum Shear =</b>	21.902 k
Load Combination = 1.60L+0.50S+1.60H, LL Comb Run (L*L*)		Load Combination = 1.60L+0.50S+1.60H, LL Comb Run (*LL*)	
Span # where maximum occurs	Span # 1	Span # where maximum occurs	Span # 2
Location of maximum on span	0.000 ft	Location of maximum on span	26.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	1.341 in	232	
Max Upward Transient Deflection	-0.345 in	904	
Max Downward Total Deflection	1.341 in	232	
Max Upward Total Deflection	-0.113 in	1889	

**General Beam Analysis**

**DESCRIPTION: PT Gym - E/W New 1000# Span 4**



- +1.40D+1.60H
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*\*LL)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*L\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*L\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*LL\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*LLL)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*L\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*LL)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LL\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LL\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LLL\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LLLL)



- +1.40D+1.60H
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*\*LL)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*L\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*L\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*LL\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*LLL)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*L\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*LL)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LL\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LL\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LLL\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LLLL)

**General Beam Analysis**


Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27

PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION: PT Gym - E/W New 1000# Span 4**



CHECK FLEXURE IN SPAN 4, ASSUME 6' WIDTH ENGRADED

$$\phi M_n = \phi A_s f_y (d - a/2)$$

WHERE  $\phi = 0.9$

$$A_s = 0.31 \text{ m}^2 (10 \text{ BARS} / 13 \text{ FT}) (6 \text{ FT}) = 1.43 \text{ m}^2$$

$$f_y = 60 \text{ ksi PER DRAWINGS}$$

$$d = 8.31 \text{ m}$$

$$a = \frac{1.43 \text{ m}^2 (60 \text{ ksi})}{0.85 (4 \text{ ksi}) (72 \text{ m})} = 0.31 \text{ m}$$

$$\begin{aligned} \therefore \phi M_n &= 0.9 (1.43 \text{ m}^2) (60 \text{ ksi}) (8.31 - 0.31 \text{ m} / 2) \\ &= 628.2 \text{ ''-K} = 52.35 \text{ ' -K} > M_u \text{ : OK} \end{aligned}$$

∴ (E) SLAB OK IN E/W

IN N/S

EXISTING

$$V_u = 20.83k$$

$$M_u = 53.20^{1-k}$$

NEW

$$V_u = 22.44k \approx 7.7\% \text{ INCREASE} > 5\% \therefore \text{CHECK BY HAND}$$

$$M_u = 55.86^{1-k} \approx 5.0\% \text{ INCREASE} \therefore \text{OK}$$

CHECK SHEAR

$$\text{FROM PREV. CALCS, } \phi V_n = 56.76k > V_u \therefore \text{OK}$$

\therefore (E) SLAB OK IN N/S

Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** PT Gym - N/S Existing 1000#

### General Beam Properties

Elastic Modulus	29,000.0 ksi		
<b>Span #1</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup>
<b>Span #2</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup>
<b>Span #3</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup>
<b>Span #4</b>	Span Length =	20.50 ft	Area = 10.0 in <sup>2</sup>
			Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

### DESIGN SUMMARY

<b>Maximum Bending =</b>	99.660 k-ft	<b>Maximum Shear =</b>	21.873 k
Load Combination: 1.0D+0.50S+1.60H, LL Comb Run (L*L*)		Load Combination: 1.0D+0.50S+1.60H, LL Comb Run (L*L*)	
Span # where maximum occurs	Span # 1	Span # where maximum occurs	Span # 1
Location of maximum on span	0.000 ft	Location of maximum on span	0.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	1.259 in		247
Max Upward Transient Deflection	-0.349 in		894
Max Downward Total Deflection	1.259 in		247
Max Upward Total Deflection	-0.059 in		4173

**General Beam Analysis**


Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** PT Gym - N/S Existing 1000#



- +1.4DD+1.6DH
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LL\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LLL\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LLLL)




- +1.4DD+1.6DH
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LL\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LLL\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LLLL)



**General Beam Analysis**

**DESCRIPTION: PT Gym - N/S Existing 1000#**



Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** PT Gym - N/S New 1000# Max Moment

### General Beam Properties

Elastic Modulus	29,000.0 ksi		
<b>Span #1</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #2</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #3</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #4</b>	Span Length =	20.50 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

Load(s) for Span Number 4


Point Load : D = 0.050, L = 1.0 k @ 17.417 ft

### DESIGN SUMMARY


<b>Maximum Bending =</b>	99.659 k-ft	<b>Maximum Shear =</b>	21.873 k
Load Combination = 1.60L+0.50S+1.60H, LL Comb Run (L*L*)		Load Combination = 1.60L+0.50S+1.60H, LL Comb Run (L*L*)	
Span # where maximum occurs	Span # 1	Span # where maximum occurs	Span # 1
Location of maximum on span	0.000 ft	Location of maximum on span	0.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	1.258 in		247
Max Upward Transient Deflection	-0.358 in		870
Max Downward Total Deflection	1.258 in		247
Max Upward Total Deflection	-0.059 in		4199

**General Beam Analysis**

**DESCRIPTION: PT Gym - N/S New 1000# Max Moment**




- +1.40D+1.60H
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*\*LL)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*L\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*L\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*LL\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*LLL)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*L\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*LL)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LL\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LL\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LLL\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LLLL)



- +1.40D+1.60H
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*\*LL)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*L\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*L\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*LL\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*LLL)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*L\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*LL)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LL\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LL\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LLL\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LLLL)

**General Beam Analysis**

**DESCRIPTION: PT Gym - N/S New 1000# Max Moment**



Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** PT Gym - N/S New 1000# Max Shear

### General Beam Properties

Elastic Modulus	29,000.0 ksi		
<b>Span #1</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup>
<b>Span #2</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup>
<b>Span #3</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup>
<b>Span #4</b>	Span Length =	20.50 ft	Area = 10.0 in <sup>2</sup>
			Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

Load(s) for Span Number 4


Point Load : D = 0.050, L = 1.0 k @ 1.167 ft

### DESIGN SUMMARY


<b>Maximum Bending =</b>	99.659 k-ft	<b>Maximum Shear =</b>	22.440 k
Load Combination = 1.60L+0.50S+1.60H, LL Comb Run (L*L*)		Load Combination = 1.60L+0.50S+1.60H, LL Comb Run (L*LL)	
Span # where maximum occurs	Span # 1	Span # where maximum occurs	Span # 3
Location of maximum on span	0.000 ft	Location of maximum on span	26.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	1.259 in		247
Max Upward Transient Deflection	-0.355 in		880
Max Downward Total Deflection	1.259 in		247
Max Upward Total Deflection	-0.059 in		4190

**General Beam Analysis**

**DESCRIPTION: PT Gym - N/S New 1000# Max Shear**




- +1.40D+1.60H
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*\*LL)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*L\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*L\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*LL\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*LLL)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*L\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*LL)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LL\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LL\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LLL\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LLLL)



- +1.40D+1.60H
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*\*LL)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*L\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*L\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*LL\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (\*LLL)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*L\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (L\*LL)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LL\*\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LL\*L)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LLL\*)
- +1.20D+1.60L+0.50S+1.60H, LL Comb Run (LLLL)

**General Beam Analysis**

**DESCRIPTION: PT Gym - N/S New 1000# Max Shear**



CEILING LIFT #36  
 IN E/W

EXISTING

$$V_u = \begin{cases} 13.52K & \text{ORIG BLDG, TYP} \\ 11.17K & \text{ADDN, TYP} \end{cases}$$

$$M_u = \begin{cases} 26.94^{1-K} \\ 39.10^{1-K} \end{cases}$$

NEW

$$V_u = \begin{cases} 14.80K & \text{ORIG BLDG, TYP} \approx 9.5\% \text{ INCREASE} > 5\% \\ & \therefore \text{CHECK BY HAND} \\ 12.29K & \text{ADDN, TYP} \approx 10.0\% \text{ INCREASE} > 5\% \\ & \therefore \text{CHECK BY HAND} \end{cases}$$

$$M_u = \begin{cases} 29.17^{1-K} \approx 8.3\% \text{ INCREASE} > 5\% \therefore \text{CHECK BY HAND} \\ 43.00^{1-K} \approx 10.0\% \text{ INCREASE} > 5\% \therefore \text{CHECK BY HAND} \end{cases}$$

AT ORIG BLDG

CHECK SHEAR

FROM PREV CALCS,  $\phi V_n = 56.76K > V_u = 13.52K$



**Kaplan/  
McLaughlin/  
Diaz**

ARCHITECTS/PLANNERS  
222 VALLEJO STREET  
SAN FRANCISCO 94111  
415-398-5191

**BJSS**

ARCHITECTS/PLANNERS  
320 WEST BAY DRIVE  
OLYMPIA, WASHINGTON  
206-943-4650

STRUCTURAL ENGINEERS  
HAROLD V. SARGENT & ASSOC  
320 WEST BAY DRIVE  
SUITE 218  
OLYMPIA, WA. 98502  
206-943-3590

MECHANICAL ENGINEERS  
BENJAMIN S. NOTKIN &  
ASSOCIATES, INC.  
820 JOHN STREET  
SEATTLE, WA. 98109  
206-682-3611

ELECTRICAL ENGINEERS  
SPARLING & ASSOC., INC.  
1920 EASTLAKE AVE EAST  
SEATTLE, WA. 98102  
206-325-7770

**GOOD  
SAMARITAN  
HOSPITAL**

Puyallup, Washington


SHEET TITLE  
LEVEL 1 FLAT SLAB PLAN



REVISIONS  
NO. DATE DESCRIPTION

SCALE NOTED DATE SEPT 5, 1980

SHEET **S-14**




**NOTES:**  
**SLAB PLACING SEQUENCE**  
 1. PLACE N-S BOTTOM BARS IN COLUMN & MIDDLE STRIPS.  
 2. PLACE E-W BOTTOM BARS IN COLUMN & MIDDLE STRIPS.  
 3. PLACE N-S TOP BARS IN COLUMN STRIPS.  
 4. PLACE E-W TOP BARS IN COLUMN STRIPS.  
 5. PLACE N-S MIDDLE STRIP TOP BARS.  
 6. PLACE E-W MIDDLE STRIP TOP BARS.  
**CODES:**  
 B = BOTTOM  
 T = TOP  
 a. = 5X/6  
 b. = 7X/8  
 c. = 7X/8  
 d. = 5X/6  
 e. = 7X/8  
 f. = 5X/6  
 g. = 7X/8  
 h. = 5X/6  
 i. = 7X/8  
 j. = 5X/6  
 k. = 7X/8  
 l. = 5X/6  
 m. = 7X/8  
 n. = 5X/6  
 o. = 7X/8  
 p. = 5X/6  
 q. = 7X/8  
 r. = 5X/6  
 s. = 7X/8  
 t. = 5X/6  
 u. = 7X/8  
 v. = 5X/6  
 w. = 7X/8  
 x. = 5X/6  
 y. = 7X/8  
 z. = 5X/6

**NOTE:**  
 MINIMUM REINFORCING SHALL BE 10#5  
 SEE SHEET S-15 FOR WALL & COLUMN REINFORCING  
 FOR CURBS, NEWS & SPANDREL WALLS SEE SHEET S-15.

**LEVEL 1 FLAT SLAB PLAN**

**NOTE**  
 ALL SLAB REINFORCING SHALL BE GRADE 60



## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #36 - E/W Existing 1000#

### General Beam Properties

Elastic Modulus	29,000.0 ksi		Area =	10.0 in <sup>2</sup>	Moment of Inertia =	100.0 in <sup>4</sup>
<b>Span #1</b>	Span Length =	14.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia =	100.0 in <sup>4</sup>
<b>Span #2</b>	Span Length =	14.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia =	100.0 in <sup>4</sup>
<b>Span #3</b>	Span Length =	14.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia =	100.0 in <sup>4</sup>



### Applied Loads


Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans :  $D = 0.1550$ ,  $L = 0.050$  k/ft, Tributary Width = 6.0 ft

### DESIGN SUMMARY



<b>Maximum Bending =</b>	32.850 k-ft	<b>Maximum Shear =</b>	13.518 k
Load Combination	$1.00L+0.50S+1.60H$ , LL Comb Run (LL*)	Load Combination	$1.00L+0.50S+1.60H$ , LL Comb Run (*LL)
Span # where maximum occurs	Span # 1	Span # where maximum occurs	Span # 2
Location of maximum on span	14.000 ft	Location of maximum on span	14.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	0.219 in		766
Max Upward Transient Deflection	-0.044 in		3817
Max Downward Total Deflection	0.219 in		766
Max Upward Total Deflection	-0.037 in		4592



### General Beam Analysis

**DESCRIPTION:** Ceiling Lift #36 - E/W Existing 1000#

SPAN 1



Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #36 - E/W New 1000#

### General Beam Properties

Elastic Modulus	29,000.0 ksi				
<b>Span #1</b>	Span Length =	14.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #2</b>	Span Length =	14.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #3</b>	Span Length =	14.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

Load(s) for Span Number 1



Point Load : D = 0.050, L = 1.0 k @ 9.417 ft

### DESIGN SUMMARY

<b>Maximum Bending =</b>	35.132 k-ft	<b>Maximum Shear =</b>	14.798 k
Load Combination: 1.00L+0.50S+1.60H, LL Comb Run (LL*)		Load Combination: 1.00L+0.50S+1.60H, LL Comb Run (LL*)	
Span # where maximum occurs	Span # 1	Span # where maximum occurs	Span # 1
Location of maximum on span	14.000 ft	Location of maximum on span	14.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	0.239 in		703
Max Upward Transient Deflection	-0.052 in		3235
Max Downward Total Deflection	0.239 in		703
Max Upward Total Deflection	-0.045 in		3745


**General Beam Analysis**

**DESCRIPTION:** Ceiling Lift #36 - E/W New 1000#



**General Beam Analysis**

**DESCRIPTION:** Ceiling Lift #36 - E/W New 1000#



## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #36 - E/W Existing Addn 1000#

### General Beam Properties

Elastic Modulus = 29,000.0 ksi  
 Span #1 Span Length = 14.0 ft Area = 10.0 in<sup>2</sup> Moment of Inertia = 100.0 in<sup>4</sup>



### Applied Loads


Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft



### DESIGN SUMMARY

Maximum Bending =	39.102 k-ft	Maximum Shear =	11.172 k
Load Combination	+1.20D+1.60L+0.50S+1.60H	Load Combination	+1.20D+1.60L+0.50S+1.60H
Span # where maximum occurs	Span # 1	Span # where maximum occurs	Span # 1
Location of maximum on span	7.000 ft	Location of maximum on span	0.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	0.090 in		1863
Max Upward Transient Deflection	0.001 in		117427
Max Downward Total Deflection	0.370 in		454
Max Upward Total Deflection	0.004 in		37879



**General Beam Analysis**

**DESCRIPTION:** Ceiling Lift #36 - E/W Existing Addn 1000#





Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #36 - E/W New 1000#

### General Beam Properties

Elastic Modulus 29,000.0 ksi  
 Span #1 Span Length = 14.0 ft Area = 10.0 in<sup>2</sup> Moment of Inertia = 100.0 in<sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

Load(s) for Span Number 1



Point Load : D = 0.050, L = 1.0 k @ 9.417 ft

### DESIGN SUMMARY

Maximum Bending =	42.998 k-ft	Maximum Shear =	12.289 k
Load Combination	+1.20D+1.60L+0.50S+1.60H	Load Combination	+1.20D+1.60L+0.50S+1.60H
Span # where maximum occurs	Span # 1	Span # where maximum occurs	Span # 1
Location of maximum on span	7.350 ft	Location of maximum on span	14.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	0.119 in		1410
Max Upward Transient Deflection	0.002 in		91858
Max Downward Total Deflection	0.400 in		420
Max Upward Total Deflection	0.004 in		37710

### General Beam Analysis

**DESCRIPTION:** Ceiling Lift #36 - E/W New 1000#



### General Beam Analysis


Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27

PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #36 - E/W New 1000#



CHECK FLEXURE

FROM PREV CALCS,  $\phi M_n = 52.35 \text{ k} > M_u \therefore \text{OK}$

AT BLDG ADDN

CHECK SHEAR

$$\phi V_n = \phi 2 \lambda \sqrt{f'_c} b_w d$$

SAME AS ORIG BLDG, EXCEPT  $f'_c = 5000 \text{ psi}$

$$\begin{aligned} \therefore \phi V_n &= 0.75 (2) (1) \sqrt{5000 \text{ psi}} (72 \text{ in}) (8.31 \text{ in}) \\ &= 63.46 \text{ k} > V_u \therefore \text{OK} \end{aligned}$$

CHECK FLEXURE

$$\phi M_n = \phi A_s f_y (d - a/2)$$

SAME AS ORIG BLDG, EXCEPT

$$A_s = 0.31 \text{ in}^2 (12 \text{ in}/16 \text{ in}) (6 \text{ ft}) = 1.40 \text{ in}^2$$

$$a = \frac{1.40 \text{ in}^2 (60 \text{ ksi})}{0.75 (5 \text{ ksi}) (72 \text{ in})} = 0.31 \text{ in}$$

$$\begin{aligned} \therefore \phi M_n &= 0.9 (1.40 \text{ in}^2) (60 \text{ ksi}) (8.31 - 0.31 \text{ in}/2) \\ &= 617 \text{ in-k} = 51.38 \text{ k} > M_u \therefore \text{OK} \end{aligned}$$

$\therefore (E)$  SLAB OK IN E/W

IN N/S

Notes:

At ORIG BLDG, CEILING LIFT HANGERS ALIGN w/  
GRID & (E) COLS, MINIMAL INCREASE IN SHEAR/FLEXURE

At BLDG ADDN, SLAB IS A ONE-WAY SLAB THAT SPANS  
EAST/WEST, CHECK IN NORTH/SOUTH NOT REQD

∴ (E) SLAB OK IN N/S

CEILING LIFT #38

IN E/W

EXISTING

$$V_u = 24.64 \text{ k}$$

$$M_u = 90.41 \text{ k-ft}$$

New

$$V_u = 26.26 \text{ k} \approx 6.6\% \text{ INCREASE} > 5\% \therefore \text{CHECK BY HAND}$$

$$M_u = 94.62 \text{ k-ft} \approx 4.7\% \text{ INCREASE} < 5\% \therefore \text{OK}$$

CHECK SHEAR

$$\text{FROM PREV CALCS, } \phi V_n = 56.76 \text{ k} > V_u \therefore \text{OK}$$

\therefore (E) SLAB OK IN E/W

**Kaplan/  
McLaughlin/  
Diaz**

ARCHITECTS/PLANNERS  
222 VALLEJO STREET  
SAN FRANCISCO 94111  
415-398-5191

**BJSS**

ARCHITECTS/PLANNERS  
320 WEST BAY DRIVE  
OLYMPIA, WASHINGTON  
206-943-4650

STRUCTURAL ENGINEERS  
HAROLD V. SARGENT & ASSOC  
320 WEST BAY DRIVE  
SUITE 218  
OLYMPIA, WA. 98502  
206-943-3590

MECHANICAL ENGINEERS  
BENJAMIN S. NOTKIN &  
ASSOCIATES, INC.  
820 JOHN STREET  
SEATTLE, WA. 98109  
206-682-3611

ELECTRICAL ENGINEERS  
SPARLING & ASSOC., INC.  
1920 EASTLAKE AVE EAST  
SEATTLE, WA. 98102  
206-325-7770

**GOOD  
SAMARITAN  
HOSPITAL**

Puyallup, Washington


SHEET TITLE  
LEVEL 1 FLAT SLAB PLAN



REVISIONS  
NO. DATE DESCRIPTION

SCALE NOTED DATE SEPT 5, 1980

SHEET **S-14**




**NOTES:**  
**SLAB PLACING SEQUENCE**  
 1. PLACE N-S BOTTOM BARS IN COLUMN & MIDDLE STRIPS.  
 2. PLACE E-W BOTTOM BARS IN COLUMN & MIDDLE STRIPS.  
 3. PLACE N-S TOP BARS IN COLUMN STRIPS.  
 4. PLACE E-W TOP BARS IN COLUMN STRIPS.  
 5. PLACE N-S MIDDLE STRIP TOP BARS.  
 6. PLACE E-W MIDDLE STRIP TOP BARS.  
**CODES:**  
 B = BOTTOM  
 T = TOP  
 a = 5x5' C-1  
 b = 5x5' C-2  
 c = 7'5" TOP MIDDLE STRIP OVER COLUMN  
 d = 5'5" TOP MIDDLE STRIP OVER COLUMN

**NOTE:**  
 MINIMUM REINFORCING SHALL BE #5 @ 18" ON CENTER THROUGHOUT FOR CURBS, NEWS & PARAPET WALLS. SEE SHEET S-5.

**LEVEL 1 FLAT SLAB PLAN**

**NOTE:**  
 ALL SLAB REINFORCING SHALL BE GRADE 60



## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #38 - E/W Existing 1000#

### General Beam Properties

Elastic Modulus	29,000.0 ksi				
<b>Span #1</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #2</b>	Span Length =	26.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads


Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

### DESIGN SUMMARY

<b>Maximum Bending =</b>	101.146 k-ft	<b>Maximum Shear =</b>	24.638 k
Load Combination	1.0D+0.50L+0.50S+1.60H, LL Comb Run (LL)	Load Combination	1.0D+0.50L+0.50S+1.60H, LL Comb Run (LL)
Span # where maximum occurs	Span # 1	Span # where maximum occurs	Span # 1
Location of maximum on span	13.000 ft	Location of maximum on span	13.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	2.496 in		124
Max Upward Transient Deflection	-0.296 in		526
Max Downward Total Deflection	2.496 in		124
Max Upward Total Deflection	-0.296 in		526







**General Beam Analysis**

**DESCRIPTION:** Ceiling Lift #38 - E/W Existing 1000#

SPAN 2



Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #38 - E/W New 1000# Max Moment

### General Beam Properties

Elastic Modulus	29,000.0 ksi				
<b>Span #1</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #2</b>	Span Length =	26.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

Load(s) for Span Number 2



Point Load : D = 0.050, L = 1.0 k @ 9.417 ft

### DESIGN SUMMARY

<b>Maximum Bending =</b>	106.590 k-ft	<b>Maximum Shear =</b>	25.906 k
Load Combination: 1.0D+0.50S+1.60H, LL Comb Run (LL)		Load Combination: 1.0D+0.50S+1.60H, LL Comb Run (LL)	
Span # where maximum occurs	Span # 1	Span # where maximum occurs	Span # 1
Location of maximum on span	13.000 ft	Location of maximum on span	13.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	2.614 in		119
Max Upward Transient Deflection	-0.319 in		489
Max Downward Total Deflection	2.614 in		119
Max Upward Total Deflection	-0.319 in		489

### General Beam Analysis

**DESCRIPTION:** Ceiling Lift #38 - E/W New 1000# Max Moment



### General Beam Analysis


Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27

PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #38 - E/W New 1000# Max Moment



Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #38 - E/W New 1000# Max Shear

### General Beam Properties

Elastic Modulus	29,000.0 ksi				
<b>Span #1</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #2</b>	Span Length =	26.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

Load(s) for Span Number 2



Point Load : D = 0.050, L = 1.0 k @ 1.667 ft

### DESIGN SUMMARY

<b>Maximum Bending =</b>	102.818 k-ft	<b>Maximum Shear =</b>	26.256 k
Load Combination: 1.0D+0.50S+1.60H, LL Comb Run (LL)		Load Combination: 1.0D+0.50S+1.60H, LL Comb Run (LL)	
Span # where maximum occurs	Span # 1	Span # where maximum occurs	Span # 1
Location of maximum on span	13.000 ft	Location of maximum on span	13.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	2.513 in		124
Max Upward Transient Deflection	-0.303 in		514
Max Downward Total Deflection	2.513 in		124
Max Upward Total Deflection	-0.303 in		514

### General Beam Analysis

**DESCRIPTION:** Ceiling Lift #38 - E/W New 1000# Max Shear



### General Beam Analysis


Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27

PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #38 - E/W New 1000# Max Shear



IN N/S

EXISTING

$$V_u = \begin{cases} 12.65 \text{ K} & \text{SPAN 1, TYP} \\ 11.36 \text{ K} & \text{SPAN 2, TYP} \end{cases}$$

$$M_u = \begin{cases} 22.65 \text{ K} \\ 12.65 \text{ K} \end{cases}$$

New

$$V_u = \begin{cases} 12.85 \text{ K} & \text{SPAN 1, TYP} \approx 1.6\% \text{ INCREASE} < 5\% \therefore \text{OK} \\ 12.65 \text{ K} & \text{SPAN 2, TYP} \approx 11.4\% \text{ INCREASE} > 5\% \therefore \text{CHECK BY HAND} \end{cases}$$

$$M_u = \begin{cases} 23.66 \text{ K} \approx 4.5\% \text{ INCREASE} < 5\% \therefore \text{OK} \\ 14.05 \text{ K} \approx 11.1\% \text{ INCREASE} > 5\% \therefore \text{OK} \end{cases}$$

CHECK SHEAR

FROM PREV CALCS,  $\phi V_n = 56.76 \text{ K} > V_u \therefore \text{OK}$

CHECK FLEXURE

FROM PREV CALCS,  $\phi M_n = 52.35 \text{ K} > M_u \therefore \text{OK}$

$\therefore (E) \text{ SLAB OK IN N/S}$



Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #38 - N/S Existing 1000#

### General Beam Properties

Elastic Modulus	29,000.0 ksi				
<b>Span #1</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #2</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #3</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #4</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

### DESIGN SUMMARY

<b>Maximum Bending =</b>	29.547 k-ft	<b>Maximum Shear =</b>	12.647 k
Load Combination = 1.60L+0.50S+1.60H, LL Comb Run (LL*L)		Load Combination = 1.60L+0.50S+1.60H, LL Comb Run (LL*L)	
Span # where maximum occurs	Span # 1	Span # where maximum occurs	Span # 1
Location of maximum on span	13.000 ft	Location of maximum on span	13.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	0.158 in		984
Max Upward Transient Deflection	-0.029 in		5333
Max Downward Total Deflection	0.158 in		984
Max Upward Total Deflection	-0.018 in		8475


**General Beam Analysis**

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #38 - N/S Existing 1000#



- +1.4DD+1.6DH
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*LLL)



- +1.4DD+1.6DH
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*LLL)

**General Beam Analysis**


Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27

PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #38 - N/S Existing 1000#



Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #38 - N/S New 1000# Span 1

### General Beam Properties

Elastic Modulus	29,000.0 ksi				
<b>Span #1</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #2</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #3</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #4</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

Load(s) for Span Number 1


Point Load : D = 0.050, L = 1.0 k @ 1.250 ft

### DESIGN SUMMARY


<b>Maximum Bending =</b>	30.098 k-ft	<b>Maximum Shear =</b>	12.849 k
Load Combination: 1.60L+0.50S+1.60H, LL Comb Run (LL*L)		Load Combination: 1.60L+0.50S+1.60H, LL Comb Run (LL*L)	
Span # where maximum occurs	Span # 1	Span # where maximum occurs	Span # 1
Location of maximum on span	13.000 ft	Location of maximum on span	13.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	0.165 in		945
Max Upward Transient Deflection	-0.031 in		5047
Max Downward Total Deflection	0.165 in		945
Max Upward Total Deflection	-0.020 in		7887

**General Beam Analysis**

**DESCRIPTION:** Ceiling Lift #38 - N/S New 1000# Span 1



- +1.4DD+1.6DH
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LL\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LLL\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LLLL)



- +1.4DD+1.6DH
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LL\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LLL\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LLLL)

Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

**General Beam Analysis**


Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27

PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #38 - N/S New 1000# Span 1



Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #38 - N/S New 1000# Span 2

### General Beam Properties

Elastic Modulus	29,000.0 ksi				
<b>Span #1</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #2</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #3</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #4</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

Load(s) for Span Number 2

Point Load : D = 0.050, L = 1.0 k @ 3.250 ft

### DESIGN SUMMARY

<b>Maximum Bending =</b>	31.080 k-ft	<b>Maximum Shear =</b>	12.765 k
Load Combination: 1.60L+0.50S+1.60H, LL Comb Run (LL*L)		Load Combination: 1.60L+0.50S+1.60H, LL Comb Run (LL*L)	
Span # where maximum occurs	Span # 1	Span # where maximum occurs	Span # 1
Location of maximum on span	13.000 ft	Location of maximum on span	13.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	0.158 in		986
Max Upward Transient Deflection	-0.029 in		5333
Max Downward Total Deflection	0.158 in		986
Max Upward Total Deflection	-0.018 in		8620

**General Beam Analysis**


LIC# : KW-06014122, Build:20.24.02.27

PCS STRUCTURAL SOLUTIONS


(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #38 - N/S New 1000# Span 2

SPAN 2



SPAN 2





Project Title:  
Engineer:  
Project ID:  
Project Descr:

## General Beam Analysis


Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27

PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #38 - N/S New 1000# Span 2



CEILING LIFT #41 (700<sup>W</sup>)

IN E/W

EXISTING

$$V_u = 25.23 \text{ k}$$

$$M_u = 90.82 \text{ k-ft}$$

New

$$V_u = 26.31 \text{ k} \approx 4.3\% \text{ INCREASE} < 5\% \therefore \text{OK}$$

$$M_u = 95.14 \text{ k-ft} \approx 4.8\% \text{ INCREASE} < 5\% \therefore \text{OK}$$

IN N/S

EXISTING

$$V_u = \begin{cases} 12.87 \text{ k} & \text{SPAN 1, TYP} \\ 12.49 \text{ k} & \text{SPAN 2, TYP} \end{cases}$$

$$M_u = \begin{cases} 21.88 \text{ k-ft} \\ 17.80 \text{ k-ft} \end{cases}$$

**Kaplan/  
McLaughlin/  
Diaz**

ARCHITECTS/PLANNERS  
222 VALLEJO STREET  
SAN FRANCISCO 94111  
415-398-5191

**BJSS**

ARCHITECTS/PLANNERS  
320 WEST BAY DRIVE  
OLYMPIA, WASHINGTON  
206-943-4650

STRUCTURAL ENGINEERS  
HAROLD V. SARGENT & ASSOC  
320 WEST BAY DRIVE  
SUITE 218  
OLYMPIA, WA. 98502  
206-943-3590

MECHANICAL ENGINEERS  
BENJAMIN S. NOTKIN &  
ASSOCIATES, INC.  
820 JOHN STREET  
SEATTLE, WA. 98109  
206-682-3611

ELECTRICAL ENGINEERS  
SPARLING & ASSOC., INC.  
1920 EASTLAKE AVE EAST  
SEATTLE, WA. 98102  
206-325-7770

**GOOD  
SAMARITAN  
HOSPITAL**

Puyallup, Washington


SHEET TITLE  
LEVEL 1 FLAT SLAB PLAN



REVISIONS  
NO. DATE DESCRIPTION

SCALE NOTED DATE SEPT 5, 1980

SHEET **S-14**




**NOTES:**  
**SLAB PLACING SEQUENCE**  
 1. PLACE N-S BOTTOM BARS IN COLUMN & MIDDLE STRIPS.  
 2. PLACE E-W BOTTOM BARS IN COLUMN & MIDDLE STRIPS.  
 3. PLACE N-S TOP BARS IN COLUMN STRIPS.  
 4. PLACE E-W TOP BARS IN COLUMN STRIPS.  
 5. PLACE N-S MIDDLE STRIP TOP BARS.  
 6. PLACE E-W MIDDLE STRIP TOP BARS.  
**CODES:**  
 B = BOTTOM  
 T = TOP  
 a = 5'x5' OVER COLUMN  
 b = 7'x7' OVER COLUMN  
 c = 7'x5' OVER COLUMN  
 d = 5'x7' OVER COLUMN

**NOTE:**  
 MINIMUM REINFORCING SHALL BE 10#5 PER 12" SPACING FOR CHASE, NEWS & PARAPET WALLS SEE SHEET S-5.

**LEVEL 1 FLAT SLAB PLAN**

**NOTE:**  
 ALL SLAB REINFORCING SHALL BE GRADE 60



Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #41 - E/W Existing 700#

### General Beam Properties

Elastic Modulus	29,000.0 ksi		
<b>Span #1</b>	Span Length =	13.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #2</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #3</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #4</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...


Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

### DESIGN SUMMARY


<b>Maximum Bending =</b>	116.498 k-ft	<b>Maximum Shear =</b>	25.229 k
Load Combination = 1.60L+0.50S+1.60H, LL Comb Run (L*LL)		Load Combination = 1.60L+0.50S+1.60H, LL Comb Run (L*LL)	
Span # where maximum occurs	Span # 3	Span # where maximum occurs	Span # 3
Location of maximum on span	26.000 ft	Location of maximum on span	26.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	2.494 in		125
Max Upward Transient Deflection	-0.445 in		700
Max Downward Total Deflection	2.494 in		125
Max Upward Total Deflection	-0.293 in		1064

**General Beam Analysis**

**DESCRIPTION:** Ceiling Lift #41 - E/W Existing 700#




- +1.4DD+1.6DH
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LL\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LLLL)



- +1.4DD+1.6DH
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LL\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LLLL)

**General Beam Analysis**

**DESCRIPTION: Ceiling Lift #41 - E/W Existing 700#**



Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #41 - E/W New 700# Max Moment

### General Beam Properties

Elastic Modulus	29,000.0 ksi		
<b>Span #1</b>	Span Length =	13.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #2</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #3</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #4</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

Load(s) for Span Number 4


Point Load : D = 0.050, L = 0.70 k @ 11.583 ft

### DESIGN SUMMARY


<b>Maximum Bending =</b>	119.660 k-ft	<b>Maximum Shear =</b>	26.005 k
Load Combination = 1.60L+0.50S+1.60H, LL Comb Run (L*LL)		Load Combination = 1.60L+0.50S+1.60H, LL Comb Run (L*LL)	
Span # where maximum occurs	Span # 3	Span # where maximum occurs	Span # 3
Location of maximum on span	26.000 ft	Location of maximum on span	26.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	2.605 in		119
Max Upward Transient Deflection	-0.481 in		648
Max Downward Total Deflection	2.605 in		119
Max Upward Total Deflection	-0.324 in		963

## General Beam Analysis

DESCRIPTION: Ceiling Lift #41 - E/W New 700# Max Moment



- +1.4DD+1.6DH
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LL\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LLL\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LLLL)



- +1.4DD+1.6DH
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LL\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (\*LLL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*L\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (L\*LL)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LL\*L)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LLL\*)
- +1.2DD+1.6DL+0.5DS+1.6DH, LL Comb Run (LLLL)



**General Beam Analysis**


Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27

PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #41 - E/W New 700# Max Moment



Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #41 - E/W New 700# Max Shear

### General Beam Properties

Elastic Modulus	29,000.0 ksi				
<b>Span #1</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #2</b>	Span Length =	26.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #3</b>	Span Length =	26.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #4</b>	Span Length =	26.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

Load(s) for Span Number 4



Point Load : D = 0.050, L = 0.70 k @ 3.917 ft

### DESIGN SUMMARY

<b>Maximum Bending =</b>	118.447 k-ft	<b>Maximum Shear =</b>	26.306 k
Load Combination: 1.60L+0.50S+1.60H, LL Comb Run (L*LL)		Load Combination: 1.60L+0.50S+1.60H, LL Comb Run (L*LL)	
Span # where maximum occurs	Span # 3	Span # where maximum occurs	Span # 3
Location of maximum on span	26.000 ft	Location of maximum on span	26.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	2.535 in		123
Max Upward Transient Deflection	-0.467 in		667
Max Downward Total Deflection	2.535 in		123
Max Upward Total Deflection	-0.312 in		1000

**General Beam Analysis**

**DESCRIPTION:** Ceiling Lift #41 - E/W New 700# Max Shear



Project Title:  
Engineer:  
Project ID:  
Project Descr:

## General Beam Analysis


Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27

PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #41 - E/W New 700# Max Shear



New

$$V_u = \begin{cases} 12.97\text{K SPAN 1, TYP} \approx 0.8\% \text{ INCREASE} < 5\% \therefore \text{OK} \\ 13.48\text{K SPAN 2, TYP} \approx 7.9\% \text{ INCREASE} > 5\% \therefore \text{CHECK BY HAI'D} \end{cases}$$
$$M_u = \begin{cases} 22.36\text{'-K} \approx 2.2\% \text{ INCREASE} < 5\% \therefore \text{OK} \\ 18.37\text{'-K} \approx 3.2\% \text{ INCREASE} < 5\% \therefore \text{OK} \end{cases}$$

CHECK SHEAR

FROM PREV CALCS,  $\phi V_n = 56.76\text{K} > V_u \therefore \text{OK}$

$\therefore$  (E) SLAB OK IN N/S

Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #41 - N/S Existing 700#

### General Beam Properties

Elastic Modulus	29,000.0 ksi		
<b>Span #1</b>	Span Length =	13.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #2</b>	Span Length =	13.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #3</b>	Span Length =	13.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #4</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

### DESIGN SUMMARY

<b>Maximum Bending =</b>	103.810 k-ft	<b>Maximum Shear =</b>	22.352 k
Load Combination = 1.0D+0.50S+1.60H, LL Comb Run (*L*L)		Load Combination = 1.0D+0.50S+1.60H, LL Comb Run (*L*L)	
Span # where maximum occurs	Span # 4	Span # where maximum occurs	Span # 4
Location of maximum on span	26.000 ft	Location of maximum on span	26.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	1.166 in		267
Max Upward Transient Deflection	-0.151 in		1029
Max Downward Total Deflection	1.166 in		267
Max Upward Total Deflection	-0.151 in		1029



**General Beam Analysis**

LIC# : KW-06014122, Build:20.24.02.27

PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION: Ceiling Lift #41 - N/S Existing 700#**



**General Beam Analysis**


Project File: good sam rehab ceiling lifts.ecb

LIC# : KW-06014122, Build:20.24.02.27

PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #41 - N/S Existing 700#





Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #41 - N/S New 700# Span 1

### General Beam Properties

Elastic Modulus	29,000.0 ksi		
<b>Span #1</b>	Span Length =	13.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #2</b>	Span Length =	13.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #3</b>	Span Length =	13.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #4</b>	Span Length =	26.0 ft	Area = 10.0 in <sup>2</sup> Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

Load(s) for Span Number 1

Point Load : D = 0.050, L = 0.70 k @ 0.8330 ft

### DESIGN SUMMARY

<b>Maximum Bending =</b>	103.810 k-ft	<b>Maximum Shear =</b>	22.352 k
Load Combination = 1.60L+0.50S+1.60H, LL Comb Run (*L*L)		Load Combination = 1.60L+0.50S+1.60H, LL Comb Run (*L*L)	
Span # where maximum occurs	Span # 4	Span # where maximum occurs	Span # 4
Location of maximum on span	26.000 ft	Location of maximum on span	26.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	1.166 in		267
Max Upward Transient Deflection	-0.151 in		1029
Max Downward Total Deflection	1.166 in		267
Max Upward Total Deflection	-0.151 in		1029



**General Beam Analysis**

LIC# : KW-06014122, Build:20.24.02.27

PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION: Ceiling Lift #41 - N/S New 700# Span 1**



Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis


Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27

PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #41 - N/S New 700# Span 1



Project Title:  
 Engineer:  
 Project ID:  
 Project Descr:

## General Beam Analysis

Project File: good sam rehab ceiling lifts.ec6

LIC# : KW-06014122, Build:20.24.02.27


PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** Ceiling Lift #41 - N/S New 700# Span 2

### General Beam Properties

Elastic Modulus	29,000.0 ksi				
<b>Span #1</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #2</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #3</b>	Span Length =	13.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>
<b>Span #4</b>	Span Length =	26.0 ft	Area =	10.0 in <sup>2</sup>	Moment of Inertia = 100.0 in <sup>4</sup>



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Loads on all spans...

Uniform Load on ALL spans : D = 0.1550, L = 0.050 k/ft, Tributary Width = 6.0 ft

Load(s) for Span Number 2

Point Load : D = 0.050, L = 0.70 k @ 2.50 ft

### DESIGN SUMMARY

<b>Maximum Bending =</b>	103.860 k-ft	<b>Maximum Shear =</b>	22.358 k
Load Combination = 1.60L+0.50S+1.60H, LL Comb Run (*L*L)		Load Combination = 1.60L+0.50S+1.60H, LL Comb Run (*L*L)	
Span # where maximum occurs	Span # 4	Span # where maximum occurs	Span # 4
Location of maximum on span	26.000 ft	Location of maximum on span	26.000 ft
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	1.167 in		267
Max Upward Transient Deflection	-0.153 in		1021
Max Downward Total Deflection	1.167 in		267
Max Upward Total Deflection	-0.153 in		1021

**General Beam Analysis**

LIC# : KW-06014122, Build:20.24.02.27

PCS STRUCTURAL SOLUTIONS

(c) ENERCALC INC 1983-2023

**DESCRIPTION: Ceiling Lift #41 - N/S New 700# Span 2**

