



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 16, 2024

Inspection Result: **FAILED**

Permit Number: PRMH20241150

Property Address: 1001 SHAW RD, PUYALLUP, WA 98372;

Contractor: AIR SYSTEMS ENGINEERING 3602 S PINE ST TACOMA, WA 98409-8197

To construct: Replace a split system heat pump (like for like) ~ ABSHER
CONSTRUCTION

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide pan at unit above ceiling as discussed with contractor.
- 2 ; provide protection from U.V. rays at insulation of refrigeration line set as per code.

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684