



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 20, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: B-20-0741

Property Address: 2345 W STEWART, PUYALLUP, WA 98371;

Contractor: RICHARD A FARRIS 2401 W STEWART PUYALLUP, WA 98371-4813
(253) 255-3413

To construct: NEW SFR

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Corrections will stay in place until work has been completed.
These are just reminders. The E&S will be finalized at end of project.

Corrections:

- 1 - Silt fence along west side may need to be extended east a few feet. We will take a look after grading has been completed.
- Silt fence along east side may need to be added. After grading and SFR import we will need to take a look.
- Protect new septic tanks.
- No track out. Maintain rock cleanliness during the wet months.
- No stock piles where dispersion trenches belong.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little
Development Engineering Inspector
JLittle@PuyallupWA.gov
(253) 435-3636