



CITY OF PUYALLUP
Development & Permitting Services
 333 S. Meridian, Puyallup, WA 98371
 (253) 864-4165
www.cityofpuyallup.org

Permit No:
 PRFA20241312

FIRE ALARMS

Puyallup, WA

Job Address	Address: 1023 39TH AVE SE, PUYALLUP, WA 98374 Parcel # 0419034037	ISSUED August 21, 2024
Owner	BCC PUYALLUP LLC 9675 SE 36TH ST STE 115 MERCER ISLAND, WA 98188	
Applicant	James Pan 917 134th St SW Everett, WA 98204 jamesp@redhawkfp.com	
Contractor	RED HAWK FIRE PROTECTION LLC 917 134th ST SW, STE B-3 EVERETT, WA 98204 jamesp@redhawkfp.com WA L&I #:	
Description of Work	One for one replacement for fire incident damaged devices in Battery Room. Replace (4) duct detector monitor module and(2) ceiling horn/strobe. All existing fire alarm panel, field devices and sequence of operations to remain the same. - CENTERIS VOLTAGE PARK	
Permit Types	Fire Alarms	
Expiration Date:	February 17, 2025	
Total ESU's		

Building Components:

Quantity	Units	Description
6	DEVICES	Fire Alarm and Detection System and Related Equipment, Alteration
		Total Value of Work: \$0.00

Standard Conditions:

1. SEE ORIGINAL PERMIT CONDITIONS

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether

Applicant:
 James Pan

specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.