

City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 26, 2024 Inspection Result: PARTIAL PASS

Permit Number: B-20-0180

Property Address: 3601 9TH ST SW, PUYALLUP, WA 98373;

Contractor: THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND

58104 Roger Olson 4520 36th ave s fargo, ND 58104 (701) 850-9953

To construct: HOMEWOOD SUITES SOUTH HILL MALL MOTEL *FEE DEFERRAL-SWR*

REVISION (1) 6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD

PERIMETER DRAINTILE

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 date of inspection 8/14/20245th floor framing inspection of rooms
 - 1. type A unit needs to be verified
 - 2.complete fire stopping at at stair walls
 - 3. provide separation at floor trusses that communicate with multiple units
 - 4. complete truss clips
 - 5.OK TO INSULATE AS DISCUSSED WITH CONTRACTOR

Sincerely,

Kevin Spruell Building Inspector KSpruell@PuyallupWA.gov (253) 841-5590



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org