



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 27, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: B-20-0741

Property Address: 2345 W STEWART, PUYALLUP, WA 98371;

Contractor: RICHARD A FARRIS 2401 W STEWART PUYALLUP, WA 98371-4813
(253) 255-3413

To construct: NEW SFR

On this day we have inspected your construction for **Storm Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Okay to backfill.

Please maintain a 1' separation between the footing drain and roof drains. If connecting together, positive flow at connection point so that the roof drain does not backup the footing drain. Next inspection will be for the roof/footing drain separation at the corner of the building.

Corrections:

Sincerely,

Jason Little



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 435-3636