



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 28, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: B-20-0180

Property Address: 3601 9TH ST SW, PUYALLUP, WA 98373;

Contractor: THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND 58104 Roger Olson 4520 36th ave s fargo, ND 58104 (701) 850-9953

To construct: HOMEWOOD SUITES SOUTH HILL MALL MOTEL *FEE DEFERRAL-SWR*
REVISION (1) 6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD PERIMETER DRAINTILE

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 date of inspection 7/31/2024
 - 1.insulation and vapor barrier at top of wall in pool area approved
- 2 date of inspection 8/8/2024
 - 1.insulation and vapor barrier at pool ceiling approved
- 3 date of inspection 8/13/2024
 - 1.level 5 exterior wall and corridor wall top out insulation and vapor barrier approved
- 4 date of inspection 8/27/2024
 - level 5
 1. from elevator south rooms approved for cover
 2. type A unit provide blocking for bars
 3. type A unit toilet flange to meet accessible code by final
 - 4.bathroom areas not approved for cover

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Kevin Spruell
Building Inspector
KSpruell@PuyallupWA.gov
(253) 841-5590