

TEL: (253) 926.2290 FAX: (253) 922.6150

August 28, 2024

To: Puyallup Fire Prevention 333 S. Meridian Puyallup, WA 98371

Re: Good Sam Pool RM 401 15th Ave SE Puyallup, WA 98372

To whom it may concern,

The sprinkler modifications for the Good Sam Pool RM do not change the hydraulic characteristics of the existing sprinkler system. This project consists of adding sprinklers for TI wall and ceiling changes.

Please feel free to call with any questions.

Sincerely, PATRIOT FIRE PROTECTION, INC.

Mathew Greene Service Project Manager