



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 30, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: B-20-0078

Property Address: 1515 S MERIDIAN, PUYALLUP, WA 98371;

Contractor: BALDWIN GENERAL CONTRACTING PO BOX 686, 0876 ALBANY, OR 93721

To construct: HAMPTON INN ADDITION & PARKING BELOW * REV (1) - 10/26/2023 - LOCATION CHANGE FOR OIL/WATER SEPARATOR IN PARKING LOT * REV (2) - 12/27/2023 - UPDATES TO WALL TYPE, PLANS, SECTIONS, ELEVATIONS & SHEAR WALL DETAILS * REV (3) - 3/25/2024 - UPDATES TO CHASE AND SHAFT WALLS

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 date of inspection 8/28/2024
 - 1.stack 39 floor 3 and 4 complete header install at new opening to existing corridor per detail
 - 2.complete fire stopping
 3. ok to insulateGARAGE AREA
 1. rockwool at pipe penetration's approved
 - 2.provide documentation to support repair of holes with no pipe in them
- 2 date of inspection 8/30/2024
 - 1.stack 39 header at corridor 2nd 3rd 4th floors approved
 2. stack 39 2nd level corridor ok to cover ceiling only

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Kevin Spruell
Building Inspector
KSpruell@PuyallupWA.gov
(253) 841-5590