



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Sep 04, 2024

**Inspection Result:** NOT READY

**Permit Number:** PRCNC20221036

**Property Address:** 1601 39TH AVE SE, PUYALLUP, WA 98374;

**Contractor:** ABSHER CONSTRUCTION CO. PO BOX 280 PUYALLUP, WA 98371-0152

**To construct:** New ~54,000 SF building containing labs, classrooms, faculty and student spaces. REVISION (1) -003/21/2023 - ADDED DETAILS & DESIGN REFINEMENT FROM PERMIT SET TO IFC SET OF DOCUMENTS (NO CHANGE IN SQ FTG OR COST)

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 date of inspection 9/3/2024  
inspection of exterior
  - 1.paint gas pipe
  2. seal penetration's where gas pipe enters building
  - 3.seal foundation at gas meter where water is flowing
  - 4.provide screens at air intakes and exhaust
- LEVEL 0
  1. provide all final letters
  - 2.complete install of doors at vestibule
  - 3.complete floor transition at interior door at vestibule
  4. complete accessible switches at vestibule doors
  - 5.provide ADA signage/ brail at exits
  - 6.provide proper clearance at handrail at gravity lab stairs
  - 7.complete fire stopping at shafts in boiler room
  - 8.Once final letters are on site to review all mechanical will be inspected in boiler room



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Sincerely,

Kevin Spruell  
Building Inspector  
[KSpruell@PuyallupWA.gov](mailto:KSpruell@PuyallupWA.gov)  
(253) 841-5590