



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 05, 2024

Inspection Result: **FAILED**

Permit Number: B-17-0271

Property Address: 3303 8TH AVE SE ;

Contractor:

To construct: GREEN HOUSE

On this day we have inspected your construction for **Engineering Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Please see condition 2 on the permit.

** Engineering Inspector to verify that the existing impervious area is removed as indicated on the approved site plan **

*** Pipe coming into the pond has an invert elevation listed 1-foot below the pond bottom elevation. Pipe must be placed at the same elevation as the pond bottom ***

Has this been completed with no inspection?

Corrections:

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 435-3636