



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 05, 2024 **Inspection Result:** **PASSED**

Permit Number: PRCTI20240250

Property Address: 1019 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: SMAJIC CONSTRUCTION LLC 7405 118TH AVE SE NEWCASTLE, WA 98056 (425) 378-2593

To construct: Interior renovation of approximately 9,193 SF space for receiving and storage of fire department personnel equipment/ clothing. - CENTRAL PIERCE FIRE & RESCUE WAREHOUSE

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684