



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Permit Review Correction Letter

Permit Application #PRCTI20241266

September 05, 2024

The City has completed the review of the above-mentioned permit submittal. All your review comments, conditions, and redlined plans can be found on the [City's permit portal](#). Redlined plans can be found on the City's Permit Portal in the "Reviews" section under "Documents Returned for Corrections". Below please find the permit submittal review comments from your review team and re-submittal instructions. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Re-submittal Instructions

To resubmit, you must address all comments and upload a ~~Correction Response Letter~~ that states how the corrections have been addressed in your resubmitted documents. Avoid using "upload additional docs" unless there is NO submittal item available for your document. Please Note: If you have any questions about how to resubmit, please contact the permit center.

- 1 Log in to your permits portal and navigate to the status page for this permit under the "My Items" tab by selecting the "Upload Submittals" button under the permit number.
- 2 For each submittal item listed re-submit a new version of the submittal item by clicking the "New Version" button next to the file name of the original file submitted. DO NOT click the 'browse' button unless the document you are submitting for that submittal item is not a new version of the originally submitted document. Click 'Upload Documents' at bottom of the page.
- 3 If any re-submittal fees have been assessed, you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid.

Corrections

Corrections to be addressed on the next set of resubmitted plans:

Building Review	Brian Snowden	(253)435-3618	BSnowden@puyallupwa.gov
<ul style="list-style-type: none"> - The text on the Proposed / Existing Floor Plan is not legible. Please submit the plan in it's original sheet size and ensure all notes are legible prior to resubmitting. - The bottom portion of the Structural Plans are cut off, including the sheet numbers and engineer's stamp. - Please show the aisle width between the proposed rack(s) and the existing racks, the lighting of the aisles and exit lighting. The plan set should also include the width and height of the rack(s) (or rack type: Merchandise Display, 2 Level, 3 Level, etc.). Note: the plan resolution is very poor, so this information may already be on the plan set, but is not legible. - The structural plans note that Special Inspections are not required. However, most (perhaps all) of the post-installed anchors noted on sheet 1 of 2 require Special Inspections per their ICC-ES Reports. Please review the report for the proposed anchors and include a Special Inspection schedule if Special Inspections are required by the report and/or anchor manufacturer. Note: If the report(s) state special inspection(s) are required - the final special inspection report must be on site during City inspections. Please also note: Welding is shown on the plans. All welds must be inspected and approved by a WABO certified special inspector - see Chapter 17, section 1705.2 of the 2021 Washington State Building Code. 			

Conditions

The items listed in the table below are conditions of the permit that do not need to be addressed on the next resubmittal of plans but will need to be fulfilled at some point in the permit review process. The "Condition Category" indicates the approximate phase of the permit process by which the condition must be fulfilled for the City to continue processing this permit. "Condition Status" if "Open" means that the condition has not been fulfilled, if "Resolved" means the condition has been fulfilled successfully. For some conditions that require submittal of a document to the City, those documents can be submitted via the Conditions Section of the [City's permit portal](#).

Condition Category	Condition	Department	Condition Status
---------------------------	------------------	-------------------	-------------------------

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center
(253) 864-4165 option 1
permitcenter@puyallupwa.gov